

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	36	546	425	121	AS Per MOD
		67	74				
3	TPC U-8	1	34	235	172	63	AS Per MOD
		66	74				
4	TPC U-5	1	26	473	292	181	AS Per MOD
		66	73	473	338	135	
5	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	PARALI 3,4,5	X	X	X	X	X	NO SCHEDULE
7	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
8	REL G	1	27	479	336	143	AS Per MOD
9	BHUSAWAL-4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	PARALI-7	2	27	230	166	64	AS Per MOD
11	PARALI-6	2	27	230	166	64	AS Per MOD
12	INDIABULL TO MSEDCL	3	27	245	172	73	AS Per MOD
13	KHAPERKHEDA-5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
14	KHAPERKHEDA-U 1 TO 4	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
15	CHANDRAPUR	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	PARAS-3	3	12	182	164	18	DUE TO SYSTEM CONDITION
17	PARAS-4	3	12	210	164	46	DUE TO SYSTEM CONDITION
18	JSW U 1	3	12	275	200	75	DUE TO SYSTEM CONDITION
19	AMNEPL TO REL	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
20	APML U 2 TO MSEDCL	3	13	617	460	157	DUE TO SYSTEM CONDITION
		41	68	617	465	152	DUE TO OUT. OF WARORA-WARDHA PG CKT-I
21	APML U 3 TO MSEDCL	3	13	617	460	157	DUE TO SYSTEM CONDITION
		41	68	617	460	157	DUE TO OUT. OF WARORA-WARDHA PG CKT-I

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 MOD rates revised w.e.f 13-Aug.-2013.