

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW TO MSEB FIRM	1	96	200	140	60	AS PER SYSTEM CONDITION
3	TPC U-6	1	60	473	292	181	AS PER SYSTEM CONDITION
		76	96	473	292	181	AS PER SYSTEM CONDITION
4	TPC U-8	X	X	X	X	X	UNIT SHUT DOWN
5	DTPS REL U1 AND U2	1	27	460	336	124	AS PER SYSTEM CONDITION
		28	45	230	169	61	UNIT-2 TRIPPED AS PER SYSTEM CONDITION
		76	96	460	336	124	UNIT-2 SYN.AS PER SYSTEM CONDITION
6	NASHIK U-3,4,5	1	27	364	284	80	UNIT-5 SHUT DOWN, BID AS PER SYSTEM CONDITION
		30	37	364	284	80	UNIT-5 SHUT DOWN, BID AS PER SYSTEM CONDITION
		76	96	364	284	80	UNIT-5 SHUT DOWN, BID AS PER SYSTEM CONDITION
7	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN
8	RATTANINDIA U1 TO U-6	1	27	490	344	146	AS PER SYSTEM CONDITION UNIT-2,3,5 SHUT DOWN
		30	37	490	344	146	AS PER SYSTEM CONDITION UNIT-2,3,5 SHUT DOWN
		76	96	490	344	146	AS PER SYSTEM CONDITION UNIT-2,3,5 SHUT DOWN
9	PARLEY U-6 AND U-7	1	26	458	332	126	AS PER SYSTEM CONDITION
		30	37	458	332	126	AS PER SYSTEM CONDITION
		76	96	458	332	126	AS PER SYSTEM CONDITION
10	BHUSWAL U-4 AND U-6	1	26	940	644	296	AS PER SYSTEM CONDITION
		30	37	940	644	296	AS PER SYSTEM CONDITION
		76	96	940	644	296	AS PER SYSTEM CONDITION
11	VIPL U-1 AND U-2	1	26	572	382	190	AS PER SYSTEM CONDITION
		30	37	572	382	190	AS PER SYSTEM CONDITION
		76	96	572	382	190	AS PER SYSTEM CONDITION
12	PARLEY U-8	X	X	X	X	X	UNIT SHUT DOWN
13	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	D.C. BELOW TECH MIN UNIT-1 AND UNIT-2, UNIT-3 UNIT-4 SHUT DOWN,
14	PARAS U-3 AND U-4	1	26	460	332	128	AS PER SYSTEM CONDITION
		76	96	460	332	128	AS PER SYSTEM CONDITION
15	ADANI TIRODA 440 PPA	1	26	X	X	X	D.C. ZERO
		83	96	X	X	X	D.C. ZERO
16	KORADI U-5,6,7	X	X	X	X	X	UNIT -5,6,SHUTDOWN UNIT-7 SYN. 16:36HRS RUNNING BELOW TECH MIN
17	ADANI U- 1 (1200+125)MW PP	1	26	614	432	182	AS PER SYSTEM CONDITION
		83	96	432	X	X	D.C. TECH MIN
18	ADANI U-4 (1200+125)MW PP	1	26	614	432	182	AS PER SYSTEM CONDITION
		83	96	432	X	X	D.C. TECH MIN
19	ADANI U-5 (1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
20	KHAPERKHEDA U-6	1	26	423	335	88	AS PER SYSTEM CONDITION
		83	96	423	335	88	AS PER SYSTEM CONDITION
21	CHANDRAPUR U-3 TO U-7	1	6	370	328	42	UNIT-3, UNIT-4 UNIT-6, AS PER SYSTEM CONDITION
		88	96	370	328	42	UNIT-3, SYN. 19:28UNIT-4 23:04HRS UNIT-6 unit-7 shut downAS PER SYSTEM CONDITION
22	KORADI U-8,9,10	1	6	1042	864	178	UNIT-8 SHUT DOWN,AS PER SYSTEM CONDITION
		88	96	868	827	41	UNIT-8 SHUT DOWN,BID AS PER SYSTEM CONDITION
23	JSW U-1	1	6	284	200	84	AS PER SYSTEM CONDITION
		88	96	281	200	81	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	1	6	782	658	124	AS PER SYSTEM CONDITION
		88	96	782	658	124	AS PER SYSTEM CONDITION
25	IEPL TO MSEDCCL DA	X	X	X	X	X	UNIT SHUT DOWN
26	ADANI U-3	X	X	X	X	X	UNIT SHUT DOWN
27	ADANI U-2	1	5	623	432	191	AS PER SYSTEM CONDITION
		90	96	432	X	X	D.C. TECH MIN

Note :  
1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".  
2 M.O.D. RATES REVISED FROM DT. 12TH NOV 2016  
3 # Indicates that back down withdrawn due to Line loading/system constraints.