

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	SWPL U-1,2,4 TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
2	JSW234 TO MSEDCL	1	30	X	X	X	VARIABLE SCHEDULE BID AS PER SYSTEM CONDITION
		45	96	X	X	X	VARIABLE SCHEDULE BID AS PER SYSTEM CONDITION
2	TPC U-8	1	30	204	187	17	AS PER SYSTEM CONDITION
		46	96	204	187	17	AS PER SYSTEM CONDITION
3	TPCU-5	1	30	473	292	181	AS PER SYSTEM CONDITION
		46	96	473	292	181	AS PER SYSTEM CONDITION
4	OTPS REL U-1 AND U-2	1	30	X	X	X	UNIT-2 SSYN. RUNNING TECH MIN. BID AS PER SYSTEM CONDITION
		46	96	226	167	59	UNIT-2 SSYN. BID AS PER SYSTEM CONDITION
5	JSW -2,3,4 TO AEML DA	1	30	X	X	X	AS PER SYSTEM CONDITION
		52	96	55	38.5	16.5	AS PER SYSTEM CONDITION
5	PARALI U-6 AND U-7	X	X	X	X	X	withn for zero schedule as per msedcl
6	PARALI U-8	1	30	229	166	63	AS PER SYSTEM CONDITION
		47	96	229	166	63	AS PER SYSTEM CONDITION
7	BHUSWAL U-3	X	X	X	X	X	AS PER SYSTEM CONDITION UNIT-3 ZERO SCHEDULE BY MSEDCL
8	VPL U-1 AND U-2	1	30	438	356	82	AS PER SYSTEM CONDITION
		47	96	438	356	82	AS PER SYSTEM CONDITION
9	RATTANNIDIA U-1 TO U-5	1	25	465	344	121	AS PER SYSTEM CONDITION
		48	96	465	344	121	AS PER SYSTEM CONDITION
10	NASIK U-3,4 AND U-5	1	25	177	142	35	AS PER SYSTEM CONDITION
		50	96	177	142	35	AS PER SYSTEM CONDITION
11	IEPL TO MSEDCL	X	X	X	X	X	NO SCHEDULE
12	DHARWAL TO MSEDCL	1	23	X	X	X	D.C.TECH. MIN
		50	96	X	X	X	D.C.TECH. MIN
13	JSW U-1	1	22	290	200	90	AS PER SYSTEM CONDITION
		50	96	290	200	90	AS PER SYSTEM CONDITION
14	BHUSWAL U-4 AND U-5	1	22	940	644	296	AS PER SYSTEM CONDITION
		50	96	940	644	296	AS PER SYSTEM CONDITION
15	KORADI U-6, U-7	1	22	X	X	X	UNIT-7 D.C. TECH MIN. UNIT-6 SHUT DOWN
		54	96	X	X	X	UNIT-7 D.C. TECH MIN. UNIT-6 SHUT DOWN
16	KHAERKHEDA U-1 TO U-4	1	22	716	568	148	AS PER SYSTEM CONDITION
		54	96	705	568	137	AS PER SYSTEM CONDITION
17	PARAS U-3 AND U-4	1	22	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		54	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
18	KHAERKHEDA U-5	1	22	428	335	93	AS PER SYSTEM CONDITION
		54	96	428	335	93	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1 (A/PPA 440MW)	1	19	440	0	440	AS PER SYSTEM CONDITION
		54	96	440	0	440	AS PER SYSTEM CONDITION
20	KORADI U-8,9 AND U-10	1	19	X	X	X	D.C. BELOW TECH. MIN
		54	96	X	X	X	D.C. BELOW TECH. MIN
21	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	19	466	432	34	AS PER SYSTEM CONDITION
		54	96	466	432	34	AS PER SYSTEM CONDITION
22	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	19	466	432	34	AS PER SYSTEM CONDITION
		54	96	466	432	34	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	19	466	432	34	AS PER SYSTEM CONDITION
		54	96	466	432	34	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-3 TO U-7	1	19	1102	988	114	AS PER SYSTEM CONDITION
		56	89	1488	1282	186	AS PER SYSTEM CONDITION
		74	96	1488	1282	186	AS PER SYSTEM CONDITION
25	CHANDRAPUR U-8 AND U-9	1	19	844	656	188	AS PER SYSTEM CONDITION
		57	89	884	656	228	AS PER SYSTEM CONDITION
		74	96	893	656	237	AS PER SYSTEM CONDITION
26	ADANI U-2	1	16	623	432	191	AS PER SYSTEM CONDITION
		82	96	623	432	191	AS PER SYSTEM CONDITION
27	ADANI U-3	1	16	623	432	191	AS PER SYSTEM CONDITION
		82	96	623	432	191	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH NOV- 2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.