

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
2	DTPS REL U-1 AND U-2	1	96	455	336	119	AS PER SYSTEM CONDITION
3	JSW TO TATA	X	X	X	X	X	NO SCHEDULE
4	JSW TO BEST	1	96	150	105	45	AS PER SYSTEM CONDITION
5	TPC U-5	X	X	X	X	X	UNIT SHUT DOWN
6	PARALI U-6 AND U-7	1	96	X	X	X	widn for zero schedule as per msedcl
7	NASHIK U-3,4,5	1	96	177	142	35	AS PER SYSTEM CONDITION
8	PARALI U-8	X	X	X	X	X	ZERO SCHEDULE BY MSIEDCL
9	BHUSWAL U-3	X	X	X	X	X	ZERO SCHEDULE BY MSIEDCL
10	VIPL U-1 AND U-2	X	X	X	X	X	UNIT-1 AND UNIT-2 SHUT DOWN
11	RATTANINDIA U-1 TO U-5	1	9	245	172	73	AS PER SYSTEM CONDITION
		10	96	X	X	XX	RPL UNIT- 1 2,3,4,5 ZERO SCHEDULE BY MSIEDCL
12	JSW U-1	1	37	290	200	90	AS PER SYSTEM CONDITION
		52	96	290	200	90	AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	37	940	644	296	AS PER SYSTEM CONDITION
		52	96	893	644	249	AS PER SYSTEM CONDITION
14	KHAERKHEDA U-1 TO U-4	1	35	428	335	93	AS PER SYSTEM CONDITION
		53	96	399	335	64	AS PER SYSTEM CONDITION
15	KORADI U-6 AND U-7	1	34	162	144	18	UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION
		53	96	162	144	18	UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION
16	ADANI TIRODA U-1 ,4,5(PPA 440MW)	1	34	440	0	440	AS PER SYSTEM CONDITION
		53	96	440	0	440	AS PER SYSTEM CONDITION
17	KORADI U-8, U9,U-10	1	31	903	614	89	AS PER SYSTEM CONDITION
		54	96	904	658	46	AS PER SYSTEM CONDITION
18	KHAERKHEDA U-5	1	31	428	335	93	AS PER SYSTEM CONDITION
		54	96	399	335	64	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	30	466	432	34	AS PER SYSTEM CONDITION
		54	96	466	432	34	AS PER SYSTEM CONDITION
20	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	30	466	432	34	AS PER SYSTEM CONDITION
		54	96	466	432	34	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-5(PPA 1200MW&125MW)	1	30	466	432	34	AS PER SYSTEM CONDITION
		54	96	466	432	34	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-3 TO U-7	1	29	1529	1282	247	AS PER SYSTEM CONDITION
		66	96	1501	1282	219	AS PER SYSTEM CONDITION
23	PARAS U-3, U-4	1	29	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		66	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	1	29	922	656	266	AS PER SYSTEM CONDITION
		69	96	922	656	266	AS PER SYSTEM CONDITION
25	ADANI U-2	1	24	623	432	191	AS PER SYSTEM CONDITION
		69	76	623	432	191	AS PER SYSTEM CONDITION
		88	96	623	432	191	AS PER SYSTEM CONDITION
26	ADANI U-3	1	24	623	432	191	AS PER SYSTEM CONDITION
		69	76	623	432	191	AS PER SYSTEM CONDITION
		88	96	623	432	191	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT 12TH JAN 2019

3 # Indicates that back down withdrawn due to Line loading/system constraints.