

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

27-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK	
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)			
1	TPC U-6	1	44	483	145	338	AS PER MOD	
		45	48	483	205	278	DUE TO SYSTEM CONDITION	
		49	66	483	300	183		
		67	71	483	150	333		
		72	96	483	145	338	AS PER MOD	
2	NASIK	1	41	516	425	91	AS PER MOD	
		49	57					
		65	96					
3	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM	
4	JSW U-2,4-MSEDCL	1	39	250	175	75	AS PER MOD	
		72	94					
5	VIPL TO MSEDCL	1	39	85	59.5	26	AS PER MOD	
		50	52	85	72	13		
		66	69	85	59.5	25.5		
		71	93					
6	REL G	1	37	478	336	142	AS PER MOD	
		72	80	478	336	142		
		86	88	478	438	40		
7	KORADI 5,6,7	5	36	297	290	7	AS PER MOD	
		68	68					
8	TPC U-5	10	36	473	300	173	AS PER MOD	
		68	68	473	441	32		

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-May-2013.