

| PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | | 27-Aug-16 |
|--|--------------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|---|
| SR. NO. | GENERATING STN. / STO A | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT SHUTDOWN |
| 2 | NASIK | 1 | 96 | 354 | 283 | 71 | AS PER SYSTEM CONDITION :UNIT-5 ZERO SCHEDULE BY MSEDCL |
| 3 | BHUSWAL U 2,3 | X | X | X | X | X | MSEDCL W/DN UNIT-3 FOR ZERO SCHEDULE AND UNIT-2SHUT DOWN |
| 4 | REL DAHANU U 1&2 | 1 | 96 | 466 | 336 | 130 | AS PER SYSTEM CONDITION |
| 5 | TPC U-5 | 1 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 6 | TPC U-8 | 1 | 96 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| 7 | RATAN INDIA U-1,2,3,4,5. | x | x | X | X | X | MSEDCL W/DN UNIT- 1 TO 5 FOR ZERO SCHEDULE |
| 8 | BHUSWAL U -4 AND U-5 | 1 | 38 | 940 | 644 | 296 | UNIT-4 ZERO SCHEDULE W/DN. BY MSEDCL UNIT-4 SYN.AT4:45HRS B/D AS PER SYSTEM CONDITION |
| | | 47 | 96 | 940 | 644 | 296 | UNIT-4 SYN. B/D AS PER SYSTEM CONDITION |
| 9 | VIPL U1&2 | 1 | 38 | 546 | 382 | 164 | AS PER SYSTEM CONDITION |
| | | 65 | 96 | 546 | 382 | 164 | AS PER SYSTEM CONDITION |
| 10 | KORADI U-5 TO U-7 | 1 | 36 | X | X | X | UNIT-6 SHUT DOWN ANDUNIT-7,5 D.C. BELOW TECH MIN. |
| | | 65 | 96 | X | X | X | UNIT-6 SHUT DOWN ANDUNIT-7,5 D.C. BELOW TECH MIN. |
| 11 | KHAPERKHEDA U1 TO U4 | 1 | 36 | 742 | 572 | 170 | AS PER SYSTEM CONDITION |
| | | 65 | 96 | 742 | 572 | 170 | AS PER SYSTEM CONDITION |
| 12 | ADANI U-1 | 1 | 32 | 611 | 432 | 179 | AS PER SYSTEM CONDITION |
| | | 65 | 74 | 550 | 432 | 118 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 585 | 432 | 153 | AS PER SYSTEM CONDITION |
| 13 | ADANI U-4 | x | x | X | X | X | SHUT DOWN |
| 14 | ADANI U-5 | 1 | 32 | 611 | 432 | 179 | AS PER SYSTEM CONDITION |
| | | 65 | 74 | 575 | 432 | 143 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 575 | 432 | 143 | AS PER SYSTEM CONDITION |
| 15 | PARAS U-3 AND U-4 | 1 | 25 | 450 | 332 | 118 | AS PER SYSTEM CONDITION |
| | | 65 | 74 | 450 | 332 | 118 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 450 | 332 | 118 | AS PER SYSTEM CONDITION |
| 16 | CHANDRAPUR U-3 to 7 | 1 | 25 | 1599 | 1282 | 317 | AS PER SYSTEM CONDITION |
| | | 65 | 70 | 1599 | 1282 | 317 | AS PER SYSTEM CONDITION |
| | | 71 | 74 | 1188 | 954 | 234 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 1188 | 954 | 234 | AS PER SYSTEM CONDITION |
| 17 | KORADI U-8 | 1 | 24 | 520 | 432 | 88 | AS PER SYSTEM CONDITION |
| | | 66 | 74 | 564 | 432 | 132 | AS PER SYSTEM CONDITION |
| | | 82 | 96 | 564 | 432 | 132 | AS PER SYSTEM CONDITION |
| 18 | CHANDRAPUR U-8 | 1 | 24 | 432 | 329 | 103 | AS PER SYSTEM CONDITION |
| | | 66 | 96 | 432 | 329 | 103 | AS PER SYSTEM CONDITION |
| 19 | KHAPERKHEDA U-5 | 1 | 24 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| | | 66 | 74 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| | | 85 | 96 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| 20 | ADANI U-3 | 2 | 22 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |
| | | 71 | 74 | 623 | 545 | 78 | AS PER SYSTEM CONDITION |
| | | 85 | 96 | 610 | 432 | 178 | AS PER SYSTEM CONDITION |
| 21 | ADANI U-2 | 2 | 22 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |
| | | 71 | 74 | 623 | 510 | 113 | AS PER SYSTEM CONDITION |
| | | 85 | 96 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |

NOTE-

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM 12 TH OF AUG 2016
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.