

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DTPS REL U-1 AND U-2	1	33	468	336	122	AS PER SYSTEM CONDITION
		42	71	468	336	122	AS PER SYSTEM CONDITION
		91	96	468	336	122	AS PER SYSTEM CONDITION
2	TPC U-6	1	33	473	292	181	AS PER SYSTEM CONDITION
		43	69	473	292	181	AS PER SYSTEM CONDITION
		91	96	473	292	181	AS PER SYSTEM CONDITION
3	TPC U-8	1	33	204	187	17	AS PER SYSTEM CONDITION
		43	69	204	187	17	AS PER SYSTEM CONDITION
		91	96	204	187	17	AS PER SYSTEM CONDITION
4	NASK U-3,4 AND 5	1	25	172	142	30	AS PER SYSTEM CONDITION unit-6 w/dn for zero schedule by msedclat00hrs of 12/07/2018
		44	69	172	142	30	AS PER SYSTEM CONDITION unit-6 w/dn for zero schedule by msedclat00hrs of 12/07/2018
		92	96	172	142	30	AS PER SYSTEM CONDITION unit-6 w/dn for zero schedule by msedclat00hrs of 12/07/2018
5	BHUSWAL U-3	X	X	X	X	X	UNIT SHUT DOWN
6	RATTANINDIA U-1 TO U-5	1	25	490	344	146	AS PER SYSTEM CONDITION UNIT-2 AND UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL AND UNIT-3 SHUT DOWN
		44	65	490	344	146	AS PER SYSTEM CONDITION UNIT-2 AND UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL AND UNIT-3 SHUT DOWN
		92	96	490	344	146	AS PER SYSTEM CONDITION UNIT-2 AND UNIT-4 W/DN FOR ZERO SCHEDULE BY MSEDCL AND UNIT-3 SHUT DOWN
7	VPL U1 &2	1	24	191	X	X	UNIT-2 SHUT DOWN D.C. BELOW TECH MIN
		54	65	191	X	X	UNIT-2 SHUT DOWN D.C. BELOW TECH MIN
		93	96	191	X	X	UNIT-2 SHUT DOWN D.C. BELOW TECH MIN
8	PARALI U-6 AND U-7	1	24	229	166	63	UNIT-6 SHUT DOWN B/D AS PER SYSTEM CONDITION
		54	65	229	166	63	UNIT-6 SHUT DOWN B/D AS PER SYSTEM CONDITION
		94	96	229	166	63	UNIT-6 SHUT DOWN B/D AS PER SYSTEM CONDITION
9	KHAPERKHEDA U-1 TO U-4	1	24	279	X	X	UNIT-1 AND UNIT-2 SHUT DOWN D.C. TECH MIN
		54	65	279	X	X	UNIT-1 AND UNIT-2 SHUT DOWN D.C. TECH MIN
		94	96	279	X	X	UNIT-1 AND UNIT-2 SHUT DOWN D.C. TECH MIN
10	IDEAL ENERGY	1	24	172	X	X	D.C. TECH MIN
		54	65	160	X	X	D.C. BELOW TECH MIN
		94	96	160	X	X	D.C. BELOW TECH MIN
11	DHARWAL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
12	BHUSWAL U-4 AND U-5	1	22	432	322	110	UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
		54	65	395	322	73	UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
		94	96	432	322	110	UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
13	PARALI U-8	1	22	229	166	63	AS PER SYSTEM CONDITION
		54	65	229	166	63	AS PER SYSTEM CONDITION
		94	96	229	166	63	AS PER SYSTEM CONDITION
14	KHAPERKHEDA U-5	1	22	428	335	93	AS PER SYSTEM CONDITION
		54	65	428	335	93	AS PER SYSTEM CONDITION
		94	96	342	335	7	AS PER SYSTEM CONDITION
15	KORADI U-6 AND U-7	X	X	X	X	X	UNIT SHUT DOWN
16	KORADI U-9 AND U-10	1	22	282	X	X	D.C. BELOW TECH MIN AS PER SYSTEM CONDITION
17	ADANI TIRODA 440MW PPA U-1,4 &5	1	16	190	0	190	AS PER SYSTEM CONDITION
18	PARAS U-3 BU-4	1	16			0	AS PER SYSTEM CONDITION
19	JSW U-1	1	16	275	200	75	AS PER SYSTEM CONDITION
20	ADANI TIRODA U-1 (PPA 1200MW &125mw)	1	16	442	432	10	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	16	442	432	10	AS PER SYSTEM CONDITION
22	ADANI TIRODA U-6 (PPA 1200MW&125MW)	1	16	442	432	10	AS PER SYSTEM CONDITION
23	CHANDRAPUR U-3 TO U-7	1	16	840	808	32	AS PER SYSTEM CONDITION UNIT-3 AND UNIT-7 SHUT DOWN
24	CHANDRAPUR U-8 AND U-9	1	16	294	X	X	D.C. BELOW TECH MIN UNIT-8 SHUT DOWN
25	ADANI U-2	X	X	X	X	X	NO BACK DOWN
26	ADANI U-3	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH AUG-2018

3 # Indicates that back down withdrawn due to Line loading/system constraints.