

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

27-Dec-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	35	483	145	338	AS Per MOD
		36	41	483	280	203	
		42	64	483	395	88	
		65	72	483	405	78	
		73	77	483	265	218	
		78	96	483	145	338	
2	JSW U2&4 TO TPC D	81	84	100	84.5	15.5	AS Per MOD
3	JSW U#4-MSEDCL (Approval No.1409)	25	25	100	70	30	AS Per MOD
		31	32	100	96	4	
4	JSW U#4-MSEDCL (Approval No.1397)	25	25	50	35	15	AS Per MOD
		30	32	50	35	15	
5	NASIK	1	25	516	465	51	AS Per MOD
		81	96	516	465	51	
6	TPC U-5	1	24	473	260	213	AS Per MOD
		83	96	473	360	113	
7	JSW U4 TO MSEDCL	6	20	90	63	27	AS Per MOD
8	JSW U2 TO MSEDCL	9	20	210	147	63	AS Per MOD
9	TPC U-8	X	X	X	X	X	UNIT UNDER OUTAGE
10	BHUSAWAL-2,3	X	X	X	X	X	DC REVISED
11	KORADI 5,6,7	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
12	PARLI 3,4,5	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
13	REL G	9	20	479	336	143	AS Per MOD
14	BHUSAWAL-4	x	x	x	x	x	DC REVISED
15	K'KHEDA U-1,2,3,4	x	x	x	x	x	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
16	PARALI-6	14	18	180	164	16	AS Per MOD
17	CHANDRAPUR	15	18	1852	1829	23	AS Per MOD

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Dec.-2012.