

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

28-Mar-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	42	483	145	338	AS Per MOD
		43	71	483	265	218	
		72	96	483	145	338	
2	NASIK	1	33	521	465	56	AS Per MOD
		96	96	521	515	6	
3	JSW U2&4 TO MSEDCL	1	31	500	350	150	AS Per MOD
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	TPC U-5	1	28	473	260	213	AS Per MOD
6	KORADI 5,6,7	1	24	324	310	14	AS Per MOD
8	PARLI 3,4,5	X	X	X	X	X	UNITS UNDER OUTAGE DUE TO WATER SHORTAGE
7	TPC U-8	1	2	235	180	55	AS Per MOD
		5	24	235			
9	REL G	5	24	479	336	143	AS Per MOD
10	BHUSAWAL-4	7	22	451	322	129	AS Per MOD

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
11	K'KHEDA U-1,2,3,4	7	21	705	620	85	AS Per MOD
12	PARALI-6	X	X	X	X	X	UNIT UNDER OUTAGE DUE TO WATER SHORTAGE
13	CHANDRAPUR	7	20	1824	1537	287	AS Per MOD
14	PARALI-7	X	X	X	X	X	UNIT UNDER OUTAGE DUE TO WATER SHORTAGE
15	K'KHEDA U-5	13	18	425	335	90	AS Per MOD
16	JSW U-1	X	X	X	X	X	UNIT UNDER OUTAGE
17	PARAS-3	14	17	230	208	22	AS Per MOD

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-March-2013.