

## STATEMENT OF GENERATOR / STOA SCHEDULES (EX\_BUS) BACKED DOWN FOR THE DATE:

28-Apr-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	42	483	145	338	AS Per MOD
		43	62	483	205	278	
		63	64	483	190	293	
		65	69	483	205	278	
		70	78	483	145	338	
		79	96	483	145	338	DUE TO SYSTEM CONDITION
2	NASIK	1	8	511	465	46	AS Per MOD
		71	78				
		79	96				DUE TO SYSTEM CONDITION
3	JSW U2&4 TO MSEDCL	14	31	490	332	158	DUE TO LINE CONSTRAINT
		71	78	490	343	147	AS Per MOD
		79	96				DUE TO SYSTEM CONDITION
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	TPC U-5	71	76	473	260	213	AS Per MOD
		77	84				DUE TO SYSTEM CONDITION
6	TPC U-8	72	76	235	180	55	AS Per MOD
7	KORADI 5,6,7	73	75	441	434	7	AS Per MOD
8	PARLI 3,4,5	X	X	X	X	X	UNITS UNDER OUTAGE DUE TO WATER SHORTAGE
9	REL G	73	74	478	474	4	AS Per MOD
10	JSW U-1	12	33	275	160	115	DUE TO LINE CONSTRAINT

**Note :**

<sup>1</sup> Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

<sup>2</sup> MOD rates revised w.e.f 18-April-2013.