

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	NASIK U-3, U-4 & U-5	X	X	X	X	X	U-3&4 UNDER ZERO SCHEDULE & U-5 UNDER CASE-IV
2	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
3	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
4	DTPS U-1 & U-2	1	39	227.5	167	60.5	AS PER SYSTEM CONDITION/U-1 UNDER ZERO SCHEDULE
		54	91	227.5	167	60.5	
5	TPC U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
6	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	TPC U-5	1	89	470	292	178	AS PER SYSTEM CONDITION
8	RATTANINDIA U-1 TO U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
9	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
10	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
11	BHUSAWAL U-4 & U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	APML U-1,U-4 & U-5 (PPA440 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
13	APML U-1,U-4 & U-5 (PPA1200MW,125 MW)	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
14	KORADI U-8 TO U-10	2	18	X	X	X	DC TECH MIN/ U-8 UNDER ZERO SCHEDULE
		30	89	X	X	X	
15	PARAS U-3 & U-4	2	13	454	332	122	AS PER SYSTEM CONDITION
		31	80	454	332	122	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	2	13	308	278	30	AS PER SYSTEM CONDITION/ U-2&3 OUT
		31	76	308	278	30	AS PER SYSTEM CONDITION/ U-2&3 OUT
17	DHARIWAL to MSEDCL (Case- IV)	4	12	185	129.5	55.5	AS PER SYSTEM CONDITION
		31	76	185	129.5	55.5	AS PER SYSTEM CONDITION
18	CHANDRAPUR U-3 TO U-7	33	37	1134	954	180	AS PER SYSTEM CONDITION/ U-7 OUT
		42	76	1134	954	180	AS PER SYSTEM CONDITION/ U-7 OUT
19	CHANDRAPUR U-8 & U-9	33	37	851	656	195	AS PER SYSTEM CONDITION
		42	74	851	656	195	AS PER SYSTEM CONDITION
20	KHAPERKHEDA U-5	34	37	451	335	116	AS PER SYSTEM CONDITION
		42	74	451	335	116	AS PER SYSTEM CONDITION
21	JSW U-1	34	36	286	200	86	AS PER SYSTEM CONDITION
		42	74	286	200	86	AS PER SYSTEM CONDITION
22	APML U-2 & U-3	42	56	1130	864	266	AS PER SYSTEM CONDITION
		62	70	1130	864	266	AS PER SYSTEM CONDITION
23	SWPGL to BEST	44	56	100	70	30	AS PER SYSTEM CONDITION
		52	70	100	70	30	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 # Indicates that back down withdrawn due to Line loading/system constraints.
- 3 * Indicates that back down implemented due to Line loading/system constraints.
- 4 Revised MOD Rates effective from 00:00 hrs of 19th Jun 2020