

STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:

28/07/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	96	445	260	185	AS PER SYSTEM CONDITION
2	TPC U-8	1	96	229	126	103	AS PER SYSTEM CONDITION
3	DTPS U-1 & U-2	1	96	455	250	205	AS PER SYSTEM CONDITION
4	NASIK U-3, U-4 & U-5	1	25	185	102	83	AS PER SYSTEM CONDITION/ U-3 UNDER CASE IV & U-4 UNDER ZERO SCHEDULE
		33	96	185	102	83	
5	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
9	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
10	PARAS U-3 & U-4	1	28	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		33	96	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
11	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
12	BHUSAWAL U-4 & U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
13	RATTANINDIA U-1 TO U-5	1	22	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		43	96	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
14	APML U-1,U-4 & U-5 (PPA 440 MW)	1	19	415	0	415	AS PER SYSTEM CONDITION
		43	76	415	0	415	AS PER SYSTEM CONDITION
		85	96	415	0	415	AS PER SYSTEM CONDITION
15	CHANDRAPUR U-3 TO U-7	1	17	1365	963	402	AS PER SYSTEM CONDITION
		44	72	1365	963	402	AS PER SYSTEM CONDITION
		85	96	1365	963	402	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case- IV)	1	17	185	101.75	83.25	AS PER SYSTEM CONDITION
		44	71	185	101.75	83.25	AS PER SYSTEM CONDITION
		85	96	185	101.75	83.25	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA 125 MW)	1	16	118	96	22	AS PER SYSTEM CONDITION
		44	71	118	96	22	AS PER SYSTEM CONDITION
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	1	16	1132	921	211	AS PER SYSTEM CONDITION
		44	71	1132	921	211	AS PER SYSTEM CONDITION
19	KHAPERKHEDA U-5	44	58	470	256	214	AS PER SYSTEM CONDITION
		63	71	470	256	214	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-8 & U-9	44	58	367	259	108	AS PER SYSTEM CONDITION/ U-9 OUT
		63	71	367	259	108	AS PER SYSTEM CONDITION/ U-9 OUT
21	APML U-2 & U-3	63	70	1140	805	335	AS PER SYSTEM CONDITION
22	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
23	JSW U-1	X	X	X	X	X	NO BACK DOWN
24	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th July 2021
- 6 Nasik U-5 & Paras U-4 kept on bar due to Line loading/system constraints.