

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCH SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	TPC U-5	1	46	473	292	181	AS PER SYSTEM CONDITION
		52	96	473	292	181	AS PER SYSTEM CONDITION
3	TPC U-8	1	46	235	187	48	AS PER SYSTEM CONDITION
		52	96	235	187	48	AS PER SYSTEM CONDITION
4	DTPS REL U1 AND U2	1	44	460	336	124	AS PER SYSTEM CONDITION
		52	96	460	336	124	AS PER SYSTEM CONDITION
5	NASHIK U-3,4,5	1	44	182	142	40	UNIT-4 TSHUT DOWN UNIT-3 SHUT DOWN B/D AS PER SYSTEM CONDITION
		57	60	182	142	40	UNIT-4 SYN 15:55HRS UNIT-3 SHUT DOWN B/D AS PER SYSTEM CONDITION
		61	96	364	294	80	UNIT-4 SYN 15:55HRS UNIT-3 SHUT DOWN B/D AS PER SYSTEM CONDITION
6	RATTANINDIA U1 TO U-5	1	43	245	172	73	UNIT-2 W/DN FOR ZERO SCHEDULE BY MSEDCL, UNIT-4,4,5 SHUT DOWN B/D AS PER SYSTEM CONDITION
		57	96	245	172	73	UNIT-2 W/DN FOR ZERO SCHEDULE BY MSEDCL, UNIT-4,4,5 SHUT DOWN B/D AS PER SYSTEM CONDITION
7	VIPL U-1 AND U-2	1	43	572	382	190	AS PER SYSTEM CONDITION
		64	96	572	382	190	AS PER SYSTEM CONDITION
8	BHUSWAL U-3	1	29	187	144	43	AS PER SYSTEM CONDITION
		39	43	187	144	43	AS PER SYSTEM CONDITION
		70	96	187	144	43	AS PER SYSTEM CONDITION
9	PARLEY U-6 AND U-7	1	29	X	X	X	UNIT-7 SHUT DOWN, D.C. TECH MIN
		39	43	X	X	X	UNIT-7 SHUT DOWN, D.C. TECH MIN
		70	96	X	X	X	UNIT-7 SHUT DOWN, D.C. TECH MIN
10	BHUSWAL UNIT-4 AND UNIU-5	1	29	940	644	296	AS PER SYSTEM CONDITION
		39	43	940	644	296	AS PER SYSTEM CONDITION
		70	96	940	644	296	AS PER SYSTEM CONDITION
11	PARLEY U-8	1	29	X	X	X	D.C. TECH MIN
		39	43	X	X	X	D.C. TECH MIN
		70	96	X	X	X	D.C. TECH MIN
12	KHAPERKHEDA U-1 TO U-4	1	29	467	428	39	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN
		72	96	467	428	39	AS PER SYSTEM CONDITION UNIT-3 SHUT DOWN
13	KORADI U-6 TO UNIT-7	X	X	X	X	X	UNIT-6 AND UNIT-7 SHUT DOWN
14	ADANI TIRODA 440 PPA	1	23	440	0	440	AS PER SYSTEM CONDITION
		73	96	440	0	440	AS PER SYSTEM CONDITION
15	PARAS U-3 AND U-4	1	23	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		73	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
16	ADANI U-1 (1200+125)MW PP	1	23	468	432	36	AS PER SYSTEM CONDITION
		73	96	468	432	36	AS PER SYSTEM CONDITION
17	ADANI U-4 (1200+125)MW PP	1	23	468	432	36	AS PER SYSTEM CONDITION
		73	96	468	432	36	AS PER SYSTEM CONDITION
18	ADANI U-5 (1200+125)MW PP	1	23	468	432	36	AS PER SYSTEM CONDITION
		73	96	468	432	36	AS PER SYSTEM CONDITION
19	KORADI U-8,9,10	1	23	1033	864	169	UNIT-8 SHUT DOWN B/D AS PER SYSTEM CONDITION
		75	96	1033	864	169	UNIT-8 SHUT DOWN B/D AS PER SYSTEM CONDITION
20	CHANDRAPUR U-3 TO U-7	1	23	1226	988	237	AS PER SYSTEM CONDITION UNIT-3,4 SHUT DOWN
		78	96	855	660	195	UNIT-6 TRIPPED 11:41HRS AS PER SYSTEM CONDITION UNIT-3,4 SHUT DOWN
21	KHAPERKHEDA U-5	1	23	440	335	105	AS PER SYSTEM CONDITION
		78	96	470	335	135	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-8 AND U-9	1	23	445	329	116	UNIT-8 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		78	96	445	329	116	UNIT-8 SHUT DOWN, B/D AS PER SYSTEM CONDITION
23	JSW U-1	1	22	289	200	89	AS PER SYSTEM CONDITION
		82	96	289	200	89	AS PER SYSTEM CONDITION
24	IDEAL ENERGY DA	1	22	X	X	X	BELOW TECH MIN
		83	96	X	X	X	BELOW TECH MIN
25	ADANI U-3	X	X	X	X	X	UNIT SHUT DOWN
26	ADANI U-2	1	22	623	432	191	AS PER SYSTEM CONDITION
		83	96	623	432	191	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT. 12/12/2017
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.