

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	1	20	483	145	338	AS Per MOD
		67	72	483	145	338	
		94	96	483	145	338	
2	JSW U-4 (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 00:00 to 05:00 hrs & 21:00 to 24:00 to 190 MW (TECHNICAL MINIMUM)
3	ABHIJIT TO MSEDCL (STOA)	X	X	X	X	X	MSEDCL HAS CURTAILED POWER FROM 52 TO 35MW ( 00:00 TO 06:00 HRS & 21:00 TO 24:00 Hrs)
4	TPC U-5	X	X	X	X	X	UNDER OUTAGE
5	TPC U-8	1	20	230	160	70	AS Per MOD
6	JSW U-2 (STOA)	1	20	275	190	85	AS Per MOD
7	NASHIK	1	20	576	465	111	AS Per MOD
8	REL_G	1	20	480	336	144	AS Per MOD
9	BSL	1	20	322	310	12	AS Per MOD
10	PARLI 4	1	20	173	155	18	AS Per MOD
11	PARLI 5	X	X	X	X	X	Declared Capacity (144 MW) less than TECHNICAL MINIMUM (150 MW)
12	K'KHEDA	1	20	683	609	74	AS Per MOD
13	PARLI_ 6	4	20	180	164	16	AS Per MOD
14	JSW U1	4	20	275	190	85	AS Per MOD
15	PARLI_ 7	5	20	210	164	46	AS Per MOD
16	KORADI#	X	X	X	X	X	
17	CHANDRAPUR	8	20	1897	1806	91	AS Per MOD

# KORADI SCHEDULE WAS REDUCED AS PER MOD. DUE TO LESS AVAILABILITY DECLARED BY KORADI IN REV w.e f Block No. 1 , HENCE NO BACKDOWN.

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 From 19-1-2012, JSW Unit-3 is having CPP transaction with JSW ISPAT for 220 MW RTC, part of the balance power is sold in IEX.

3 Short Term Open Access Contracts of M/s Abhijit are based on station capacity and accordingly Schedule issued to Abhijit is on Station wise basis.