

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

29-Apr-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	34	483	145	338	AS Per MOD
		73	96				DUE TO SYSTEM CONDITION
		35	39	483	230	253	AS Per MOD
		40	50	483	350	133	
		51	69	483	320	163	
		70	72	483	240	243	
2	NASIK	1	31	511	465	46	AS Per MOD
		53	55	511	503	8	
		71	90	511	465	46	DUE TO SYSTEM CONDITION
3	JSW U2&4 TO MSEDCL	7	31	490	343	147	AS Per MOD
		71	90	490	350	140	DC REVISED BY LM CELL
4	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	TPC U-5	8	25	473	260	213	AS Per MOD
6	TPC U-8	10	12	235	180	55	DUE TO SYSTEM CONDITION
		13	17				AS Per MOD
		18	21	235	210	25	DUE TO SYSTEM CONDITION
7	KORADI 5,6,7	10	13	432	425	7	DUE TO SYSTEM CONDITION
		14	16				AS Per MOD
		17	19				DUE TO SYSTEM CONDITION
8	PARLI 3,4,5	X	X	X	X	X	UNITS UNDER OUTAGE DUE TO WATER SHORTAGE
9	REL G	11	13	478	436	42	DUE TO SYSTEM CONDITION
		14	16				AS Per MOD
		17	19				DUE TO SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View

2 MOD rates revised w.e.f 18-April-2013.