

SR. NO.	GENERATING STN. / STO A	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	WPCL TO MSEDCL	74	91	60	42	18	AS PER SYSTEM CONDITION
2	JSW TO MSEDCL	74	90	275	192.5	82.5	AS PER SYSTEM CONDITION
3	DTPS REL U-1 AND U-2	74	87	455	336	119	AS PER SYSTEM CONDITION
4	TPC U-5	74	87	473	292	181	AS PER SYSTEM CONDITION
5	DHARIWAL TO RINFRA (DA)	74	87	85	59.5	25.5	AS PER SYSTEM CONDITION
6	TPC U-8	75	87	204	187	17	AS PER SYSTEM CONDITION
7	VIPL U-1 AND U-2	75	87	286	191	95	AS PER SYSTEM CONDITION
8	NASHIK U-3,4,5	75	87	355	283	72	AS PER SYSTEM CONDITION
9	RATTANINDIA U-1 TO U-5	75	77	980	688	292	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
10	BHUSAWAL U-3	75	77	178	144	34	AS PER SYSTEM CONDITION
11	PARALI U-6 AND U-7	75	77	440	332	108	AS PER SYSTEM CONDITION
12	PARALI U-8	75	77	X	X	X	D.C. BELOW TECH MIN
13	PARAS U-3 AND U-4	X	X	X	X	X	NO BACK DOWN
14	DHARIWAL TO MSEDCL (DA)	X	X	X	X	X	NO BACK DOWN
15	BHUSWAL U-4 AND U-5	X	X	X	X	X	NO BACK DOWN
16	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	NO BACK DOWN
17	ADANI (TIRODA 440MW PPA) U1,4&5	X	X	X	X	X	NO BACK DOWN
18	KORADI U-8,9,10	X	X	X	X	X	NO BACK DOWN
19	ADANI U-1 (1200+125)MW PP	X	X	X	X	X	NO BACK DOWN
20	ADANI U-4 (1200+125)MW PP	X	X	X	X	X	NO BACK DOWN
21	ADANI U-5(1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
22	KORADI U-6 AND U-7	X	X	X	X	X	UNIT SHUT DOWN
23	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	NO BACK DOWN
25	CHANDRAPUR U-3 TO U-7	X	X	X	X	X	UNIT- 3,4,6 SHUT DOWN NO BACK DOWN
26	CHANDRAPUR U-8AND U-9	X	X	X	X	X	NO BACK DOWN
27	ADANI U-2	X	X	X	X	X	SHUT DOWN
28	ADANI U-3	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backindown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM D1 12-Apr-18

3 # Indicates that back down withdrawn due to Line loading/system constraints.