

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:							28-May-17
SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT SHUT DOWN
2	NASHIK	8	46	531	425	106	AS PER SYSTEM CONDITION
		47	96	364	283	81	UNIT-3 WDN AT 11:30HRS AS PER SYSTEM CONDITION
3	REL DAHANU U1 AND U2	8	96	464	336	128	AS PER SYSTEM CONDITION
4	TPC U-8	8	43	235	187	48	AS PER SYSTEM CONDITION
		44	88	X	X	X	#
		81	96	235	187	48	AS PER SYSTEM CONDITION
5	TPC U-5	8	43	430	292	138	AS PER SYSTEM CONDITION
		44	88	X	X	X	#
		81	96	430	292	138	AS PER SYSTEM CONDITION
6	JSW34 TO RINFRA DA1 TPTCL	X	X	X	X	X	NO SCHEDULE
7	RATTANINDIA U1,2,3,4,5	X	X	X	X	X	D.C TECH MIN. UNIT-1 AND UNIT-5 SHUT DOWN
8	BHUSWAL U2,3	12	96	179	144	35	UNIT-2 SHUT DOWN, B/D AS PER SYSTEM CONDITION
9	KORADI U-5 TO U-7	12	96	X	X	X	UNIT-5 , UNIT-6 SHUT DOWN UNIT 7 RUNNING BELOW TECH MIN
10	DHARIWAL TO MSEB	12	96	150	140	10	AS PER SYSTEM CONDITION
11	VIPL U1 AND U2	12	96	546	382	164	AS PER SYSTEM CONDITION UNIT-2 WDN AT.23:52HRS
12	PARLEY U-8	12	96				AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	12	57	940	644	296	AS PER SYSTEM CONDITION
		65	96	940	644	296	AS PER SYSTEM CONDITION
14	PARLEY U-6,7	34	50	458	332	126	AS PER SYSTEM CONDITION
		65	96	458	332	126	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U1 TO U4	34	50	x	x	x	D.C BELOW TECH MIN
		65	96	x	x	x	D.C BELOW TECH MIN
16	JSW RINFRA DA JSW PTC	X	X	X	X	X	B/D VARIABLE SCH.BLK NO.1 TO 12 , 55 TO 67 , 82 TO 96AS PER SYSTEM CONDITION
17	KHAPERKHEDA U-5	34	50	X	X	X	UNIT SHUT DOWNA
		65	96	X	X	X	UNIT SHUT DOWNA
		81	96	X	X	X	UNIT SYN.AT 19:46HRS RUNNING BELOW TECH MINSYSTEM
18	KORADI U8 ,U9,10	34	45	1095	964	131	UNIT-10 SYN. 8:22HRS TRIPPED 12:16HRS SYN. 14:31HRSAS PER SYSTEM CONDITION
		65	75	X	X	X	D.C TECH MIN
		83	96	1475	1453	22	AS PER SYSTEM CONDITION
19	PARAS U-3 ANDU-4	34	45	364	332	32	AS PER SYSTEM CONDITION
		76	82	364	332	32	AS PER SYSTEM CONDITION
		83	96	364	332	32	AS PER SYSTEM CONDITION
20	ADANI 440 PPA	34	42	X	X	X	D.C TECH MIN.
		65	75	X	X	X	D.C TECH MIN.
		83	91	X	X	X	D.C TECH MIN.
21	ADANI U-1(1200MW &125MW PPA)	34	42	X	X	X	D.C TECH MIN.
		65	75	X	X	X	D.C TECH MIN.
		83	91	X	X	X	D.C TECH MIN.
22	ADANI U-4(1200MW &125MW PPA)	34	42	X	X	X	UNIT SHUT DOWN
		65	75	X	X	X	UNIT SHUT DOWN
		83	91	X	X	X	UNIT-4 SYN. AT 15:45HRS D.C TECH MIN.
23	ADANI U-5(1200MW &125MW PPA)	X	X	X	X	X	UNIT SHUT DOWN
24	CHANDRAPUR U3 TO U7	35	42	1026	806	220	UNIT-3SYN. 9:50HRS AND UNIT-6 SHUT DOWN B/DAS PER SYSTEM CONDITION
		65	75	1026	806	220	UNIT-3SYN. 9:50HRS AND UNIT-6 SHUT DOWN B/DAS PER SYSTEM CONDITION
		83	91	1026	806	220	UNIT-3SYN. 9:50HRS AND UNIT-6 SHUT DOWN B/DAS PER SYSTEM CONDITION
25	CHANDRAPUR U8 AND U9	35	42	796	658	138	AS PER SYSTEM CONDITION
		65	75	796	658	138	AS PER SYSTEM CONDITION
		83	91	796	658	138	AS PER SYSTEM CONDITION
26	ADANI UNIT-2	35	42	X	X	X	D.C TECH MIN
		65	75	X	X	X	D.C TECH MIN
		83	91	X	X	X	D.C TECH MIN
27	ADANI U-3	35	42	X	X	X	D.C TECH MIN
		65	75	X	X	X	D.C TECH MIN
		83	91	X	X	X	D.C TECH MIN
28	JSW U-1	65	75	230	200	30	AS PER SYSTEM CONDITION

NOTE:

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D RATES EFFECTIVE FROM 12TH AP May-17
- # Indicates that back down withdrawn due to Line loading/system constraints.