

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

29-Nov-12

| SR. NO. | GENERATING STN. / STOA | Backing Down Period (in Time Block) | | (In MW) | | Backing Down Quantum [Max] in MW [A-B] | REMARK |
|---------|------------------------|-------------------------------------|----|-----------------------|--------------------------------------|--|--|
| | | FROM | TO | Declared Capacity (A) | Target Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | 1 | 35 | 483 | 145 | 338 | AS Per MOD |
| | | 83 | 96 | | | | |
| | | 36 | 43 | 483 | 260 | 223 | |
| | | 51 | 75 | 483 | 425 | 58 | |
| | | 76 | 82 | 483 | 250 | 233 | |
| 2 | TPC U-5 | 1 | 33 | 473 | 260 | 213 | AS Per MOD |
| 3 | JSW U4 TO MSEDCL | X | X | X | X | X | MSEDCL REQUIREMENT OF TECHNICAL MINIMUM |
| | | 21 | 28 | 275 | 192.5 | 82.5 | DUE TO SYSTEM CONDITION |
| 4 | JSW U2 TO MSEDCL | X | X | X | X | X | MSEDCL REQUIREMENT OF TECHNICAL MINIMUM |
| | | 21 | 28 | 225 | 157.5 | 67.5 | DUE TO SYSTEM CONDITION |
| 5 | NASIK | 2 | 28 | 526 | 465 | 61 | AS Per MOD |
| 6 | TPC U-8 | 5 | 24 | 235 | 180 | 55 | AS Per MOD |
| 7 | BHUSAWAL-2,3 | 8 | 22 | 179 | 155 | 24 | AS Per MOD |
| 8 | KORADI | x | x | x | x | x | DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM |
| 9 | PARALI U# 3,4,5 | x | x | x | x | x | DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM |
| 10 | REL-G | 12 | 21 | 479 | 427 | 52 | AS Per MOD |

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 11-Nov-2012.