

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	ECONOMIC SHUT DOWN
2	NASIK	1	25	516	425	91	AS PER MOD
		76	96				DUE TO SYSTEM CONDITION
3	PARALI 3,4,5	1	3	151	138	13	DUE TO SYSTEM CONDITION
		4	20				AS PER MOD
		76	96				DUE TO SYSTEM CONDITION
4	JSW U 2,4 TO BEST(100 MW)	X	X	X	X	X	SCH.GIVEN FROM BLK(41-76)
5	BHUSAWAL-2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	TPC U-5	1	20	473	292	181	DUE TO SYSTEM CONDITION
		81	96	473	360	113	
7	TPC U-8	1	20	235	172	63	DUE TO SYSTEM CONDITION
		89	96	235	200	35	
8	PARALI-6	1	20	180	166	14	DUE TO SYSTEM CONDITION
		78	96				
9	PARALI-7	1	20	180	166	14	DUE TO SYSTEM CONDITION
		78	96				
10	REL G	1	25	475	336	139	DUE TO SYSTEM CONDITION
		89	96				
11	BHUSAWAL-4	X	X	X	X	X	UNIT SHUT DOWN
12	KHAPERKHEDA-U5	1	20	420	335	85	DUE TO SYSTEM CONDITION
		78	96	X	X	X	DC REVISED TO BELOW TECHNICAL MINIMUM DUE TO PCO
13	KORADI 5,6,7	1	77	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
		78	96	284	272	12	DUE TO SYSTEM CONDITION
14	INDIABULL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
15	CHANDRAPUR	1	20	1303	1163	140	DUE TO SYSTEM CONDITION
		78	96	1395	1215	180	
16	KHAPER KHEDA U 1 TO 4	1	20	475	426	49	DUE TO SYSTEM CONDITION
		78	96	367	340	27	
17	JSW U-1	1	20	275	200	75	DUE TO SYSTEM CONDITION
		79	96				
19	ADANI U-1	1	20	617	432	185	DUE TO SYSTEM CONDITION
		85	96				
20	PARAS -U3	1	20	182	164	18	DUE TO SYSTEM CONDITION
		85	96				
21	PARAS U4	1	20	182	168	14	DUE TO SYSTEM CONDITION
		85	96				

TPC U 5 IN BLK(78-80) , U 8 IN BLK(78-88) & REL G IN BLK(78-88) BACKING DOWN NOT IMPLEMENTED DUE TO LINE LOADING CONSTRAINT IN MUMBAI SYSTEM.

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- MOD rates revised w.e.f 12-Nov.-2013.