

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCH SCHEDULE (in MW)		Backing Down Quantum (Max) in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW TO MSEB FIRM	1	16	200	140	60	AS PER SYSTEM CONDITION
		84	96	200	140	60	AS PER SYSTEM CONDITION
3	TPC U-5	1	16	473	292	181	AS PER SYSTEM CONDITION
		84	96	473	292	181	AS PER SYSTEM CONDITION
4	TPC U-8	X	X	X	X	X	UNIT SHUT DOWN
5	DTPS REL U1 AND U2	1	16	460	336	124	AS PER SYSTEM CONDITION
		85	96	460	336	124	UNIT-2 TRIPPED 7:21 AND SYN. 9:29HRS AS PER SYSTEM CONDITION
6	NASHIK U-3,4,5	1	2	X	X	X	UNIT-5 SHUT DOWN, B/D AS PER SYSTEM CONDITION
		3	16	160	142	18	UNIT-5 SHUT DOWN, UNIT-3 SYN. 3:10 TRIPPED 3:26B/D AS PER SYSTEM CONDITION
		85	96	320	284	36	UNIT-5 SHUT DOWN, UNIT-3 SYN. 5:58HRS B/D AS PER SYSTEM CONDITION
7	BHUSWAL U-2 AND U-3	X	X	X	X	X	UNIT-2 AND UNIT-3 SHUT DOWN unit-3 syn. 22:55hrs running below tech min
8	RATTANINDIA U1 TO U-5	1	14	490	344	146	AS PER SYSTEM CONDITION UNIT-2 ,3, 5 SHUT DOWN
		85	96	490	344	146	AS PER SYSTEM CONDITION UNIT-2 ,3, 5 SHUT DOWN
9	PARLEY U-6 AND U-7	1	10	458	332	126	AS PER SYSTEM CONDITION
		85	96	458	332	126	AS PER SYSTEM CONDITION
10	BHUSWAL U-4 AND U-5	1	8	658	644	14	AS PER SYSTEM CONDITION
		85	96	658	644	14	AS PER SYSTEM CONDITION
11	VIPL U-1 AND U-2	1	8	286	191	95	AS PER SYSTEM CONDITION
		85	96	471	362	109	UNIT-2 SYN. 21:51hrs AS PER SYSTEM CONDITION
12	PARLEY U-8	1	8	X	X	X	D.C. BELOW TECH MIN
		85	96	X	X	X	D.C. BELOW TECH MIN
13	KHAPERKhedA U-1 TO U-4	X	X	X	X	X	UNIT-1,2,3,4 SHUT DOWN
14	PARAS U-3 AND U-4	1	7	460	332	128	AS PER SYSTEM CONDITION
		87	96	x	x	x	D.C. BELOW TECH MIN
15	ADANI TIRODA 440 PPA	1	7	215	X	X	D.C. TECH MIN
		87	96	274	38.22	235.78	AS PER SYSTEM CONDITION
16	KORADI U-5,6,7	1	7	X	X	X	UNIT -5,6,SHUTDOWN UNIT-7 RUNNING BELOW TECH MIN
		87	96	X	X	X	UNIT -5,6,SHUTDOWN UNIT-7 RUNNING BELOW TECH MIN
17	ADANI U-1 (1200+125)MW PP	1	7	324	X	X	D.C. TECH MIN
		87	96	412	X	X	D.C. TECH MIN
18	ADANI U-4 (1200+125)MW PP	1	7	324	X	X	D.C. TECH MIN
		87	96	412	X	X	D.C. TECH MIN
19	ADANI U-5 (1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
20	KHAPERKhedA U-5	1	7	423	335	88	AS PER SYSTEM CONDITION
		87	96	423	335	88	AS PER SYSTEM CONDITION
21	CHANDRAPUR U-3 TO U-7	87	96	736	656	80	UNIT-5 UNIT-7 SHUT DOWN,AS PER SYSTEM CONDITION
22	KORADI U-8,9,10	87	96	550	432	118	UNIT-8 SHUT DOWN,UNIT-10 TRIPPED 5:00HRS AS PER SYSTEM CONDITION
23	JSW U-1	X	X	X	X	X	UNIT SHUT DOWN
24	CHANDRAPUR U-8 AND U-9	X	X	X	X	X	NO BACK DOWN
25	IEPL TO MSEDCL DA	X	X	X	X	X	UNIT SHUT DOWN
26	ADANI U-3	X	X	X	X	X	UNIT SHUT DOWN
27	ADANI U-2	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM DT. 12TH NOV 2016

3 # Indicates that back down withdrawn due to Line loading/system constraints.