STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

29-Dec-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down	
		FROM	то	Declared Capacity <i>(A)</i>	Targat Despatched Schedule (Min) (B)	Quantum [Max] in MW [A-B]	REMARK
1	TPC U-6	х	х	Х	х	Х	ECONOMIC SHUT DOWN
2	NASIK	1	36	516	425	91	
		64 82	65 96	516 516	512 425	4 AS PER MOD 91	
	PARALI 3,4,5	1	32	- 282	276	6	
3		82	96				AS PER MOD
4	BHUSAWAL-2,3	х	х	х	х	Х	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
5	PARALI-7	х	х	Х	х	Х	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
6	JSW U 2,4 TO BEST(100 MW)	х	х	х	х	х	NO SCHEDULE
7	PARALI-6	х	х	Х	х	Х	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
	BHUSAWAL-4	1	32	330	322	8	AS PER MOD
9		82	96	360	322	38	
	TPC U-5	1	32			181	AS PER MOD
10		83	96	473	292		
	TPC U-8	1	30	235	172	63	AS PER MOD
11		83	96				
12	KORADI 5,6,7	х	х	х	х	х	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
	REL G	1	28		336	142	AS PER MOD
13		83	96	478			
	KHAPER KHEDA U 1 TO 4	1	25	556	526	30	AS PER MOD
14		85	96	585	555	30	DUE TO SYSTEM CONDITION
15	KHAPERKHEDA-U5	1	25	423	335	88	AS PER MOD
		85	96	451	335	116	DUE TO SYSTEM CONDITION
	CHANDRAPUR	1	24	1382	1206	176	AS PER MOD
16		85	88				DUE TO SYSTEM CONDITION
		89	96				AS PER MOD
	INDIABULL TO MSEDCL	1	22	- 245	172	73	AS PER MOD
17		23	24				DUE TO SYSTEM CONDITION
		85	88				
		89	96				AS PER MOD
	PARAS -U3	1	21	220	164	56	AS PER MOD
		22	24				DUE TO SYSTEM CONDITION
18		85	90	191	164	27	
		91	96				AS PER MOD
	PARAS U4	1	21	· 220 · 191	168	52	AS PER MOD
19		22	24				DUE TO SYSTEM CONDITION
		85	91				
		92	96				AS PER MOD
20	APML U-1	1	24	605	432	173	DUE TO SYSTEM CONDITION
		85	96	605	460	145	
	JSW U-1	1	7	275	200	75	DUE TO SYSTEM CONDITION
21		8	20				AS PER MOD
		86	96				DUE TO SYSTEM CONDITION
22	APML U-2,3	1	20	623	432	191	
		89	96				DUE TO SYSTEM CONDITION
		07	70				

 Note :
 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

 2
 MOD rates revised w.e.f 12-Dec.-2013.