

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW U-2 3 AND 4 TO MSEDCL	1	96	200	140	60	AS PER SYSTEM CONDITION
2	DHARIWAL TO MSEDCL	1	96	205	143.5	61.5	AS PER SYSTEM CONDITION
3	JSW TO AEML (DA)	1	96	305	213.5	91.5	AS PER SYSTEM CONDITION
4	TPC U-8	2	36	227	172	32	AS PER SYSTEM CONDITION
		43	49	227	172	32	AS PER SYSTEM CONDITION
		53	59	227	172	32	AS PER SYSTEM CONDITION
		70	96	227	172	32	AS PER SYSTEM CONDITION
5	DTPS U-1 & U-2	2	36	428	336	92	AS PER SYSTEM CONDITION
		43	47	428	336	92	AS PER SYSTEM CONDITION
		53	59	428	336	92	AS PER SYSTEM CONDITION
		70	96	428	336	92	AS PER SYSTEM CONDITION
6	VIPL U-1 & U-2	X	X	X	X	X	UNIT OUT DUE TO COAL SHORTAGE
7	TPC U-5	2	36	473	292	181	AS PER SYSTEM CONDITION
		43	47	473	292	181	AS PER SYSTEM CONDITION
		53	59	473	292	181	AS PER SYSTEM CONDITION
		70	96	473	292	181	AS PER SYSTEM CONDITION
8	PARALI U-6 & U-7	X	X	X	X	X	ZERO SCHEDULE BY MSEDCL
9	BHUSAWAL U-3	X	X	X	X	X	ZERO SCHEDULE BY MSEDCL
10	NASHIK U-3, U-4 & U-5	12	21	374	283	91	AS PER SYSTEM CONDITION
		33	36	374	283	91	AS PER SYSTEM CONDITION
		44	47	374	283	91	AS PER SYSTEM CONDITION
		53	59	374	283	91	AS PER SYSTEM CONDITION
		71	96	374	283	91	AS PER SYSTEM CONDITION
11	RATTANINDIA U-1 TO U-5	12	21	245	172	73	UNIT-1,2,4,5 ZERO SCHEDULE BY MSEDCL
		33	36	245	172	73	UNIT-1,2,4,5 ZERO SCHEDULE BY MSEDCL
		44	47	245	172	73	UNIT-1,2,4,5 ZERO SCHEDULE BY MSEDCL
		53	57	245	172	73	UNIT-1,2,4,5 ZERO SCHEDULE BY MSEDCL
		71	96	245	172	73	UNIT-1,2,4,5 ZERO SCHEDULE BY MSEDCL
12	PARALI U-8	12	21	229	166	63	AS PER SYSTEM CONDITION
		33	36	229	166	63	AS PER SYSTEM CONDITION
		44	47	229	166	63	AS PER SYSTEM CONDITION
		53	57	229	166	63	AS PER SYSTEM CONDITION
		71	96	229	166	63	AS PER SYSTEM CONDITION
13	KORADI U-6 & U-7	12	21	180	155	25	AS PER SYSTEM CONDITION
		33	36	180	155	25	AS PER SYSTEM CONDITION
		53	57	180	155	25	AS PER SYSTEM CONDITION
		71	96	180	155	25	AS PER SYSTEM CONDITION
14	KORADI U-8 TO U-10	12	21	1278	1278	0	AS PER SYSTEM CONDITION
		33	36	1278	1278	0	AS PER SYSTEM CONDITION
		53	57	1278	1278	0	AS PER SYSTEM CONDITION
		71	96	1278	1278	0	AS PER SYSTEM CONDITION
15	BHUSAWAL U-4 & U-5	33	36	940	644	296	AS PER SYSTEM CONDITION
		53	57	940	644	296	AS PER SYSTEM CONDITION
		71	96	940	644	296	AS PER SYSTEM CONDITION
16	JSW U-1	34	34	290	200	90	AS PER SYSTEM CONDITION
		53	55	290	200	90	AS PER SYSTEM CONDITION
		72	78	290	200	90	AS PER SYSTEM CONDITION
		83	88	290	200	90	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-3 TO U-7	73	78	1153	954	199	AS PER SYSTEM CONDITION
		83	96	1153	954	199	AS PER SYSTEM CONDITION
18	ADANI U-1, U-4 & U-5 (PPA 440 MW)	73	76	440	0	440	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1(PPA 1200MW&125MW)	73	76	1399	1296	103	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-8 & U-9	73	76	902	658	244	AS PER SYSTEM CONDITION
21	PARAS U-3 & U-4	73	76	458	332	126	AS PER SYSTEM CONDITION
22	KHAPERKHEDA U-1 TO U-4	73	76	432	425	7	AS PER SYSTEM CONDITION
23	KHAPERKHEDA U-5	73	76	428	335	93	AS PER SYSTEM CONDITION
24	ADANI U-2 & 3	X	X	X	X	X	NO BACK DOWN

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES REVISED FROM DT. 16TH APRIL- 2019
- # Indicates that back down withdrawn due to Line loading/system constraints.