

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

30-May-13

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	43	483	145	338	AS PER MOD
		44	57	483	275	208	
		58	66	483	390	93	
		67	71	483	250	233	
		72	96	483	145	338	
2	NASIK	1	38	516	425	91	AS PER MOD
		71	78				
		80	96				
3	BHUSAWAL 2,3	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
4	VIPL TO MSEDCL	1	96	X	X	X	DC REVISED BY LM CELL
5	JSW U-2,4-MSEDCL	1	96	X	X	X	DC REVISED BY LM CELL
6	REL G	1	9	X	X	X	#
		10	37	478	336	142	AS PER MOD
		71	78	478	336	142	
7	KORADI 5,6,7	X	X	X	X	X	DC REVISED DUE TO PCQ
8	TPC U-5	9	9	X	X	X	#
		10	13	473	292	181	DUE TO SYSTEM CONDITION
		21	34	473	330	143	AS PER MOD
9	TPC U-8	13	13	X	X	X	#
		14	20	235	180	55	AS PER MOD
		27	29	235	215	20	

SCHEDULE WAS REDUCED AS PER MOD. BUT, BACKDOWN WAS WITHDRAWN DUE TO REAL TIME SYSTEM CONDITIONS.

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-May-2013.