

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW U-2 3 AND 4 TO TPCD	1	58	50	35	15	AS PER SYSTEM CONDITION
		63	66	50	35	15	AS PER SYSTEM CONDITION
		72	88	50	35	15	AS PER SYSTEM CONDITION
		96	96	50	35	15	AS PER SYSTEM CONDITION
2	JSW TO AEML (DA)	1	58	130	91	39	AS PER SYSTEM CONDITION
		63	66	130	91	39	AS PER SYSTEM CONDITION
		72	88	130	91	39	AS PER SYSTEM CONDITION
		96	96	130	91	39	AS PER SYSTEM CONDITION
3	JSW U-2 3 AND 4 TO MSDECL	1	58	200	140	60	AS PER SYSTEM CONDITION
		63	66	200	140	60	AS PER SYSTEM CONDITION
		72	88	200	140	60	AS PER SYSTEM CONDITION
		96	96	200	140	60	AS PER SYSTEM CONDITION
4	DHARIWAL TO AEML	1	3	150	84	36	AS PER SYSTEM CONDITION
		9	58	150	84	36	AS PER SYSTEM CONDITION
		63	66	150	84	36	AS PER SYSTEM CONDITION
		72	88	150	84	36	AS PER SYSTEM CONDITION
5	JSW TO AEML	96	96	150	84	36	AS PER SYSTEM CONDITION
		1	3	100	70	30	AS PER SYSTEM CONDITION
		9	58	100	70	30	AS PER SYSTEM CONDITION
		63	66	100	70	30	AS PER SYSTEM CONDITION
6	DTPS U-1 & U-2	72	88	100	70	30	AS PER SYSTEM CONDITION
		96	96	100	70	30	AS PER SYSTEM CONDITION
		12	43	456	336	120	AS PER SYSTEM CONDITION
		44	48	456	336	120	AS PER SYSTEM CONDITION
7	VIPL U-1 & U-2	49	71	X	X	X	#
8	PARALI U-6 & U-7	72	74	456	336	120	AS PER SYSTEM CONDITION
9	TPC U-8	96	96	456	336	120	AS PER SYSTEM CONDITION
		X	X	X	X	X	UNIT OUT DUE TO COAL SHORTAGE
		X	X	X	X	X	ZERO SCHEDULE BY MSDECL
		9	57	227	172	55	AS PER SYSTEM CONDITION
10	TPC U-5	64	66	227	172	55	AS PER SYSTEM CONDITION
		73	74	227	172	55	AS PER SYSTEM CONDITION
		96	96	227	172	55	AS PER SYSTEM CONDITION
		9	57	473	292	111	AS PER SYSTEM CONDITION
11	PARALI U-8	64	66	473	292	111	AS PER SYSTEM CONDITION
12	BHUSAWAL U-3	73	74	473	292	111	AS PER SYSTEM CONDITION
13	RATTANINDIA U-1 TO U-5	96	96	473	292	111	AS PER SYSTEM CONDITION
		12	19	490	344	146	AS PER SYSTEM CONDITION
		23	56	490	344	146	AS PER SYSTEM CONDITION
		73	74	490	344	146	AS PER SYSTEM CONDITION
14	NASHIK U-3, U-4 & U-5	13	17	561	425	136	AS PER SYSTEM CONDITION
		28	36	561	425	136	AS PER SYSTEM CONDITION
		41	44	561	425	136	AS PER SYSTEM CONDITION
		49	55	561	425	136	AS PER SYSTEM CONDITION
15	KORADI U-8 TO U-10	13	17	1515	864	651	AS PER SYSTEM CONDITION
		28	36	1515	864	651	AS PER SYSTEM CONDITION
		41	44	1515	864	651	AS PER SYSTEM CONDITION
		49	55	1515	864	651	AS PER SYSTEM CONDITION
16	KORADI U-6 & U-7	13	17	162	155	7	AS PER SYSTEM CONDITION
		28	36	162	155	7	AS PER SYSTEM CONDITION
		41	44	162	155	7	AS PER SYSTEM CONDITION
		49	55	162	155	7	AS PER SYSTEM CONDITION
17	BHUSAWAL U-4 & U-5	15	17	470	322	148	AS PER SYSTEM CONDITION
		28	36	470	322	148	AS PER SYSTEM CONDITION
		41	42	470	322	148	AS PER SYSTEM CONDITION
		50	55	470	322	148	AS PER SYSTEM CONDITION
18	JSW U-1	15	16	290	200	90	AS PER SYSTEM CONDITION
		28	35	290	200	90	AS PER SYSTEM CONDITION
		41	42	290	200	90	AS PER SYSTEM CONDITION
		51	54	290	200	90	AS PER SYSTEM CONDITION
19	ADANI U-1, U-4 & U-5 (PPA 440 MW)	15	16	440	0	440	AS PER SYSTEM CONDITION
		28	35	440	0	440	AS PER SYSTEM CONDITION
		41	42	440	0	440	AS PER SYSTEM CONDITION
20	CHANDRAPUR U-3 TO U-7	29	34	1574	1282	292	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-1(PPA 1200MW&125MW)	X	X	X	X	X	NO BACK DOWN
22	PARAS U-3 & U-4	X	X	X	X	X	NO BACK DOWN
23	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
24	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	NO BACK DOWN
25	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
26	ADANI U-2 & 3	X	X	X	X	X	NO BACK DOWN

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES REVISED FROM DT. 12TH MAY- 2019
- # Indicates that back down withdrawn due to Line loading/system constraints.