

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	29	33	450	260	190	AS PER SYSTEM CONDITION #
		88	92	450	260	190	AS PER SYSTEM CONDITION #
2	TPC U-8	29	33	229	126	103	AS PER SYSTEM CONDITION #
3	DTPS U-1 & U-2	29	33	224	174	50	AS PER SYSTEM CONDITION #/ U-1 OUT
4	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
5	NASIK U-3, U-4 & U-5	29	70	177	102	75	AS PER SYSTEM CONDITION#/ U-3 UNDER
		88	96	177	102	75	CASE IV & U-5 UNDER ZERO SCHEDULE
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	APML U-1,U-4 & U-5 (PPA440 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
8	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
9	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	APML U-1,U-4 & U-5 (PPA 125 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	APML U-1,U-4 & U-5 (PPA 1200 MW)	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
12	SWPGL to MSEDCL	29	74	240	132	108	AS PER SYSTEM CONDITION
		88	96	240	132	108	AS PER SYSTEM CONDITION
13	PARAS U-3 & U-4	29	35	440	243	197	AS PER SYSTEM CONDITION
		43	55	440	243	197	AS PER SYSTEM CONDITION
		60	74	440	243	197	AS PER SYSTEM CONDITION
		88	94	440	243	197	AS PER SYSTEM CONDITION
		31	35	185	101.75	83.25	AS PER SYSTEM CONDITION
14	DHARIWAL to MSEDCL (Case-IV)	43	55	185	101.75	83.25	AS PER SYSTEM CONDITION
		60	74	185	101.75	83.25	AS PER SYSTEM CONDITION
		88	94	185	101.75	83.25	AS PER SYSTEM CONDITION
		44	54	940	518	422	AS PER SYSTEM CONDITION
15	BHUSAWAL U-4 & U-5	60	73	940	518	422	AS PER SYSTEM CONDITION
		88	92	940	518	422	AS PER SYSTEM CONDITION
		63	68	617	413	204	AS PER SYSTEM CONDITION
16	KHAPERKHEDA U-1 TO U-4	63	68	617	413	204	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-3 TO U-7	63	68	890	607	283	AS PER SYSTEM CONDITION/ U-4&7 OUT
18	RATTANINDIA U-1 TO U-5	63	66	1200	900	300	AS PER SYSTEM CONDITION
19	KORADI U-8 TO U-10	X	X	X	X	X	NO BACK DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACK DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACK DOWN
22	SWPGL to BEST	X	X	X	X	X	NO BACK DOWN
23	APML U-2 & U-3	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	NO BACK DOWN

Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 * Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 16th May 2021