

PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE:

30/06/2019

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW U-2 3 AND 4 TO BEST 2	X	X	0	0	0	NO SCHEDULE
2	JSW U-2 3 AND 4 TO AEML DA	X	X	0	0	0	NO SCHEDULE
3	PARALI U-8	X	X	X	X	X	ZERO SCHEDULE BY MSEDCL
4	JSW TO AEML	1	96	315	220.5	94.5	AS PER SYSTEM CONDITION
5	VIPL U-1 & U-2	X	X	X	X	X	UNIT OUT DUE TO COAL SHORTAGE
6	DHARIWAL TO AEML	1	96	160	112	48	AS PER SYSTEM CONDITION
7	TPC U-8	1	96	225	172	53	AS PER SYSTEM CONDITION
8	DTPS U-1 & 2	1	96	456	336	120	AS PER SYSTEM CONDITION
9	TPC U-5	1	96	473	292	181	AS PER SYSTEM CONDITION
10	PARALI U-6 & U-7	X	X	X	X	X	UNIT OUT DUE TO WATER SHORTAGE
11	BHUSAWAL U-3	1	96	187	144	43	AS PER SYSTEM CONDITION
12	RATTANINDIA U-1 TO U-5	1	96	720	516	204	UNIT-2,5 ZERO SCHEDULE BY MSEDCL
13	NASHIK U-3, U-4 & U-5	1	96	511	425	86	AS PER SYSTEM CONDITION
14	KORADI U-6 & U-7	1	96	270	270	0	AS PER SYSTEM CONDITION
15	KORADI U-8 TO U-10	1	96	750	750	0	AS PER SYSTEM CONDITION
16	BHUSAWAL U-4 & U-5	1	76	470	322	148	AS PER SYSTEM CONDITION
		83	96	470	322	148	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-3 TO U-7	1	76	1554	1275	279	AS PER SYSTEM CONDITION
		83	96	1554	1275	279	AS PER SYSTEM CONDITION
18	ADANI U-1, U-4 & U-5 (PPA 440 MW)	1	75	306	0	306	AS PER SYSTEM CONDITION
		90	96	306	0	306	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1(PPA 1200MW&125MW)	4	75	921	864	57	AS PER SYSTEM CONDITION
		90	96	921	864	57	AS PER SYSTEM CONDITION
20	JSW U-1	4	75	280	200	80	AS PER SYSTEM CONDITION
		92	96	280	200	80	AS PER SYSTEM CONDITION
21	PARAS U-3 & U-4	5	75	458	332	126	AS PER SYSTEM CONDITION
		93	96	458	332	126	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-8 & U-9	5	75	940	658	282	AS PER SYSTEM CONDITION
		93	96	940	658	282	AS PER SYSTEM CONDITION
23	KHAPERKHEDA U-1 TO U-4	5	75	585	567	18	AS PER SYSTEM CONDITION
24	KHAPERKHEDA U-5	5	73	428	335	93	AS PER SYSTEM CONDITION
25	ADANI U-2 & 3	6	25	1246	864	382	AS PER SYSTEM CONDITION
		42	71	1246	864	382	AS PER SYSTEM CONDITION

Note :

- Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.
Maximum backingdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- M.O.D. RATES REVISED FROM DT. 12TH JUNE- 2019
- # Indicates that back down withdrawn due to Line loading/system constraints.