

## STATEMENT OF GENERATOR SCHEDULE (EX\_BUS) BACKED DOWN FOR THE DATE:

30/08/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSWEL to AEML_DA	5	22	237	130.35	106.65	AS PER SYSTEM CONDITION
		61	66	237	130.35	106.65	AS PER SYSTEM CONDITION
		81	96	237	130.35	106.65	AS PER SYSTEM CONDITION
2	TPC U-5	5	22	470	260	210	AS PER SYSTEM CONDITION #
		81	96	470	260	210	AS PER SYSTEM CONDITION #
3	TPC U-8	81	94	229	126	103	AS PER SYSTEM CONDITION #
4	BHUSAWAL U-3	7	20	151	104	47	AS PER SYSTEM CONDITION
		61	66	151	104	47	AS PER SYSTEM CONDITION
		82	96	151	104	47	AS PER SYSTEM CONDITION
5	DTPS U-1 & U-2	X	X	X	X	X	NO BACKING DOWN #
6	NASIK U-3, U-4 & U-5	7	20	177	102	75	AS PER SYSTEM CONDITION#/ U-5 OUT & U-3 UNDER CASE IV
		61	66	177	102	75	
		82	96	177	102	75	
7	PARALI U-6 & U-7	7	20	227	121	106	AS PER SYSTEM CONDITION/ U-6 OUT
		61	66	227	121	106	AS PER SYSTEM CONDITION/ U-6 OUT
		82	96	227	121	106	AS PER SYSTEM CONDITION/ U-6 OUT
8	KORADI U-6	7	20	162	103	59	AS PER SYSTEM CONDITION
		61	66	162	103	59	AS PER SYSTEM CONDITION
		82	96	162	103	59	AS PER SYSTEM CONDITION
9	PARAS U-3 & U-4	8	20	194	122	72	AS PER SYSTEM CONDITION/ U-3 OUT
		61	66	194	122	72	AS PER SYSTEM CONDITION/ U-3 OUT
		93	96	194	122	72	AS PER SYSTEM CONDITION/ U-3 OUT
10	DHARIWAL to MSEDCL (Case-IV)	93	96	185	101.75	83.25	AS PER SYSTEM CONDITION/ Unit synch at 22:30 hrs
11	PARALI U-8	8	19	200	122	78	AS PER SYSTEM CONDITION
		62	65	200	122	78	AS PER SYSTEM CONDITION
		93	96	200	122	78	AS PER SYSTEM CONDITION
12	SWPGL to MSEDCL	9	19	X	X	X	DC TECH MIN
		62	65	X	X	X	DC TECH MIN
		95	96	X	X	X	DC TECH MIN
13	KHAPERKHEDA U-1 TO U-4	10	18	512	413	99	AS PER SYSTEM CONDITION
		62	65	512	413	99	AS PER SYSTEM CONDITION
14	BHUSAWAL U-4 & U-5	10	15	440	259	181	AS PER SYSTEM CONDITION/ U-4 OUT
		62	65	440	259	181	AS PER SYSTEM CONDITION/ U-4 OUT
15	CHANDRAPUR U-3 TO U-7	12	15	1217	963	254	AS PER SYSTEM CONDITION
16	APML U-1,U-4 & U-5 (PPA 440 MW)	X	X	X	X	X	NO BACKING DOWN
17	RATTANINDIA U-1 TO U-5	X	X	X	X	X	NO BACKING DOWN
18	APML U-1,U-4 & U-5 (PPA 125 MW)	X	X	X	X	X	NO BACKING DOWN
19	APML U-1,U-4 & U-5 (PPA 1200 MW)	X	X	X	X	X	NO BACKING DOWN
20	CHANDRAPUR U-8 & U-9	X	X	X	X	X	NO BACKING DOWN
21	KHAPERKHEDA U-5	X	X	X	X	X	NO BACKING DOWN
22	KORADI U-8 TO U-10	X	X	X	X	X	NO BACKING DOWN
23	APML U-2 & U-3	X	X	X	X	X	NO BACKING DOWN
24	JSW U-1	X	X	X	X	X	NO BACKING DOWN
25	SWPGL to BEST	X	X	X	X	X	NO BACKING DOWN

## Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.  
Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 \* Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 29th Aug 2021