

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCH SCHEDULE (in MW)		Backing Down Quantum (Max) in MW (A-B)	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (B)		
1	TPC U-6	X	X	X	X	X	UNIT WITHDRAWN ON ECONOMIC SHUTDOWN
2	JSW TO MSEB FIRM	1	25	200	140	60	AS PER SYSTEM CONDITION
		52	59	200	140	60	AS PER SYSTEM CONDITION
		79	96	200	140	60	AS PER SYSTEM CONDITION
3	JSW TO RINFRA DA	X	X	X	X	X	LESS SCHEDULE
4	JSW MSEDCCL FIRM	1	25	70	49	21	AS PER SYSTEM CONDITION
		52	59	70	49	21	AS PER SYSTEM CONDITION
		79	96	70	49	21	AS PER SYSTEM CONDITION
5	DHARIWAL TO MSEB	X	X	X	X	X	UNIT SHUT DOWN
6	PARAJI U-6 AND U-7	X	X	X	X	X	UNIT-6 AND UNIT-7 WIDN FOR ZERO SCHEDULE BY MSEDCCL
7	TPC U-5	1	23	X	X	X	D.C. BELOW TECH MIN
		53	59	X	X	X	D.C. BELOW TECH MIN
		79	96	X	X	X	D.C. BELOW TECH MIN
8	DTPS REL U1 AND U2	1	23	458	336	122	AS PER SYSTEM CONDITION
		54	59	458	336	122	AS PER SYSTEM CONDITION
		79	96	458	336	122	AS PER SYSTEM CONDITION
9	TATA U-8	1	23	235	187	48	AS PER SYSTEM CONDITION
		79	96	235	187	48	AS PER SYSTEM CONDITION
10	NASHIK U-3,4,5	1	22	324	284	40	AS PER SYSTEM CONDITION UNIT-5 WIDN FOR ZERO SCHEDULE BY MSEDCCL
		80	96	506	425	81	UNIT-5 SYN.17-20HRS AND UNIT-3 WIDN 23:35 , BID AS PER SYSTEM CONDITION
11	BHUSWAL U-2 AND U-3	1	22	X	X	X	UNIT-2 SHUT DOWN UNIT-3 D.C TECH MIN
		80	96	X	X	X	UNIT-2 SHUT DOWN UNIT-3 D.C TECH MIN
12	RATTANINDIA U1 TO U-5	1	22	735	516	219	UNIT-3,5 SHUT DOWN , S BIDAS PER SYSTEM CONDITION
		80	96	735	516	219	UNIT-3,5 SHUT DOWN , S BIDAS PER SYSTEM CONDITION
13	PARLEY U-8	1	22	180	166	14	AS PER SYSTEM CONDITION
		81	96	180	166	14	AS PER SYSTEM CONDITION
14	BHUSWAL U-4 AND U-5	1	22	658	644	14	AS PER SYSTEM CONDITION
		81	96	658	644	14	AS PER SYSTEM CONDITION
15	KHAPERKHEDA U-1 TO U-4	1	22	480	431	49	UNIT-3 SHUT DOWNAS PER SYSTEM CONDITION
		81	96	X	X	X	UNIT-3 SHUT DOWND.C. BELOW TECH MIN
16	VIPL U-1 AND U-2	1	22	572	382	190	AS PER SYSTEM CONDITION
		81	96	572	382	190	AS PER SYSTEM CONDITION
17	ADANI TIRODA 440 PPA	1	22	306	0	306	AS PER SYSTEM CONDITION
		84	96	306	0	306	AS PER SYSTEM CONDITION
18	ADANI U- 1 (1200+125)MW PP	1	22	461	432	29	AS PER SYSTEM CONDITION
		84	96	461	432	29	AS PER SYSTEM CONDITION
19	ADANI U-4 (1200+125)MW PP	1	22	461	432	29	AS PER SYSTEM CONDITION
		84	96	461	432	29	AS PER SYSTEM CONDITION
20	ADANI U-5 (1200+125)MW PP	X	X	X	X	X	UNIT SHUT DOWN
21	KHAPERKHEDA U-5	1	22	430	335	95	AS PER SYSTEM CONDITION
		89	96	405	335	70	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-3 TO U-7	1	22	1030	988	42	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		89	96	1184	988	196	UNIT-3 SHUT DOWN,UNIT-4 SHUT DOWN AS PER SYSTEM CONDITION
23	KORADI U-5,6,7	1	17	X	X	X	UNIT-7 D.C TECH MIN UNIT-5 AND UNIT-6 SHUT DOWNAS PER SYSTEM CONDITION
		89	96	X	X	X	UNIT-7 D.C TECH MIN UNIT-5 AND UNIT-6 SHUT DOWNAS PER SYSTEM CONDITION
24	PARAS U-3 AND U-4	1	17	421	332	89	AS PER SYSTEM CONDITION
		89	96	421	332	89	AS PER SYSTEM CONDITION
25	CHANDRAPUR U-8 AND U-9	1	17	948	658	290	AS PER SYSTEM CONDITION
		89	96	900	658	242	AS PER SYSTEM CONDITION
26	KORADI U-8,9,10	1	17	X	X	X	D.C. BELOW TECH MIN
		89	96	1065	742	323	AS PER SYSTEM CONDITION
27	JSW U-1	1	16	280	200	80	AS PER SYSTEM CONDITION
		89	96	280	200	80	AS PER SYSTEM CONDITION
28	ADANI U-3	1	16	623	432	191	AS PER SYSTEM CONDITION
		89	96	623	445	178	AS PER SYSTEM CONDITION
29	ADANI U-2	X	X	X	X	X	UNIT SHUT DOWN

Note :
1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
2 M.G.D. RATES REVISED FROM DT: 12TH OCT. 2017
3 # Indicates that back down withdrawn due to Line loading/system constraints.