

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
2	DTPS U-1 & U-2	1	21	456	336	120	AS PER SYSTEM CONDITION
		81	96	456	336	120	AS PER SYSTEM CONDITION
3	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
4	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
5	PARAS U-3 & U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
6	JSW TO AEML_DA	1	20	132.66	92.86	39.80	AS PER SYSTEM CONDITION
		81	96	132.66	92.86	39.80	AS PER SYSTEM CONDITION
7	TPC U-5	1	20	473	292	181	AS PER SYSTEM CONDITION
		81	96	473	292	181	AS PER SYSTEM CONDITION
8	TPC U-8	1	20	X	X	X	DC TECH MIN
		81	96	X	X	X	DC TECH MIN
9	NASHIK U-3, U-4 & U-5	1	20	172	141	31	AS PER SYSTEM CONDITION / U-4 UNDER ZERO SCHEDULE & U-3 UNDER CASE-IV
		81	96	172	141	31	
10	RATTANINDIA U-1 TO U-5	X	X	X	X	X	U-1 OUT & U-2,3,4&5 UNDER ZERO SCHEDULE
11	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	U-4 OUT & U-1,2&3 UNDER ZERO SCHEDULE
12	BHUSAWAL U-4 & U-5	1	20	832	644	188	AS PER SYSTEM CONDITION
		81	96	832	644	188	AS PER SYSTEM CONDITION
13	KHAPERKHEDA U-5	1	20	475	335	140	AS PER SYSTEM CONDITION
		81	96	475	335	140	AS PER SYSTEM CONDITION
14	PARALI U-6 & U-7	1	20	458	332	126	AS PER SYSTEM CONDITION
		82	96	458	332	126	AS PER SYSTEM CONDITION
15	JSW TO AEML_DA	1	20	290.00	203.00	87.00	AS PER SYSTEM CONDITION
		84	96	290.00	203.00	87.00	AS PER SYSTEM CONDITION
16	DHARIWAL TO AEML_DA	1	20	80.00	56.00	24.00	AS PER SYSTEM CONDITION
		84	96	80.00	56.00	24.00	AS PER SYSTEM CONDITION
17	CHANDRAPUR U-3 TO U-7	1	20	1123	954	169	AS PER SYSTEM CONDITION/ U-7 OUT
		86	96	1123	954	169	AS PER SYSTEM CONDITION/ U-7 OUT
18	PARALI U-8	1	18	229	166	63	AS PER SYSTEM CONDITION
		86	96	229	166	63	AS PER SYSTEM CONDITION
19	CHANDRAPUR U-8 & U-9	1	18	921	656	265	AS PER SYSTEM CONDITION
		86	96	921	656	265	AS PER SYSTEM CONDITION
20	DHARIWAL TO MSDDL(CASE IV)	1	16	X	X	X	DC TECH MIN
21	APML U-1,U-4&U-5 (PPA440 MW)	1	12	440	0	440	AS PER SYSTEM CONDITION
22	KORADI U-8 TO U-10	8	11	1184	864	320	AS PER SYSTEM CONDITION/ U-10 OUT
23	APML U-1,U-4&U-5 (PPA1200MW,125 MW)	X	X	X	X	X	NO BACK DOWN
24	JSW U-1	X	X	X	X	X	NO BACK DOWN
25	ADANI U-2 & U-3	X	X	X	X	X	NO BACK DOWN

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.

Indicates that back down withdrawn due to Line loading/system constraints.

2 Revised MOD Rates effective from 00:00 HRS of 12th Nov 2019 (JSW TO AEML & DHARIWAL TO AEML DA POWER ADDED

3