

STATEMENT OF GENERATOR / STOA SCHEDULES (EX_BUS) BACKED DOWN FOR THE DATE:

30-Dec-12

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		(In MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Target Despatched Schedule (Min) (B)		
1	TPC U-6	1	96	483	145	338	AS Per MOD
2	JSW U#4-MSEDCL (Approval No.1409)	25	53	100	70	30	AS Per MOD
3	NASIK	1	52	344	310	34	AS Per MOD
4	TPC U-5	1	33	473	260	213	AS Per MOD
		80	96	473	260	213	
5	JSW U2 TO MSEDCL	1	11	210	147	63	AS Per MOD
		80	96	210	147	63	
6	JSW U4 TO MSEDCL	2	10	90	63	27	AS Per MOD
		81	82	90	82	8	
		85	90	90	63	27	
		94	96	90	63	27	
7	TPC U-8	X	X	X	X	X	UNIT UNDER OUTAGE
8	BHUSAWAL-2,3	3	6	161	155	6	AS Per MOD
		85	90	170	155	15	
		94	96	170	155	15	
9	KORADI 5,6,7	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
10	PARLI 3,4,5	X	X	X	X	X	DECLARED CAPACITY IS LESS THAN TECHNICAL MINIMUM
11	REL G	4	7	479	396	83	AS Per MOD
		85	90	479	451	28	
		94	96	479	441	38	

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backing down quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 MOD rates revised w.e.f 12-Dec.-2012.