

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	SWPL U-1,2,4 TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
2	JSW234 TO MSEDCL	1	96	X	X	X	VARIABLE SCHEDULE 1TO 96 BLOCK
2	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
3	TPCU-5	1	96	473	292	181	AS PER SYSTEM CONDITION
4	DTPS REL U-1 AND U-2	1	96	227	166	61	AS PER SYSTEM CONDITION
5	JSW -2,3,4 TO AEML DA	1	96	55	38.5	16.5	AS PER SYSTEM CONDITION
5	PARALI U-6 AND U-7	1	96	X	X	X	widn for zero schedule as per msedcl
6	PARALI U-8	1	96	229	166	63	AS PER SYSTEM CONDITION
7	BHUSWALU-3	X	X	X	X	X	AS PER SYSTEM CONDITION UNIT-3 ZERO SCHEDULE BY MSEDCL
8	VIFL U-1 AND U-2	1	96	273	191	82	UNIT-1 SHUT DOWN AS PER SYSTEM CONDITION
9	RATTANINDIA U-1 TO U-5	x	x	x	x	x	AS PER SYSTEM CONDITION
10	NASIK U-3,4 AND U-5	1	43	177	142	35	AS PER SYSTEM CONDITION
		48	96	177	142	35	AS PER SYSTEM CONDITION
11	IEPL TO MSEDCL	X	X	X	X	X	NO SCHEDULE
12	DHARIWAL TO MSEDCL	1	37	X	X	X	D.C.TECH. MIN
		50	96	X	X	X	D.C.TECH. MIN
13	JSW U-1	1	37	290	200	90	AS PER SYSTEM CONDITION
		51	96	290	200	90	AS PER SYSTEM CONDITION
14	BHUSWAL U-4 AND U-5	1	32	940	644	296	AS PER SYSTEM CONDITION
		51	96	940	644	296	AS PER SYSTEM CONDITION
15	KORADI U-6, U-7	1	32	X	X	X	UNIT-7 D.C. TECH MIN UNIT-6 SHUT DOWN
		51	96	X	X	X	UNIT-7 D.C. TECH MIN UNIT-6 SHUT DOWN
16	KHAERKHEDA U-1 TO U-4	1	32	711	568	143	AS PER SYSTEM CONDITION
		51	96	711	568	143	AS PER SYSTEM CONDITION
17	PARAS U-3 AND U-4	1	32	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		51	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
18	KHAPERKHEDA U-5	1	32	428	335	93	AS PER SYSTEM CONDITION
		51	96	428	335	93	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1 ,4,5(PPA 440MW)	1	30	440	0	440	AS PER SYSTEM CONDITION
		53	96	440	0	440	AS PER SYSTEM CONDITION
20	KORADI U-8,9 AND U-10	1	30	X	X	X	D.C. BELOW TECH. MIN
		58	96	X	X	X	D.C. BELOW TECH. MIN
21	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	29	466	432	34	AS PER SYSTEM CONDITION
		58	96	466	432	34	AS PER SYSTEM CONDITION
22	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	29	466	432	34	AS PER SYSTEM CONDITION
		58	96	466	432	34	AS PER SYSTEM CONDITION
23	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	29	466	432	34	AS PER SYSTEM CONDITION
		58	96	466	432	34	AS PER SYSTEM CONDITION
24	CHANDRAPUR U-3 TO U-7	1	29	1505	1282	223	AS PER SYSTEM CONDITION
		61	96	1505	1282	223	AS PER SYSTEM CONDITION
25	CHANDRAPUR U-8 AND U-9	1	28	898	656	242	AS PER SYSTEM CONDITION
		61	96	898	656	242	AS PER SYSTEM CONDITION
26	ADANI U-2	1	26	623	432	191	AS PER SYSTEM CONDITION
		80	96	623	432	191	AS PER SYSTEM CONDITION
27	ADANI U-3	1	26	623	432	191	AS PER SYSTEM CONDITION
		80	96	623	432	191	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT 12TH NOV- 2018
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.