

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-8	1	24	204	187	17	AS PER SYSTEM CONDITION
		48	96	204	187	17	AS PER SYSTEM CONDITION
2	DTPS REL U-1 AND U-2	1	24	455	336	119	AS PER SYSTEM CONDITION
		48	96	455	336	119	AS PER SYSTEM CONDITION
3	JSW TO TATA	X	X	X	X	X	NO SCHEDULE
4	JSW TO BEST	1	24	150	105	45	AS PER SYSTEM CONDITION
		48	96	150	105	45	AS PER SYSTEM CONDITION
5	TPC U-5	1	24	473	292	181	AS PER SYSTEM CONDITION
		48	96	473	292	181	AS PER SYSTEM CONDITION
6	PARALI U-6 AND U-7	X	X	X	X	X	widen for zero schedule as per msedcl
7	NASHIK U-3,4,5	1	24	182	142	40	AS PER SYSTEM CONDITION unit-3 AND UNIT-5 zero schedule by msedcl
		48	96	187	142	45	AS PER SYSTEM CONDITION unit-3 AND UNIT-5 zero schedule by msedcl
8	PARALI U-8	X	X	X	X	X	ZERO SCHEDULE BY MSIEDCL
9	BHUSWAL U-3	X	X	X	X	X	ZERO SCHEDULE BY MSIEDCL
10	VIPL U-1 AND U-2	X	X	X	X	X	UNIT-1 AND UNIT-2 SHUT DOWN
11	RATTANINDIA U-1 TO U-5	X	X	X	X	X	RPL UNIT- 1 2,3,4,5 ZERO SCHEDULE BY MSIEDCL
12	JSW U-1	1	23	290	200	90	AS PER SYSTEM CONDITION
		48	77	290	200	90	AS PER SYSTEM CONDITION
		78	89	X	X	X	D.C. BELOW TECH MIN
		90	96	290	200	90	AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	23	940	644	296	AS PER SYSTEM CONDITION
		68	96	400	322	78	UNIT-5 SHUT DOWN AS PER SYSTEM CONDITION
14	KHAERKHEDA U-1 TO U-4	1	23	X	X	X	D.C. BELOW TECH MIN
		68	96	576	572	4	AS PER SYSTEM CONDITION
15	KORADI U-6 AND U-7	1	21	X	X	X	UNIT-7 SHUT DOWN D.C. TECH MIN
		68	96	180	174	6	UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION
16	ADANI TIRODA U-1 ,A,5(PPA 440MW)	1	21	440	0	440	AS PER SYSTEM CONDITION
		68	96	440	0	440	AS PER SYSTEM CONDITION
17	KORADI U-8, U9,U-10	1	21	812	723	89	AS PER SYSTEM CONDITION UNIT-10 SHUT DOWN
		70	96	947	864	83	AS PER SYSTEM CONDITION UNIT-10 SHUT DOWN
18	KHAERKHEDA U-5	1	21	428	335	93	AS PER SYSTEM CONDITION
		70	96	475	335	140	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	20	466	432	34	AS PER SYSTEM CONDITION
		70	75	466	432	34	AS PER SYSTEM CONDITION
		81	96	466	432	34	AS PER SYSTEM CONDITION
20	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	20	466	432	34	AS PER SYSTEM CONDITION
		70	75	466	432	34	AS PER SYSTEM CONDITION
		81	96	466	432	34	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-5(PPA 1200MW&125MW)	1	20	466	432	34	AS PER SYSTEM CONDITION
		70	75	466	432	34	AS PER SYSTEM CONDITION
		81	96	466	432	34	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-3 TO U-7	1	20	1515	1282	233	AS PER SYSTEM CONDITION
		90	96	1529	1282	247	AS PER SYSTEM CONDITION
23	PARAS U-3, U-4	1	20	220	168	52	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
		90	96	220	168	52	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	1	20	922	656	266	AS PER SYSTEM CONDITION
		92	96	922	656	266	AS PER SYSTEM CONDITION
25	ADANI U-2	1	19	623	432	191	AS PER SYSTEM CONDITION
		92	96	623	505	118	AS PER SYSTEM CONDITION
26	ADANI U-3	1	19	623	432	191	AS PER SYSTEM CONDITION
		92	96	623	515	108	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT: 112TH JAN: 2019
- 3 # indicates that back down withdrawn due to Line loading/system constraints.