

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	JSW U-2,3&4 TO AEML	1	35	300	210	90	AS PER SYSTEM CONDITION
		39	82	300	210	90	AS PER SYSTEM CONDITION
		94	96	300	210	90	AS PER SYSTEM CONDITION
2	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
3	TPC U-8	1	27	220	187	33	AS PER SYSTEM CONDITION
		39	82	220	187	33	AS PER SYSTEM CONDITION
		94	96	220	187	33	AS PER SYSTEM CONDITION
4	DTPS U-1 & U-2	1	27	456	336	120	AS PER SYSTEM CONDITION
		40	77	456	336	120	AS PER SYSTEM CONDITION
		94	96	456	336	120	AS PER SYSTEM CONDITION
5	VIPL U-1 & U-2	X	X	X	X	X	UNITS SHUT DOWN
6	TPC U-5	1	27	473	292	181	AS PER SYSTEM CONDITION
		40	76	473	292	181	AS PER SYSTEM CONDITION
		94	96	473	292	181	AS PER SYSTEM CONDITION
7	PARALI U-8	X	X	X	X	X	UNIT SHUT DOWN
8	PARALI U-6 & U-7	X	X	X	X	X	UNIT SHUT DOWN
9	RATTANINDIA U-1 TO U-5	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
10	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
11	KORADI U-8 TO U-10	1	96	X	X	X	U-8&9 OUT & U-10 UNDER ZERO SCHEDULE
12	NASHIK U-3, U-4 & U-5	1	26	561	425	136	AS PER SYSTEM CONDITION
		43	76	561	425	136	AS PER SYSTEM CONDITION
		95	96	561	425	136	AS PER SYSTEM CONDITION
13	CHANDRAPUR U-3 TO U-7	1	26	911	770	141	AS PER SYSTEM CONDITION/ U-3&7 OUT
		43	76	911	770	141	AS PER SYSTEM CONDITION/ U-3&7 OUT
		95	96	911	770	141	AS PER SYSTEM CONDITION/ U-3&7 OUT
14	BHUSAWAL U-4 & U-5	1	26	940	644	296	AS PER SYSTEM CONDITION
		43	76	940	644	296	AS PER SYSTEM CONDITION
		95	96	940	644	296	AS PER SYSTEM CONDITION
15	CHANDRAPUR U-8 & U-9	1	26	X	X	X	DC TECH MIN
		43	76	X	X	X	DC TECH MIN
16	APML U-1,U-4&U-5 (PPA440 MW)	1	25	440	0	440	AS PER SYSTEM CONDITION
		43	72	440	0	440	AS PER SYSTEM CONDITION
17	JSW U-1	1	25	285	200	85	AS PER SYSTEM CONDITION
		43	72	285	200	85	AS PER SYSTEM CONDITION
18	APML U-1,U-4&U-5 (PPA1200MW,125 MW)	1	25	1399	1296	103	AS PER SYSTEM CONDITION
		43	72	1399	1296	103	AS PER SYSTEM CONDITION
19	PARAS U-3 & U-4	44	72	458	332	126	AS PER SYSTEM CONDITION
20	KHAPERKHEDA U-1 TO U-4	44	72	X	X	X	DC TECH MIN/ U-4 OUT
21	KHAPERKHEDA U-5	44	72	342	335	7	AS PER SYSTEM CONDITION
22	ADANI U-2 & U-3	46	70	1246	864	382	AS PER SYSTEM CONDITION

Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 # Indicates that back down withdrawn due to Line loading/system constraints.
- 3 Revised MOD Rates effective from 00:00 HRS of 12th July 2019