

## STATEMENT OF GENERATOR SCHEDULE (EX\_BUS) BACKED DOWN FOR THE DATE:

31/07/2021

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		Target Despatch Schedule (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-5	1	96	470	260	210	AS PER SYSTEM CONDITION
2	TPC U-8	1	96	229	126	103	AS PER SYSTEM CONDITION
3	BHUSAWAL U-3	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
4	DTPS U-1 & U-2	1	79	455	250	205	AS PER SYSTEM CONDITION
		85	96	455	250	205	AS PER SYSTEM CONDITION
5	NASIK U-3, U-4 & U-5	1	31	185	102	83	AS PER SYSTEM CONDITION #/ U-3 UNDER
		89	96	185	102	83	CASE IV & U-4 UNDER ZERO SCHEDULE
6	PARALI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
7	KORADI U-6 & U-7	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
8	PARAS U-3 & U-4	1	76	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
		89	96	227	122	105	AS PER SYSTEM CONDITION / U-3 OUT
9	PARALI U-8	X	X	X	X	X	UNIT UNDER ZERO SCHEDULE
10	SWPGL to MSEDCL	X	X	X	X	X	PPA UNDER ZERO SCHEDULE
11	KHAPERKHEDA U-1 TO U-4	X	X	X	X	X	UNITS UNDER ZERO SCHEDULE
12	CHANDRAPUR U-3 TO U-7	1	24	1055	712	343	AS PER SYSTEM CONDITION/ U-7 UNDER ZERO SCHEDULE
		29	75	1055	712	343	
		89	96	1055	712	343	
13	BHUSAWAL U-4 & U-5	1	23	940	518	422	AS PER SYSTEM CONDITION
		29	36	940	518	422	AS PER SYSTEM CONDITION
		41	73	940	518	422	AS PER SYSTEM CONDITION
		92	96	940	518	422	AS PER SYSTEM CONDITION
14	RATTANINDIA U-1 TO U-5	1	21	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		41	71	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
		92	96	980	540	440	AS PER SYSTEM CONDITION/ U-3 OUT
15	APML U-1,U-4 & U-5 (PPA 440 MW)	1	19	400	0	400	AS PER SYSTEM CONDITION
		48	71	400	0	400	AS PER SYSTEM CONDITION
		93	96	400	0	400	AS PER SYSTEM CONDITION
16	DHARIWAL to MSEDCL (Case- IV)	1	19	185	101.75	83.25	AS PER SYSTEM CONDITION
		49	70	185	101.75	83.25	AS PER SYSTEM CONDITION
17	APML U-1,U-4 & U-5 (PPA 125 MW)	1	17	114	96	18	AS PER SYSTEM CONDITION
		50	67	114	96	18	AS PER SYSTEM CONDITION
18	APML U-1,U-4 & U-5 (PPA 1200 MW)	1	17	1091	921	170	AS PER SYSTEM CONDITION
		50	67	1091	921	170	AS PER SYSTEM CONDITION
19	KHAPERKHEDA U-5	X	X	X	X	X	UNIT OUT
20	CHANDRAPUR U-8 & U-9	1	17	432	259	173	AS PER SYSTEM CONDITION/ U-9 OUT
		50	64	432	259	173	AS PER SYSTEM CONDITION/ U-9 OUT
21	KORADI U-8 TO U-10	1	16	835	682	153	AS PER SYSTEM CONDITION/ U-8 OUT
		53	64	835	682	153	AS PER SYSTEM CONDITION/ U-8 OUT
22	APML U-2 & U-3	54	64	1040	678	362	AS PER SYSTEM CONDITION
23	JSW U-1	57	62	290	160	130	AS PER SYSTEM CONDITION
24	SWPGL to BEST	57	62	100	66	34	AS PER SYSTEM CONDITION

## Note :

- 1 MoD stack is prepared as per the clause 33 & 34 of MERC(State Grid Code) 2020.
- 2 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch.  
Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations with ramp are available under "View Schedules" on website.
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.
- 4 \* Indicates that back down implemented due to Line loading/system constraints.
- 5 Revised MOD Rates effective from 00:00 hrs of 30th July 2021
- 6 Nasik U-5 & Paras U-4 kept on bar due to Line loading/system constraints.