

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	DTPS REL U-1 AND U-2	1	22	458	336	122	AS PER SYSTEM CONDITION
		41	71	458	336	122	AS PER SYSTEM CONDITION
		89	96	458	336	122	AS PER SYSTEM CONDITION
2	TPC U-5	1	22	473	292	181	AS PER SYSTEM CONDITION
		41	71	473	292	181	AS PER SYSTEM CONDITION
		89	96	473	292	181	AS PER SYSTEM CONDITION
3	TPC U-8	1	22	204	187	17	AS PER SYSTEM CONDITION
		41	71	204	187	17	AS PER SYSTEM CONDITION
		89	96	204	187	17	AS PER SYSTEM CONDITION
4	NASIK U-3,4 AND 5	1	20	172	142	30	AS PER SYSTEM CONDITION unit-5 w/dn for zero schedule by msedclat00hrs of 12/07/2018
		41	71	172	142	30	AS PER SYSTEM CONDITION unit-5 w/dn for zero schedule by msedclat00hrs of 12/07/2018
		89	96	172	142	30	AS PER SYSTEM CONDITION unit-5 w/dn for zero schedule by msedclat00hrs of 12/07/2018
5	BHUSWAL U-3	X	X	X	X	X	UNIT SHUT DOWN
6	RATTANINDIA U-1 TO U-5	1	20	1200	860	340	AS PER SYSTEM CONDITION
		41	70	1200	860	340	AS PER SYSTEM CONDITION
		93	96	1200	860	340	AS PER SYSTEM CONDITION
7	VIPL U1 &2	47	62	286	191	95	UNIT-2 SHUT DOWN AS PER SYSTEM CONDITION
		67	70	286	207	79	UNIT-2 SHUT DOWN AS PER SYSTEM CONDITION
8	PARALI U-6 AND U-7	54	62	229	166	63	UNIT-6 SHUT DOWN B/D AS PER SYSTEM CONDITION
9	KHAPERKHEDA U-1TO U-4	54	62	X	X	X	UNIT-1 AND UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
10	IDEAL ENERGY	X	X	X	X	X	UNIT SHUT DOWN
11	DHARIWAL TO MSEDCL	X	X	X	X	X	UNIT SHUT DOWN
12	BHUSWAL U-4 AND U-5	54	62	451	322	129	UNIT-4 SHUT DOWN B/D AS PER SYSTEM CONDITION
13	PARALI U-8	54	62	229	166	63	AS PER SYSTEM CONDITION
14	KHAPERKHEDA U-5	54	62	285	X	X	D.C. BELOW TECH MIN
15	KORADI U-6 AND U-7	X	X	X	X	X	UNIT SHUT DOWN
16	KORADIU-8 ,9 AND U-10	X	X	X	X	X	NO BACK DOWN UNIT-8 AND UNIT-10 SHUT DOWN
17	ADANI TIRODA 440MW PPA U-1,4 &5	X	X	X	X	X	NO BACK DOWN
18	PARAS U-3 &U-4	X	X	X	X	X	NO BACK DOWN
19	JSW U-1	X	X	X	X	X	NO BACK DOWN
20	ADANI TIRODA U-1 (PPA 1200MW &125mw)	X	X	X	X	X	NO BACK DOWN
21	ADANI TIRODA U-4(PPA 1200MW&125MW)	X	X	X	X	X	NO BACK DOWN
22	ADANI TIRODA U-5 (PPA 1200MW&125MW)	X	X	X	X	X	NO BACK DOWN
23	CHANDRAPUR U-3 TO U-7	X	X	X	X	X	NO BACK DOWN
24	CHANDRAPUR U-8 AND U-9	X	X	X	X	X	NO BACK DOWN
25	ADANI U-2	X	X	X	X	X	NO BACK DOWN
26	ADANI U-3	X	X	X	X	X	NO BACK DOWN

## Note :

- 1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".
- 2 M.O.D. RATES REVISED FROM DT. 12TH AUG-2018
- 3 # Indicates that back down withdrawn due to Line loading/system constraints.