

| PROVISIONAL STATEMENT OF GENERATOR SCHEDULE (EX_BUS) BACKED DOWN FOR THE DATE: | | | | | | | 31-Oct-16 |
|--|-----------------------|-------------------------------------|----|------------------------------------|-------------------------------|--|--|
| SR. NO. | GENERATING STN / STOA | Backing Down Period (in Time Block) | | TARGET DESPATCHED SCHEDULE (in MW) | | Backing Down Quantum (Max) in MW (A-B) | REMARK |
| | | FROM | TO | Declared Capacity (A) | Despatched Schedule (Min) (B) | | |
| 1 | TPC U-6 | X | X | X | X | X | UNIT SHUTDOWN |
| 2 | NASIK | 1 | 73 | 364 | 284 | 80 | UNIT-5W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION |
| | | 78 | 96 | 364 | 284 | 80 | UNIT-5W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION |
| 3 | REL DAHANU U 1&2 | 1 | 73 | 467 | 336 | 131 | AS PER SYSTEM CONDITION |
| | | 79 | 96 | 467 | 336 | 131 | AS PER SYSTEM CONDITION |
| 4 | BHUSWAL U-2,3 | X | X | X | X | X | UNIT-2 AND UNIT-3 W/DN FOR ZERO SCHEDULE |
| 5 | RATTANINDIA U1 TO U5 | X | X | X | X | X | UNIT-1,2 ,3,4,5 W/DN FOR ZERO SCHEDULE BY MSEDCL B/D AS PER SYSTEM CONDITION |
| 6 | TPC U8 | 1 | 72 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| | | 79 | 96 | 235 | 187 | 48 | AS PER SYSTEM CONDITION |
| 7 | TPC U5 | 1 | 70 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| | | 80 | 96 | 473 | 292 | 181 | AS PER SYSTEM CONDITION |
| 8 | VIPL U1&2 | 1 | 21 | 546 | 382 | 164 | VIPL UNIT-2 TRIPPED AT 5:16HRS B/DAS PER SYSTEM CONDITION |
| | | 22 | 69 | 273 | 191 | 82 | VIPL UNIT-2 TRIPPED AT 5:16HRS B/DAS PER SYSTEM CONDITION |
| | | 80 | 96 | 273 | 191 | 82 | VIPL UNIT-2 TRIPPED AT 5:16HRS B/DAS PER SYSTEM CONDITION |
| 9 | BHUSWAL U-4 &U-5 | 1 | 34 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| | | 41 | 55 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| | | 80 | 96 | 940 | 644 | 296 | AS PER SYSTEM CONDITION |
| 10 | KORADI U5 TO U7 | X | X | X | X | X | UNIT-6 SHUT DOWN UNI-5 SHUT DOWN AND UNIT-7 SHUT DOWN |
| 11 | PARLEY U-6 AND U-7 | 1 | 34 | 229 | 166 | 63 | UNIT-7 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| | | 42 | 52 | 229 | 166 | 63 | UNIT-7 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| | | 80 | 96 | 229 | 166 | 63 | UNIT-7 SHUT DOWN B/D AS PER SYSTEM CONDITION |
| 12 | KHAPERKhedA U1 TO U4 | 1 | 33 | 715 | 572 | 143 | AS PER SYSTEM CONDITION |
| | | 42 | 52 | 715 | 572 | 143 | AS PER SYSTEM CONDITION |
| | | 81 | 96 | 715 | 572 | 143 | AS PER SYSTEM CONDITION |
| 13 | CHANDRAPUR U3 TO U7 | 1 | 28 | 1594 | 1282 | 312 | AS PER SYSTEM CONDITION |
| | | 42 | 52 | 1594 | 1282 | 312 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 1594 | 1282 | 312 | AS PER SYSTEM CONDITION |
| 14 | PARAS U-3 AND U-4 | 1 | 28 | 230 | 168 | 62 | UNIT-3 SHUT DOWN B/DAS PER SYSTEM CONDITION |
| | | 89 | 96 | 230 | 168 | 62 | UNIT-3 SHUT DOWN B/DAS PER SYSTEM CONDITION |
| 15 | KHAPERKhedA U5 | 1 | 28 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 475 | 335 | 140 | AS PER SYSTEM CONDITION |
| 16 | ADANI U1 | 1 | 27 | 466.33 | 432 | 34.33 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 466.33 | 432 | 34.33 | AS PER SYSTEM CONDITION |
| 17 | ADANI U4 | 1 | 27 | 466.33 | 432 | 34.33 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 466.33 | 432 | 34.33 | AS PER SYSTEM CONDITION |
| 18 | ADANI U5 | 1 | 27 | 466.33 | 432 | 34.33 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 466.33 | 432 | 34.33 | AS PER SYSTEM CONDITION |
| 19 | CHANDRAPUR U8 | 1 | 24 | 474 | 329 | 145 | AS PER SYSTEM CONDITION |
| | | 89 | 96 | 474 | 329 | 145 | AS PER SYSTEM CONDITION |
| 20 | KORADIU8 | 1 | 24 | X | X | X | D.C BELOW TECH MIN |
| | | 89 | 96 | X | X | X | D.C BELOW TECH MIN |
| 21 | ADANI U-2 | 1 | 20 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |
| | | 92 | 96 | 623 | 474 | 149 | AS PER SYSTEM CONDITION |
| 22 | ADANI U-3 | 1 | 20 | 623 | 432 | 191 | AS PER SYSTEM CONDITION |
| | | 92 | 96 | 623 | 484 | 139 | AS PER SYSTEM CONDITION |
| 23 | JSW U-1 | 1 | 20 | 290 | 200 | 90 | AS PER SYSTEM CONDITION |

X

NOTE:

1

Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backingdown quantum during "Backing down Period" is indicated by the statement. Blockwise variations are available under "View Schedules".

2

MOD DATES REVISION#1 EFFECTIVE FROM 20CCT 2016

3

Indicates that back down withdrawn due to Line loading/system constraints.