

SR. NO.	GENERATING STN. / STOA	Backing Down Period (in Time Block)		TARGET DESPATCHED SCHEDULE (in MW)		Backing Down Quantum [Max] in MW [A-B]	REMARK
		FROM	TO	Declared Capacity (A)	Despatched Schedule (Min) (B)		
1	TPC U-8	1	96	204	187	17	AS PER SYSTEM CONDITION
2	DTPS REL U-1 AND U-2	1	96	455	336	119	UNIT-1 TRIPPED AND SYN. AS PER SYSTEM CONDITION
3	JSW TO TATA	1	96	50	35	15	AS PER SYSTEM CONDITION
4	JSW TO BEST	1	96	150	105	45	AS PER SYSTEM CONDITION
5	TPC U-5	X	X	X	X	X	UNIT SHUT DOWN
6	PARALI U-6 AND U-7	X	X	X	X	X	widn for zero schedule as per msedcl
7	NASHIK U-3,4,5	1	30	177	142	35	AS PER SYSTEM CONDITION
		41	96	177	142	35	AS PER SYSTEM CONDITION
8	PARALI U-8	X	X	X	X	X	ZERO SCHEDULE BY MSIEDCL
9	BHUSWAL U-3	X	X	X	X	X	ZERO SCHEDULE BY MSIEDCL
10	VIPL U-1 AND U-2	X	X	X	X	X	UNIT-1 AND UNIT-2 SHUT DOWN
11	RATTANINDIA U-1 TO U-5	1	30	245	172	73	RPL UNIT- 2,3,4,5 ZERO SCHEDULE BY MSIEDCL
		41	96	245	172	73	RPL UNIT- 2,3,4,5 ZERO SCHEDULE BY MSIEDCL
12	JSW U-1	1	26	290	200	90	AS PER SYSTEM CONDITION
		41	96	290	200	90	AS PER SYSTEM CONDITION
13	BHUSWAL U-4 AND U-5	1	23	470	322	148	AS PER SYSTEM CONDITION UNIT-4 SHUT DOWN
		42	96	451	322	129	AS PER SYSTEM CONDITION
14	KHAERKHEDA U-1 TO U-4	1	23	612	568	44	AS PER SYSTEM CONDITION
		42	96	540	X	X	D.C.BELOW TECH MIN
15	KORADI U-6 AND U-7	1	23	192	144	48	UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION
		42	96	162	144	18	UNIT-7 SHUT DOWN AS PER SYSTEM CONDITION
16	ADANI TIRODA U-1 ,4,5(PPA 440MW)	1	22	440	0	440	AS PER SYSTEM CONDITION
		42	96	440	0	440	AS PER SYSTEM CONDITION
17	KORADI U-8, U9,U-10	1	22	929	840	89	D.C.BELOW TECH MIN
		65	96	938	854	84	AS PER SYSTEM CONDITION
18	KHAERKHEDA U-5	1	22	428	335	93	AS PER SYSTEM CONDITION
		65	96	475	335	140	AS PER SYSTEM CONDITION
19	ADANI TIRODA U-1(PPA 1200MW&125MW)	1	22	466	432	34	AS PER SYSTEM CONDITION
		65	96	466	432	34	AS PER SYSTEM CONDITION
20	ADANI TIRODA U-4(PPA 1200MW&125MW)	1	22	466	432	34	AS PER SYSTEM CONDITION
		65	96	466	432	34	AS PER SYSTEM CONDITION
21	ADANI TIRODA U-5(PPA 1200MW&125MW)	1	22	466	432	34	AS PER SYSTEM CONDITION
		65	96	466	432	34	AS PER SYSTEM CONDITION
22	CHANDRAPUR U-3 TO U-7	1	22	1524	1282	242	AS PER SYSTEM CONDITION
		66	96	1520	1282	238	AS PER SYSTEM CONDITION
23	PARAS U-3, U-4	1	22	120	X	X	UNIT-3 SHUT DOWN D.C. BELOW TECH. MIN
		66	96	230	168	62	UNIT-3 SHUT DOWN AS PER SYSTEM CONDITION
24	CHANDRAPUR U-8 AND U-9	1	22	912	656	256	AS PER SYSTEM CONDITION
		75	96	922	656	266	AS PER SYSTEM CONDITION
25	ADANI U-2	1	21	X	X	X	UNIT SYN. RUNNING TECH. MIN
		88	96	623	432	191	AS PER SYSTEM CONDITION
26	ADANI U-3	1	21	623	432	191	AS PER SYSTEM CONDITION
		88	96	623	432	191	AS PER SYSTEM CONDITION

Note :

1 Above Statement is an abstract of Load Generation Balance as per Day Ahead Schedules, based on State Merit Order Despatch. Maximum backdown quantum during "Backing down Period" is indicated in the statement. Blockwise variations are available under "View Schedules".

2 M.O.D. RATES REVISED FROM D 12TH JAN- 2019

3 # Indicates that back down withdrawn due to Line loading/system constraints.