

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Feb/2023 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	151.979	151.979	1) Gujrat	-1.777	-1.777
2) Hydro	7.978	7.978	2) Madhya Pradesh	7.012	7.012
3) Gas	5.663	5.663	3) Chattisgarh	3.240	3.240
Total MSPGCL	165.620	165.620	4) Maharashtra	171.104	171.104
B) 1) APLM	66.830	66.830	5) Goa (Amona)	-1.660	-1.660
2) JSWEL	16.768	16.768	Total	177.919	177.919
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.963	26.963
4) RPL(AMT)	30.106	30.106	b) Mumbai Drawl	33.983	33.983
5) SWPGPL	9.145	9.145			
6) Other IPP	44.629	44.629	c) MSEDCL Bilateral *	76.493	76.493
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	4.028	4.028	d) Mumbai Bilateral *	26.940	26.940
2) TPCL Hydro	4.649	4.649	Include PX	0.000	0.000
3) TPCL Gas	2.666	2.666	Standby	0.023	0.023
4) AEML Thermal	10.026	10.026			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	333.511	333.511	1) MSEDCL	494.564	494.564
2) Hydro (A2+C2)	12.627	12.627	2) Mumbai Discoms	55.352	55.352
3) Gas (A3+B7+C3)	8.329	8.329	3) Other Discoms	10.147	10.147
4) Wind	16.482	16.482			
6) SOLAR	11.195	11.195	TOTAL STATE	560.063	560.063
TOTAL STATE	382.144	382.144			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6769	6638	6832	5481
MSPGCL Hydro	967	281	556	115
MSPGCL Gas	233	228	234	241
MSPGCL Total Generation	7969	7147	7622	5837
Central Sector Receipt	9016	8887	6843	6207
WIND	517	454	524	1037
CPP / IPP Thermal	7429	7316	7504	6398
CPP / IPP Gas	0	0	0	0
SOLAR	1446	1625	4	0
Exchange with Mumbai	-1731	-1849	-1422	-1456
MSEDCL DEMAND MET	24204	23123	20591	17610
Load Shedding	0	0	0	0
MSEDCL DEMAND	24204	23123	20591	17610
TPCL GENERATION	550	474	801	244
AEML GENERATION	497	461	495	364
MUMBAI DEMAND	2778	2784	2718	2064
OTHER DISCOM DEMAND	442	457	484	413
STATE DEMAND MET	27424	26364	23793	20087
STATE DEMAND	27424	26364	23793	20087
Frequency (Hz)	50.13	49.82	49.96	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.37 Hz at 22:01 Hrs	49.68 Hz at 06:13 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Feb/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.84	4.84	210	180
Unit 8	13.08	13.08	555	524
Unit 9	13.37	13.37	613	488
Unit 10	13.09	13.09	602	480
Total	44.38	44.38		
Bhusawal				
Unit 3	3.07	3.07	165	115
Unit 4	9.34	9.34	490	285
Unit 5	8.85	8.85	480	280
Total	21.26	21.26		
Parli				
Unit 6	4.05	4.05	238	145
Unit 7	0.00	0.00	0	0
Unit 8	3.78	3.78	201	145
Total	7.83	7.83		
Chandrapur				
Unit 3	3.28	3.28	161	120
Unit 4	2.89	2.89	139	110
Unit 5	6.96	6.96	305	280
Unit 6	7.70	7.70	430	280
Unit 7	0.00	0.00	0	0
Unit 8	9.87	9.87	493	279
Unit 9	9.85	9.85	491	305
Total	40.55	40.55		
Paras				
Unit 3	4.77	4.77	228	120
Unit 4	5.32	5.32	228	205
Total	10.09	10.09		
Khaparkheda				
Unit 1	2.55	2.55	130	85
Unit 2	2.76	2.76	138	90
Unit 3	3.34	3.34	155	130
Unit 4	3.47	3.47	170	123
Unit 5	9.81	9.81	490	275
Total	21.93	21.93		
Nasik				
Unit 3	3.40	3.40	178	115
Unit 4	2.54	2.54	148	0
Unit 5	0.00	0.00	0	0
Total	5.94	5.94		
Uran				
All Units	5.66	5.66	245	224
Total	5.66	5.66		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.26	0.26	47	0
Total	0.26	0.26		
Koyna				
Stage 1-2	2.46	2.46	345	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.75	0.75	277	0
Stage 3	0.84	0.84	144	0
Total	4.05	4.05		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.54	0.54	61	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.24	0.24	77	0
SMLHY_PTN	1.99	1.99	96	70
GHATGHAR	0.90	0.90	125	0
Total	3.66	3.66		
Wind				
Total	16.48	16.48	0	0
Total	16.48	16.48		
CPP				
APML(Mus)	66.83	66.83	0	0
JSWEL(Mus)	16.77	16.77	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.11	30.11	0	0
SWPGPL-Mus	9.14	9.14	0	0
Dhariwal	4.90	4.90	272	153
IEPL	3.01	3.01	241	0
Other(Mus)	36.72	36.72	0	0
Total	167.48	167.48		
SOLAR				
Total	11.20	11.20	0	0
Total	11.20	11.20		
Tata				
Trombay 5	0.00	0.00	0	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.52	1.52	108	44
Trombay 7B	1.14	1.14	65	39
TATA Hydro	4.65	4.65	430	2
Trombay 8	4.03	4.03	223	132
Total	11.34	11.34		
AEML				
DTPS U-1&2	10.03	10.03	501	298
Total	10.03	10.03		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	151.98	151.98	MSPGCL Total	165.62	165.62
			MSPGCL Thml+Gas	157.64	157.64	Koyna 1,2 & 4 Total	3.21	3.21
			MSPGCL Hydro	7.98	7.98	State Total	382.14	382.14

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 01/Feb/2023

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5677	315	238	6230	687	5917	0	0	6704	6856	-1273	18036	0	18036	1821	381	20238	49.93
2	5709	136	239	6084	728	6138	0	0	6793	6910	-1152	18352	0	18352	1695	356	20403	50.00
3	5689	140	238	6067	822	6313	0	0	6690	6553	-1070	18340	0	18340	1606	345	20291	50.05
4	5665	136	240	6041	837	6319	0	0	6727	6539	-1025	18391	0	18391	1555	320	20266	50.04
5	5842	126	239	6207	939	6595	0	0	6649	6647	-1049	19008	0	19008	1574	331	20913	50.02
6	5961	185	240	6386	1011	6661	0	0	6988	7208	-1168	19724	0	19724	1727	374	21825	49.97
7	6667	155	242	7064	921	6934	0	3	7160	7387	-1285	20611	0	20611	1908	413	22932	49.96
8	6899	536	245	7680	777	7428	0	114	7366	7306	-1430	21451	0	21451	2109	424	23984	50.00
9	6948	671	243	7862	715	7614	0	513	7467	7617	-1414	22476	0	22476	2376	431	25283	50.05
10	7005	504	241	7750	593	7626	0	1023	8036	8338	-1490	23388	0	23388	2615	452	26455	50.01
11	6769	967	233	7969	517	7429	0	1446	8769	9016	-1731	24204	0	24204	2778	442	27424	50.13
12	6718	682	229	7629	486	7428	0	1657	8932	9038	-1817	23979	0	23979	2817	442	27238	50.09
13	6638	281	228	7147	454	7316	0	1625	8855	8887	-1849	23123	0	23123	2784	457	26364	49.82
14	6152	292	228	6672	446	6947	0	1590	8828	8976	-1731	22462	0	22462	2670	438	25570	50.05
15	6352	243	225	6820	371	7040	0	1428	8857	9081	-1748	22563	0	22563	2702	429	25694	49.96
16	6749	194	224	7167	352	7246	0	1070	9040	8623	-1664	22345	0	22345	2706	449	25500	49.94
17	6917	184	230	7331	396	7335	0	580	8372	7931	-1546	21562	0	21562	2694	465	24721	49.98
18	6768	292	232	7292	446	7333	0	142	7144	7171	-1441	20473	0	20473	2678	470	23621	50.02
19	6832	556	234	7622	524	7504	0	4	6607	6843	-1422	20591	0	20591	2718	484	23793	49.96
20	6803	565	235	7603	704	7479	0	0	6474	6501	-1355	20453	0	20453	2673	479	23605	49.99
21	6349	352	239	6940	813	7066	0	0	6351	5870	-1310	18920	0	18920	2514	459	21893	49.85
22	5772	238	239	6249	947	6732	0	0	6192	6279	-1189	18575	0	18575	2372	443	21390	50.00
23	5617	112	241	5970	959	6680	0	0	6406	6136	-1368	17943	0	17943	2196	434	20573	50.03
24	5481	115	241	5837	1037	6398	0	0	6365	6207	-1456	17610	0	17610	2064	413	20087	49.98
MUs	151.98	7.98	5.66	165.62	16.48	167.48	0.00	11.19	177.77	177.92	-33.98	494.58	0.00	494.58	55.35	10.13	560.06	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Feb/2023

Position as on 6.30 Hrs of 02/Feb/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna STG-IV Unit-1	250	02/12/2022	18:20		Continued.	Annual Overhaul	01/02/2023
MSPGCL	Parli Unit 7	250	03/01/2023	22:16		Continued.	Annual Overhaul	31/01/2023
TPC-G	Trombay 5	500	18/01/2023	01:10		Continued.	Annual Overhaul	15/02/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	07/02/2023
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	28/02/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	30/05/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 7	500	29/11/2022	09:30		Continued.	DUE TO MAIN TURBINE GLAND SEALING PRESSURE HIGH.	31/01/2023
MSPGCL	Nasik Unit 5	210	15/01/2023	21:18	02/02/2023	03:43	ID Fan Problem	02/02/2023
IPP	IEPL Unit 1	270	26/01/2023	23:33	01/02/2023	08:24	Air Filter Problem	01/02/2023
IPP	JSW (J) U3	300	28/01/2023	06:38		Continued.	Non availability of load schedule	
IPP	SWPGPL U-2	135	29/01/2023	21:22	01/02/2023	02:09	Ash Conveying System Problem	
MSPGCL	Nasik Unit 4	210	01/02/2023	19:24		Continued.	ID Fan Problem	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 01/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 02/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Tripping							
MAIN BAY (416) OF STATION TF 4A @ DEEPNAGAR	IntraState	30/01/2023	09:44			PO	For servicing & overhauling of 400kV AREVA make STN-4A Main C.B. Mechanism
400 KV LINE Outages/Tripping							
TALANDGE - KOLHAPUR (PG) CKT - 1	InterState	28/11/2022	10:12			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. Same is approved by Ministry of Power (MOP) vide their office memorandum dt 01.12.2021 . AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS-2.
KALWA - TALEGAON (PG)	InterState	01/02/2023	22:30	01/02/2023	22:41	T	LINE TRIPPED ONLY AT TALEGAON PG END WHILE SHIFTING FORM TBC TO OWN CB AT KHARGHAR END.
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	16/01/2023	11:34			HT	For load management
KORADI - KHAPERKHEDA CKT - 2	IntraState	30/01/2023	09:03			PO	Proposal for shifting of 400KV Khaperkheda Ckt-2 on 400KV TBC bay for attending rotary broken problem of BUS-2 PG isolators and overhauling & servicing of mechanism box of PG isolators by shifting 400KV Khaperkheda Ckt-2 on 400KV TBC bay .
LONIKAND - JEJURI CKT - 2	IntraState	30/01/2023	13:10	01/02/2023	20:55	PO	O/H & Servicing of 29C PG Isolator & Replacement of PGI mechanism box.
JAIGAD - KARAD CKT - 2	IntraState	01/02/2023	23:47	02/02/2023	09:37	HT	H/T DUE TO O/V
KHADKA - BABLESHWAR	IntraState	02/02/2023	08:26			PO	Chemical Cleaning of Insulator string and Routine Line maintenance work
400 KV ICT Outages/Tripping							
400/220/33 KV 500 MVA ICT - 2 @ LAMBOTI	IntraState	01/02/2023	10:00	01/02/2023	17:09	PO	Painting work of ICT II
400/220/33 KV 500MVA ICT - 1 @ KORADI 2	IntraState	01/02/2023	11:07	01/02/2023	19:46	PO	Erection of IPS tube & BPI along the line isolator 430-89L for RRS project work.
400/220/33 KV 500MVA ICT - 2 @ KORADI 2	IntraState	02/02/2023	08:24			PO	Erection of IPS tube & BPI along the line isolator 421-89L for RRS project work.
220 KV LINE Outages/Tripping							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	18/12/2022	22:52			HT	To control overloading
VANKUSWADE - KDPH	IntraState	07/01/2023	10:46			PO	For Erection & Stringing of In line Multi Circuit tower (Loc No.1 to 7) of new 220kV Karad-Koyana Line and Re stringing of existing 220kV D/C KDPH LILLO line.
EKLAHARE (OCR) - PADGHE	IntraState	27/01/2023	06:15	01/02/2023	13:35	PO	1. Bunching atLoc No.105.2. Erection - 2 Nos. Of Monopole and 1 No. OfLattice Pole.3. Stringing-5span. 4. Dismantling - 2 Nos. Of tower.
GHATGHAR - JINDAL	IntraState	27/01/2023	06:35	01/02/2023	12:59	PO	1. Bunching at Loc No.105.2. Erection - 2 Nos. Of Monopole and 1 No. Of Lattice Pole.3. Stringing-5span. 4. Dismantling - 2 Nos. Of tower.
BORIVALI - TARAPUR	IntraState	27/01/2023	10:07			HT	Planned outage for annual maintenance at Tarapur end

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 02/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
NIGADE- PETH LINE	IntraState	30/01/2023	12:32			PO	For erection of new DXS tower at Loc. No. 81(220KV Karad-Mudshingi ckt) for 132KV Peth-Borgaon Line crossing & dismantling of existing D/C tower loc. No. 81 of old Karad - Mudshingi Ckt. 1 & 2 line.
LAMBOTI - KARKAMB	IntraState	01/02/2023	06:48	01/02/2023	07:36	T	Distance Protection
HINJAWADI I- CHINCHWAD	IntraState	01/02/2023	08:58	01/02/2023	18:51	HT	H/T for Load Management.
TALANDGE - BIDRI	IntraState	01/02/2023	09:12	01/02/2023	14:15	PO	Cold line cleaning of Disc Insulaor
LONAND-BARAMATI	IntraState	01/02/2023	09:53	01/02/2023	15:58	HT	H/T for Load Management.
BHALVANI - VARKUTI	IntraState	01/02/2023	11:20	01/02/2023	12:00	PO	Outage is required For cleaning disc insulator string from loc No. 331 to 261.
ONGC PANVEL - TSS PANVEL	IntraState	01/02/2023	12:20	01/02/2023	13:27	PO	Jumper opening at loc no 1 of 220kv Kharghar - Panvel TSS line and Jumper connection at loc. no.3 for providing Temporary second source to 220kv ONGC S/S from 220kv Kharghar S/S and 220kv Panvel TSS on single source from 220 kV ONGC S/S for 4 days (dt.31.01.2023 to 03.02.2023) 2. Destrining of 3 no. old existing conductors dismantling of tower loc. no.3 of LILO line of panvel TSS. 3. Stringing of 3 nos. conductor new Monopole to Monopole tower in bet loc no. 2 & 3 for Hight rising work of proposed DFCCIL Railway track near Central Railway chainges no 69/22-24 and chainages 69/21-23
KHARGHAR - TSS PANVEL	IntraState	01/02/2023	12:42	01/02/2023	13:52	PO	Jumper opening at loc no 1 of 220kv Kharghar - Panvel TSS line and Jumper connection at loc. no.3 for providing Temporary second source to 220kv ONGC S/S from 220kv Kharghar S/S and 220kv Panvel TSS on single source from 220 kV ONGC S/S for 4 days (dt.31.01.2023 to 03.02.2023) 2. Destrining of 3 no. old existing conductors dismantling of tower loc. no.3 of LILO line of panvel TSS. 3. Stringing of 3 nos. conductor new Monopole to Monopole tower in bet loc no. 2 & 3 for Hight rising work of proposed DFCCIL Railway track near Central Railway chainges no 69/22-24 and chainages 69/21-23
BIDRI - SAWANTWADI	IntraState	01/02/2023	14:25	01/02/2023	17:33	PO	Cold line cleaning of Disc Insulaor
EKLAHARE (OCR) - PADGHE	IntraState	01/02/2023	18:13			HT	For load mgmt
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	01/02/2023	19:06	02/02/2023	00:57	HT	For load management and withdrawal of U4 Nashik at 19:00 hrs
APTA - KALWA	IntraState	01/02/2023	23:29	02/02/2023	06:27	PO	For erection of 2 nos. of CTT Monopole in between Loc no. 686 to 687.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Feb/2023

Statement-VII

Position as on 6.30 Hrs of 02/Feb/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KALWA - PANCHANAND	IntraState	02/02/2023	00:01	02/02/2023	06:46	PO	1) For Overhauling of All Three Circuit Breaker Pole will be carried out at 220KV RS Kalwa. For this work line will be charged through TBC from 01.02.2023 to 03.02.2023 after work by EHV Project Dn, Kalwa i.e erection of 2 nos. of CTT Monopole in between loc no. 686-687 for whic outage is required for only one day i.e 01.02.2023.
TROMBAY DHARAVI - 5	IntraState	02/02/2023	00:33	02/02/2023	01:44	HT	Emergency outage availed for removing hanging wire between loc.no. 23-24
TAMBATI - ADLABS	IntraState	02/02/2023	06:53			PO	Diagnostic testing and Red hot spot attending work at both end.
BIDRI - SAWANTWADI	IntraState	02/02/2023	09:07			PO	insulator cleaning
LONAND-PHALTAN MIDC	IntraState	02/02/2023	09:40			PO	Quarterly maintenance work at 220 kV Phaltan MIDC S/S
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 100 MVA ICT 1	IntraState	01/02/2023	10:15	01/02/2023	17:56	PO	Demonstration Winding Resistance measurement arranged by TCC Nashik. And Diagnostic testing of ICT & bay equipment.
220/100 KV 200 MVA ICT 1 @ APTA	IntraState	01/02/2023	12:47	01/02/2023	12:53	T	Due to tripping of 100 kV Apta Jite TSS conductor snapping of top phase , LBB protection operated at Apta ss. So 220/100 KV 200 MVA ICT1,2 tripped alongwith Musco ckt 1,2 , Khopoli , Patalganga lines
220/100 KV 200 MVA ICT 2 @ APTA	IntraState	01/02/2023	12:47	01/02/2023	12:53	T	Due to tripping of 100 kV Apta Jite TSS conductor snapping of top phase , LBB protection operated at Apta ss. So 220/100 KV 200 MVA ICT1,2 tripped alongwith Musco ckt 1,2 , Khopoli , Patalganga lines
220/132 KV 100 MVA ICT 1 @ BELWANDI	IntraState	01/02/2023	16:19	01/02/2023	17:47	PO	For CB Contact Resistance Measurement Work.
220 KV BUSBAR Outages/Trippings							
MAIN BUS SECTION - 1 @ THEUR	IntraState	02/02/2023	08:45			PO	1. Cold Washing of Main Bus insulator strings. 2. Replacement of PID faulty insulator strings 3. Installation of Gas collecting device For 50MVA 220/22kV TF-4 & TF-5 4. 220kV Bus Isolator Maintenance

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage