

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Mar/2015 SUNDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	106.710	106.710	1) Gujrat	-3.650	-3.650
2) Hydro	6.957	6.957	2) Madhya Pradesh	9.409	9.409
3) Gas	7.598	7.598	3) Chattisgarh	2.610	2.610
Total MSPGCL	121.265	121.265	4) Maharashtra Net	51.994	51.994
B) 1) APML	29.440	29.440	5) Goa	-5.329	-5.329
2) JSWEL	3.142	3.142	6) TAPS 1&2 Injection	3.773	3.773
3) VIPL	9.156	9.156	7) RGPPL Injection	0.000	0.000
4) RPL(AMT)	4.190	4.190	8) Pench (MS)	0.066	0.066
5) WPCL	2.532	2.532	9) Pench (Excess)	-0.066	-0.066
6) Other IPP	7.646	7.646	Total	58.741	58.741
C) 1) TPCL Thermal	12.425	12.425	a) Mumbai Schedule	17.215	17.215
2) TPCL Hydro	0.230	0.230	b) Mumbai Drawl	14.882	14.882
3) TPCL Gas	3.000	3.000	c) MSEDCL Bilateral *	18.523	18.523
4) R-INFRA Thermal	9.214	9.214	Include PX	1.467	1.467
D) STATE			d) Mumbai Bilateral *	17.215	17.215
1) Thermal	184.455	184.455	Include PX	-0.157	-0.157
(A1+C1+C4+(B1-B6))			Include Standby	0.000	0.000
2) Hydro	7.187	7.187	H) ENERGY CATERED (MUs)		
3) Gas	10.598	10.598	1) MSEDCL	234.978	234.978
4) Wind	13.108	13.108	2) Mumbai Discoms	39.509	39.509
6) SOLAR	0.574	0.574	TOTAL STATE	274.487	274.487
TOTAL STATE	215.922	215.922			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 5 Hrs
MSPGCL Thermal	4372	4489	4537	4114
MSPGCL Hydro	227	425	365	140
MSPGCL Gas	321	312	310	321
MSPGCL Total Generation	4920	5226	5212	4575
Central Sector Receipt	3683	2576	3315	1304
WIND	366	791	1002	310
CPP / IPP	2238	2406	2450	2164
SOLAR	20	59	0	0
Exchange with Mumbai	-755	-527	-818	-280
MSEDCL DEMAND MET	10472	10531	11161	8073
Load Shedding	61	64	58	56
MSEDCL DEMAND	10533	10595	11219	8129
TPCL GENERATION	656	757	740	591
R-INFRA GENERATION	384	385	384	377
MUMBAI DEMAND	1795	1669	1942	1248
STATE DEMAND MET	12267	12200	13103	9321
STATE DEMAND	12328	12264	13161	9377
Frequency (Hz)	50.06	49.89	49.96	50.14

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.49 Hz at 21.50 Hrs	49.76 Hz at 16.14 Hrs	50.06	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 01/Mar/2015

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 5	0.00	0.00	0	0
Unit 6	3.91	3.91	175	148
Unit 7	3.79	3.79	172	150
Total	7.70	7.70		
Bhusawal				
Unit 2	0.00	0.00	0	0
Unit 3	3.82	3.82	170	150
Unit 4	1.51	1.51	375	0
Unit 5	8.70	8.70	380	320
Total	14.04	14.04		
Parli				
Unit 3	0.00	0.00	0	0
Unit 4	3.47	3.47	155	137
Unit 5	0.00	0.00	0	0
Unit 6	4.57	4.57	194	180
Unit 7	4.56	4.56	202	180
Total	12.60	12.60		
Chandrapur				
Unit 1	0.00	0.00	0	0
Unit 2	3.35	3.35	145	132
Unit 3	4.09	4.09	183	161
Unit 4	2.09	2.09	175	0
Unit 5	0.00	0.00	0	0
Unit 6	8.62	8.62	370	345
Unit 7	8.63	8.63	373	338
Total	26.78	26.78		
Paras				
Unit 3	4.65	4.65	204	172
Unit 4	4.52	4.52	207	165
Total	9.17	9.17		
Khaparkheda				
Unit 1	3.87	3.87	180	140
Unit 2	3.58	3.58	170	95
Unit 3	4.17	4.17	190	149
Unit 4	4.02	4.02	180	146
Unit 5	8.72	8.72	420	330
Total	24.38	24.38		
Nasik				
Unit 3	4.06	4.06	175	160
Unit 4	4.04	4.04	185	146
Unit 5	3.96	3.96	173	151
Total	12.05	12.05		
Uran				
All Units	7.60	7.60	324	308
Total	7.60	7.60		
PENCH (MS)				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Pench (MS)	0.07	0.07	27	0
Total	0.07	0.07		
Koyna				
Stage 1-2	1.57	1.57	275	40
Stage 4	0.00	0.00	0	0
Stage 3	0.71	0.71	160	0
Total	2.28	2.28		
Hydro				
KDPH	0.44	0.44	19	18
VTRNA	0.86	0.86	61	0
TILLARI	0.00	0.00	0	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.07	0.07	70	0
RNGR+BHTSA	0.33	0.33	14	13
BHANDARDRA	0.49	0.49	39	12
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.42	0.42	18	17
GHATGHAR	2.07	2.07	250	0
Total	4.68	4.68		
Wind				
Total	13.11	13.11	0	0
Total	13.11	13.11		
CPP				
APML(Mus)	29.44	29.44	0	0
JSWEL(Mus)	3.14	3.14	0	0
VIPL(Mus)	9.16	9.16	0	0
RPLAMT(Mus)	4.19	4.19	0	0
WPCL(Mus)	2.53	2.53	0	0
Other(Mus)	7.65	7.65	0	0
Total	56.11	56.11		
SOLAR				
Total	0.57	0.57	0	0
Total	0.57	0.57		
Tata				
Trombay 5	7.59	7.59	319	313
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.86	1.86	98	69
Trombay 7B	0.90	0.90	61	0
Trombay 8	4.83	4.83	204	198
TATA Hydro	0.23	0.23	95	0
Total	15.41	15.41		
R-INFRA				
1-2	9.21	9.21	388	376
Total	9.21	9.21		

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	106.71	106.71
MSPGCL Thml+Gas	114.31	114.31

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Hydro	6.96	6.96
MSPGCL Total	121.26	121.26

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
Koyna 1,2 & 4 Total	1.57	1.57
State Total	215.92	215.92

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Mar/2015

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP	SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS													
1	4812	105	322	5239	400	2611	0	2138	2071	-488	9833	85	9918	1461	11379	50.11
2	4823	100	323	5246	610	2567	0	1824	1439	-368	9494	54	9548	1340	10888	50.10
3	4629	100	322	5051	248	2568	0	1587	1662	-323	9206	54	9260	1282	10542	50.10
4	4524	130	323	4977	364	2134	0	1460	1403	-294	8584	54	8638	1254	9892	50.31
5	4114	140	321	4575	310	2164	0	1454	1304	-280	8073	56	8129	1248	9377	50.14
6	4077	130	323	4530	179	2172	0	1526	2002	-386	8497	60	8557	1350	9907	50.03
7	4162	106	324	4592	114	2157	0	1761	2308	-455	8716	75	8791	1421	10212	50.04
8	4239	101	320	4660	109	2147	1	2695	3191	-506	9602	80	9682	1494	11176	50.02
9	4318	101	321	4740	129	2193	5	2677	3347	-592	9822	76	9898	1622	11520	50.03
10	4372	227	321	4920	366	2238	20	2680	3683	-755	10472	61	10533	1795	12328	50.06
11	4382	523	318	5223	390	2219	49	2717	3237	-831	10287	56	10343	1879	12222	50.07
12	4431	647	318	5396	438	2211	68	2779	2687	-822	9978	59	10037	1882	11919	50.05
13	4479	529	315	5323	485	2266	86	2540	2693	-806	10047	117	10164	1858	12022	49.98
14	4470	524	313	5307	481	2211	111	2366	2511	-735	9886	60	9946	1782	11728	50.06
15	4485	342	313	5140	696	2287	88	2587	2454	-671	9994	59	10053	1718	11771	49.98
16	4439	166	311	4916	748	2352	64	2506	2469	-610	9939	61	10000	1667	11667	49.90
17	4489	425	312	5226	791	2406	59	2064	2576	-527	10531	64	10595	1669	12264	49.89
18	4482	324	312	5118	1109	2467	22	2041	2291	-673	10334	66	10400	1726	12126	50.04
19	4527	325	312	5164	1161	2470	1	2045	2559	-777	10578	58	10636	1823	12459	50.02
20	4537	365	310	5212	1002	2450	0	2777	3315	-818	11161	58	11219	1942	13161	49.96
21	4520	575	308	5403	783	2481	0	1979	2756	-899	10524	58	10582	1944	12526	50.02
22	4499	585	312	5396	836	2486	0	1922	2297	-900	10115	58	10173	1925	12098	50.23
23	4463	193	311	4967	693	2410	0	2067	2463	-762	9771	58	9829	1794	11623	50.15
24	4437	194	313	4944	666	2439	0	1576	2022	-604	9467	58	9525	1634	11159	50.11
MUs	106.7 1	6.96	7.60	121.27	13.11	56.11	0.57	51.77	58.74	-14.88	234.91	1.55	236.46	39.51	275.97	50.06

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 01/Mar/2015

Position as on 6.30 Hrs of 02/Mar/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Parli Unit 3	210	13/02/2013	23:50		Continued.	Water Shortage	
CENT.SECTOR	Tarapur 1	160	12/10/2014	22:39		Continued.	Refuelling Work. (60 Days)	
FORCED OUTAGE								
RGPPL	Dabhol 1B	230	28/05/2013	22:02		Continued.	Gas Shortage.	
RGPPL	Dabhol 3A	230	06/06/2013	08.28		Continued.	Gas Shortage	
RGPPL	Dabhol 2A	230	06/06/2013	09.10		Continued.	Gas Shortage	
RGPPL	Dabhol 1X	290	27/06/2013	21.46		Continued.	Gas Shortage	
RGPPL	Dabhol 1A	230	27/06/2013	21.47		Continued.	Gas Shortage	
RGPPL	Dabhol 2X	290	15/07/2013	15.09		Continued.	Gas Shortage	
RGPPL	Dabhol 2B	230	08/08/2013	15.03		Continued.	Gas Shortage	
RGPPL	Dabhol 3X	290	29/12/2013	05.47		Continued.	Gas Shortage	
RGPPL	Dabhol 3B	230	29/12/2013	06.14		Continued.	Gas Shortage	
IPP	WPCL U-2	135	18/02/2014	00.02		Continued.	Ash conveying Problem	
IPP	Dhariwal	300	28/05/2014	02.27		Continued.	PA Fan Vibration Problem	
MSPGCL	Koradi Unit 5	200	17/06/2014	11:53		Continued.	Economic Shutdown	
MSPGCL	Chandrapur Unit 1	210	28/08/2014	07:15		Continued.	Economic Shutdown.	
MSPGCL	Bhusawal Unit 2	210	13/09/2014	12.43		Continued.	Economic shutdown	
CPP	WPCL U-1	135	30/10/2014	00.43		Continued.	ESP bag Filter Damaged	
TPC-G	Trombay 7B	60	11/12/2014	20.39		Continued.	Rotor Fault	
IPP	RPL(AMT) U-1	270	27/01/2015	21.55		Continued.	Coal Shortage	
IPP	JSW (J) U1	300	03/02/2015	14:20		Continued.	PA Fan problem	
IPP	JSW (J) U3	300	03/02/2015	21:27		Continued.	Due to Unavailability of Load.	
MSPGCL	Uran Unit B0	120	11/02/2015	23.27		Continued.	Gas shortage	
MSPGCL	Koyana Unit 9	80	16/02/2015	08.15		Continued.	Annual Maintenance Work	
TPC-G	Trombay 6	500	17/02/2015	21.50		Continued.	Economic shutdown	
CENT.SECTOR	TARAPUR 4	540	18/02/2015	06.54		Continued.	AVR Problem	
MSPGCL	Koyana STG- IV Unit - 1	250	20/02/2015	09.00		Continued.	Spherical valve servo motor maintance work	
IPP	WPCL U-3	135	21/02/2015	00.34		Continued.	ID Fan Problem	
MSPGCL	Uran Unit 8	108	25/02/2015	13.32		Continued.	Gas shortage	
MSPGCL	Chandrapur Unit 4	210	25/02/2015	23.12	01/03/2015	08.52	Water Wall Tube Leakage.	
IPP	Adani U-5	660	26/02/2015	10.08		Continued.	Feed Water Comman PRV Leakage.	
MSPGCL	Chandrapur Unit 5	500	26/02/2015	21.39		Continued.	BTL.	
MSPGCL	Parli Unit 5	210	27/02/2015	10.58		Continued.	Generator Protection operated	
IPP	JSW (J) U4	300	01/03/2015	03.36	01/03/2015	14.40	Over Voltage.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Mar/2015

Position as on 6.30 Hrs of 02/Mar/2015

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	JSW (J) U2	300	01/03/2015	03.36	02/03/2015	05.44	Over Voltage.	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Mar/2015

Statement-VII

Position as on 6.30 Hrs of 02/Mar/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Dabhol New koyna I	InterState	08/02/2015	18:18		Continued.	HT	Over Voltage
Dabhol Nagothane II	InterState	13/02/2015	18:02		Continued.	T	Over Voltage
Kolhapur Mapusa II	InterState	26/02/2015	08.43		Continued.	PO	Insulator Replacement Work
Dhule Sar'Sarovar I	InterState	28/02/2015	17.14	01/03/2015	08.40	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	28/02/2015	21.04	01/03/2015	05.20	HT	Over Voltage
Kolhapur Solapur (PG) II	InterState	01/03/2015	00.53		Continued.	T	Over Voltage
Lamboti - Solapur (PG)	InterState	01/03/2015	01.33		Continued.	T	Distance Protection
Kolhapur Mapusa I	InterState	01/03/2015	03.25	01/03/2015	06.02	T	Over Voltage
Dhule Sar'Sarovar II	InterState	01/03/2015	03.31		Continued.	T	Over Voltage
Karad Solapur (PG)	InterState	01/03/2015	03.35	01/03/2015	09.47	T	Over Voltage
Kolhapur Solapur(PG) I	InterState	01/03/2015	06.44	01/03/2015	07.21	T	Over Voltage
Kolhapur Mapusa II	InterState	01/03/2015	14.34		Continued.	HT	Over Voltage
Karad Solapur (PG)	InterState	01/03/2015	17.14		Continued.	T	Over Voltage
Taptitanda Waluj	IntraState	27/01/2015	18.20		Continued.	HT	B Ph Jumper Open.
New Koyna -Koyna Stage IV-I	IntraState	26/02/2015	10.49		Continued.	PO	Shifted on TBC.
Koradi-Bhusawal	IntraState	28/02/2015	08.15		Continued.	PO	CT tan delta and relay testing work.
karad -kolhapur-II	IntraState	28/02/2015	16.07		Continued.	HT	Over Voltage
Karad-Jaigad - I	IntraState	28/02/2015	16.35		Continued.	HT	Over Voltage
Akola li - Taptitanda	IntraState	28/02/2015	19.01		Continued.	HT	Sparking on R-Ph CVT jumper at Taptitanda end.
Lonikand I - Koyna stage-IV	IntraState	28/02/2015	20.05		Continued.	HT	To control O/L.
karad -kolhapur-I	IntraState	01/03/2015	01.54	01/03/2015	09.00	T	Over Voltage
Chandrapur-Parali 3	IntraState	01/03/2015	01.55	01/03/2015	18.51	T	Over Voltage
Karad - Lonikand 1	IntraState	01/03/2015	03.24	01/03/2015	07.00	T	Over Voltage
Jaigad-New Koyna Ckt-I	IntraState	01/03/2015	03.24	01/03/2015	07.43	T	Over Voltage
Jaigad-New Koyna Ckt-li	IntraState	01/03/2015	03.24	01/03/2015	09.33	T	Over Voltage
Karad - Jaigad - II	IntraState	01/03/2015	03.24		Continued.	T	Over Voltage
N.Koyna-Karad -Ckt 1	IntraState	01/03/2015	03.24		Continued.	T	Over Voltage
New Koyna - Dabhol - li	IntraState	01/03/2015	03.24	01/03/2015	07.53	T	Over Voltage
New Koyna -Koyna Stage IV-I	IntraState	01/03/2015	03.27	01/03/2015	09.18	T	Over Voltage
Babhaleshwar - Padghe-II	IntraState	01/03/2015	03.34	01/03/2015	07.52	T	Over Voltage
Karad - Jaigad - II	IntraState	01/03/2015	03.35	01/03/2015	Continued.	T	Over Voltage
Jaigad-New Koyna Ckt-I	IntraState	01/03/2015	03.35	01/03/2015	07.43	T	Over Voltage
New Koyna - Koyna Stage IV-II	IntraState	01/03/2015	03.35	01/03/2015	07.30	T	Over Voltage
N.Koyna-Karad -Ckt 2	IntraState	01/03/2015	03.36	01/03/2015	08.22	T	Over Voltage
Akola li - Taptitanda	IntraState	01/03/2015	13.23	01/03/2015	15.50	T	Over Voltage
Jejuri- Koynastage-Iv	IntraState	01/03/2015	17.15	01/03/2015	19.06	T	Distance Protection
Lonikand I - Koyna stage-IV	IntraState	01/03/2015	21.29		Continued.	HT	Over Voltage
Chandrapur-Parali 3	IntraState	01/03/2015	21.40	02/03/2015	06.49	T	Over Voltage
karad -kolhapur-I	IntraState	02/03/2015	00.07		Continued.	T	Over Voltage
Akola li - Taptitanda	IntraState	02/03/2015	01.16	02/03/2015	06.34	T	Over Voltage
Babhaleshwar-Taptitanda ckt-II	IntraState	02/03/2015	01.16	02/03/2015	06.16	T	Over Voltage
Babhaleshwar - Padghe-II	IntraState	02/03/2015	01.16		Continued.	T	Over Voltage

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Mar/2015

Statement-VII

Position as on 6.30 Hrs of 02/Mar/2015

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Kalwa - Talegaon(PG)	IntraState	02/03/2015	02.22		Continued.	T	Over Voltage
400 KV ICT Outages/Trippings							
400/220 KV 500 MVA ICT- 2 @Warora	IntraState	16/02/2015	10:43		Continued.	HT	Attending CTR Fire System Nitrogen Leakage
400/220 KV 500 MVA ICT- 1 @Warora	IntraState	16/02/2015	18.56		Continued.	PO	Attending Oil Leakage
400/220 Kv 500 MVA ICT 3 @Kolhapur	IntraState	28/02/2015	11.54		Continued.	PO	R-Ph unit replacement.
400/220kv 315 Mva ICT 1 @ Kolhapur	IntraState	01/03/2015	03.25	01/03/2015	09.20	T	Over Voltage
400/220 Kv 315 Mva Ict -2 @New Koyna	IntraState	01/03/2015	03.35	01/03/2015	07.49	T	Over Voltage
400/220kv 315MVA ICT 2 @ Kolhapur	IntraState	01/03/2015	03.35	01/03/2015	09.22	T	Over Voltage
400/220kv 315 Mva Ict 1 @Karad	IntraState	01/03/2015	05.06	01/03/2015	10.39	T	Over Voltage
400/220kv 315 Mva ICT 3 @Karad	IntraState	01/03/2015	05.07	01/03/2015	07.11	T	Over Voltage
400/220 Kv 315 MVA ICT -I @New Koyna	IntraState	01/03/2015	05.21	01/03/2015	07.39	T	Over Voltage
400/220 KV 315 MVA ICT- 1 @Koradi	IntraState	02/03/2015	01.10		Continued.	T	On NDR.
220 KV LINE Outages/Trippings							
Talandage - Chikodi	InterState	01/03/2015	03.25	01/03/2015	10.25	T	Over Voltage
Mudshingi - Chikodi	InterState	01/03/2015	04.40	01/03/2015	22.25	T	Over Voltage
Nasik Navsari I	InterState	01/03/2015	20.19		Continued.	HT	To Control Bus Section Load @ Nasik GCR.
TBC @ Parli-II	IntraState	07/01/2015	15.48		Continued.	PO	Shifting of control panel
Butibori-Butibori Rly Tss	IntraState	18/02/2015	09:56		Continued.	PO	Erection of CB and CC, Dismantling of CB, Aligment of Line Isolator.
Magar Patta City- Serum	IntraState	23/02/2015	10.35		Continued.	HT	To control Lonikand ict loading
Kalwa Salsette 3	IntraState	24/02/2015	08.36		Continued.	PO	strengthening work
Uran - Kharghar 1	IntraState	27/02/2015	11.36		Continued.	PO	Tower height rising work.
Miraj - Ichalkaranji li	IntraState	28/02/2015	10.56		Continued.	HT	To control loading of ICT at Kolhapur.
Karad - Vita Ckt- 2	IntraState	01/03/2015	03.24	01/03/2015	07.43	T	Over Voltage
Karad-Nerle	IntraState	01/03/2015	03.34	01/03/2015	04.40	T	Over Voltage
Sadawaghapur Karad Ckt 2	IntraState	01/03/2015	04.15	01/03/2015	13.58	T	For Curtailing Wind Gen.
220 KV ICT Outages/Trippings							
220/100 Kv 200 MVA ICT III @Borivali	IntraState	21/09/2014	09.16		Continued.	T	Monkey Fault
132 KV LINE Outages/Trippings							
Telgaon - Majalgaon	IntraState	01/03/2015	01.30	01/03/2015	03.00	T	Backup Protection Operated O/C & E/F B Ph - E.
Telgaon - Majalgaon	IntraState	01/03/2015	04.40	01/03/2015	05.35	T	Backup Protection Operated O/C & E/F.
Parbhani li - Partur	IntraState	01/03/2015	05.15	01/03/2015	05.33	T	Distance Protection Operated Z-I R Ph.
Waghala -Nanded-I(Jangamwadi)	IntraState	01/03/2015	22.13		Continued.	T	Y Ph LA Burst.
Waghala - Jugamwadi Ckt 2	IntraState	01/03/2015	22.13	01/03/2015	22.28	T	Distance Protection Operated Z-I B Ph.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage