

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Jun/2021 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	113.521	113.521	1) Gujrat	3.564	3.564
2) Hydro	11.023	11.023	2) Madhya Pradesh	12.588	12.588
3) Gas	6.620	6.620	3) Chattisgarh	6.040	6.040
Total MSPGCL	131.164	131.164	4) Maharashtra	161.325	161.325
B) 1) APLM	30.657	30.657	5) Goa (Amona)	-1.261	-1.261
2) JSWEL	20.707	20.707	Total	182.256	182.256
3) VIPL	0.000	0.000	a) Mumbai Schedule	30.529	30.529
4) RPL(AMT)	31.343	31.343	b) Mumbai Drawl	28.208	28.208
5) SWPGPL	8.439	8.439	c) MSEDCL Bilateral *	58.162	58.162
6) Other IPP	9.317	9.317	Include PX	11.306	11.306
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	30.509	30.509
C) 1) TPCL Thermal	14.285	14.285	Include PX	18.246	18.246
2) TPCL Hydro	5.286	5.286	Standby	0.020	0.020
3) TPCL Gas	4.041	4.041	H) ENERGY CATERED (MUs)		
4) AEML Thermal	5.943	5.943	1) MSEDCL	408.099	408.099
D) STATE			2) Mumbai Discoms	57.763	57.763
1) Thermal	234.212	234.212	TOTAL STATE	465.862	465.862
(A1+C1+C4+(B1-B6))					
2) Hydro (A2+C2)	16.309	16.309			
3) Gas (A3+B7+C3)	10.661	10.661			
4) Wind	15.949	15.949			
6) SOLAR	6.475	6.475			
TOTAL STATE	283.606	283.606			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 23 Hrs
MSPGCL Thermal	4707	4609	4567	4368
MSPGCL Hydro	442	531	441	307
MSPGCL Gas	268	267	271	285
MSPGCL Total Generation	5417	5407	5279	4960
Central Sector Receipt	8854	9122	6241	6655
WIND	144	460	1505	713
CPP / IPP Thermal	4217	4139	4122	4170
CPP / IPP Gas	0	0	0	0
SOLAR	895	712	21	0
Exchange with Mumbai	-1444	-1484	-1046	-1076
MSEDCL DEMAND MET	18083	18356	16122	15422
Load Shedding	0	0	0	0
MSEDCL DEMAND	18083	18356	16122	15422
TPCL GENERATION	1029	1050	1084	1074
AEML GENERATION	250	251	251	205
MUMBAI DEMAND	2723	2785	2381	2355
STATE DEMAND MET	20806	21141	18503	17777
STATE DEMAND	20806	21141	18503	17777
Frequency (Hz)	49.97	50.00	49.98	49.89

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.25 Hz at 01:18 Hrs	49.73 Hz at 22:15 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 01/Jun/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	11.30	11.30	530	398
Total	11.30	11.30		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	11.72	11.72	500	310
Unit 5	2.28	2.28	465	0
Total	14.00	14.00		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.38	3.38	152	116
Unit 4	3.99	3.99	174	145
Unit 5	9.32	9.32	420	355
Unit 6	9.26	9.26	410	335
Unit 7	0.00	0.00	0	0
Unit 8	11.73	11.73	495	480
Unit 9	10.05	10.05	450	244
Total	47.73	47.73		
Paras				
Unit 3	5.33	5.33	242	160
Unit 4	5.71	5.71	253	175
Total	11.04	11.04		
Khaparkheda				
Unit 1	2.53	2.53	125	80
Unit 2	4.04	4.04	180	135
Unit 3	4.07	4.07	180	145
Unit 4	3.76	3.76	175	125
Unit 5	11.19	11.19	500	447
Total	25.59	25.59		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.86	3.86	200	121
Unit 5	0.00	0.00	0	0
Total	3.86	3.86		
Uran				
All Units	6.62	6.62	287	266
Total	6.62	6.62		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.32	0.32	22	0
Total	0.32	0.32		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.88	2.88	340	32
Stage 4	1.13	1.13	257	0
Stage 3	0.84	0.84	90	0
Total	4.85	4.85		
Hydro				
KDPH	0.34	0.34	14	14
VTRNA	0.85	0.85	59	0
TILLARI	0.58	0.58	58	0
BHIRA T.R.	0.22	0.22	77	0
SMLHY_PTN	4.18	4.18	201	151
GHATGHAR	0.00	0.00	0	0
Total	6.18	6.18		
Wind				
Total	15.95	15.95	0	0
Total	15.95	15.95		
CPP				
APML(Mus)	30.66	30.66	0	0
JSWEL(Mus)	20.71	20.71	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	31.34	31.34	0	0
SWPGPL-Mus	8.44	8.44	0	0
Other(Mus)	9.32	9.32	0	0
Total	100.46	100.46		
SOLAR				
Total	6.48	6.48	0	0
Total	6.48	6.48		
Tata				
Trombay 5	9.14	9.14	435	281
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.52	2.52	116	100
Trombay 7B	1.52	1.52	66	62
Trombay 8	5.14	5.14	227	142
TATA Hydro	5.29	5.29	449	0
Total	23.61	23.61		
AEML				
DTPS U-1&2	5.94	5.94	252	205
Total	5.94	5.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	113.52	113.52	MSPGCL Total	131.16	131.16
			MSPGCL Thml+Gas	120.14	120.14	Koyna 1,2 & 4 Total	4.01	4.01
			MSPGCL Hydro	11.02	11.02	State Total	283.61	283.61

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Jun/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	5059	321	275	5655	742	4061	0	0	7352	7395	-1252	16601	0	16601	2509	19110	50.00
2	5172	538	287	5997	738	4156	0	0	6727	6828	-1104	16615	0	16615	2334	18949	50.09
3	5138	367	286	5791	679	4273	0	0	6619	6680	-1055	16368	0	16368	2195	18563	50.03
4	5183	253	275	5711	627	4185	0	0	6779	6567	-1056	16034	0	16034	2088	18122	50.01
5	5132	264	275	5671	558	4177	0	0	6925	7034	-1016	16424	0	16424	2027	18451	49.91
6	4843	240	277	5360	592	4233	0	0	7812	8106	-941	17350	0	17350	2024	19374	50.03
7	4824	636	285	5745	502	4205	0	48	8485	8383	-947	17936	0	17936	1981	19917	49.99
8	4815	278	275	5368	448	4268	0	230	8514	8307	-999	17622	0	17622	2052	19674	49.99
9	4804	480	274	5558	347	4273	0	456	7674	8104	-1226	17512	0	17512	2248	19760	50.02
10	4793	739	271	5803	247	4278	0	645	7995	8155	-1239	17889	0	17889	2496	20385	50.06
11	4760	445	280	5485	137	4245	0	811	8728	8623	-1374	17927	0	17927	2668	20595	49.98
12	4707	442	268	5417	144	4217	0	895	9026	8854	-1444	18083	0	18083	2723	20806	49.97
13	4683	417	266	5366	180	4242	0	978	9137	8806	-1531	18041	0	18041	2720	20761	49.94
14	4669	473	266	5408	275	4202	0	885	8831	8820	-1424	18166	0	18166	2704	20870	49.94
15	4609	531	267	5407	460	4139	0	712	9132	9122	-1484	18356	0	18356	2785	21141	50.00
16	4643	758	278	5679	680	4113	0	431	8796	8908	-1539	18272	0	18272	2816	21088	50.03
17	4682	903	270	5855	627	4126	0	251	8251	7961	-1321	17499	0	17499	2735	20234	50.01
18	4592	471	270	5333	1027	4135	0	112	7727	7317	-1105	16819	0	16819	2568	19387	49.99
19	4567	441	271	5279	1505	4122	0	21	6718	6241	-1046	16122	0	16122	2381	18503	49.98
20	4608	464	282	5354	1639	4231	0	0	6241	5766	-925	16065	0	16065	2348	18413	50.01
21	4429	366	275	5070	1393	4141	0	0	6504	5995	-992	15607	0	15607	2294	17901	49.94
22	4074	309	286	4669	1274	4039	0	0	6848	6600	-1042	15540	0	15540	2279	17819	49.90
23	4368	307	285	4960	713	4170	0	0	6597	6655	-1076	15422	0	15422	2355	17777	49.89
24	4367	580	276	5223	415	4232	0	0	6640	7029	-1070	15829	0	15829	2433	18262	50.00
MUs	113.52	11.02	6.62	131.16	15.95	100.46	0.00	6.48	184.06	182.26	-28.21	408.10	0.00	408.10	57.76	465.86	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Jun/2021

Position as on 6.30 Hrs of 02/Jun/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 6	80	22/04/2021	12.00		Continued.	UGC Oil Cooler Leakage.(Converted to Capital Overhaul from 08.00Hrs DT.23-4-2021)	25/06/2021
AEML	AEML Unit 1	250	19/05/2021	09.52		Continued.	HP turbine replacement.	
FORCED OUTAGE								
IPP	SWPGPL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Nasik Unit 3	210	03/12/2020	06.45		Continued.	PA Fan Problem (Under Case 4 Bidding From 11.00Hrs DT. 21-01-2021).	
MSPGCL	Chandrapur Unit 7	500	20/02/2021	23.43		Continued.	Generator Earth Fault.	
MSPGCL	Koradi Unit 6	210	27/04/2021	19.59		Continued.	Zero Schedule.	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Bhusawal Unit 3	210	04/05/2021	20.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 6	250	04/05/2021	20.00		Continued.	Zero Schedule By MSEDCL	
MSPGCL	Parli Unit 7	250	05/05/2021	19.00		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	06/05/2021	19.45		Continued.	Zero Schedule	
IPP	Adani U-4	660	16/05/2021	10.01		Continued.	Zero Schedule.	
IPP	Adani U-1	660	16/05/2021	17.57		Continued.	Zero Schedule By MSEDCL.	
IPP	Adani U-5	660	17/05/2021	12.05		Continued.	Zero schedule.	
MSPGCL	Nasik Unit 5	210	17/05/2021	12.50		Continued.	Zero schedule.	
MSPGCL	Uran Unit 6	108	17/05/2021	22.59		Continued.	Gas shortage.	
MSPGCL	Koradi Unit-8	660	25/05/2021	03.52		Continued.	Boiler Tube Leakage	
MSPGCL	Koradi Unit 9	660	31/05/2021	21.59		Continued.	Boiler Tube Leakage	
MSPGCL	Bhusawal Unit 5	500	01/06/2021	05.21		Continued.	Boiler Tube Leakage	
MSPGCL	Chandrapur Unit 9	500	01/06/2021	23.57		Continued.	Boiler Validity Renevoation	
IPP	RPL(AMT) U-5	270	02/06/2021	14.29		Continued.	Bottom ash problem	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2021

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Lamboti - Solapur (PG)	InterState	02/06/2021	21.50		Continued.	T	Distance Protection
Babhleshwar - RIPL(Nashik)	IntraState	18/03/2021	15.48		Continued.	PO	Hot spot attending.
Bhusawal-Aurangabad	IntraState	31/05/2021	21.12	01/06/2021	09.32	HT	Over Voltage
Khadka-Aurangabad (Waluj)	IntraState	01/06/2021	20.01	02/06/2021	09.45	HT	Over Voltage
Pune(GIS)-A'bad(Waluj) Ckt 1	IntraState	01/06/2021	20.52	01/06/2021	23.38	T	Rain at Waluj.
Parly(MS)- Nanded ckt I	IntraState	02/06/2021	00.11	02/06/2021	01.32	T	Distance Protection
New Koyna - Koyna Stage IV-II	IntraState	02/06/2021	10.11	02/06/2021	21.44	PO	Routine Maintenance Work
Ektuni-Taptitanda II	IntraState	02/06/2021	15.58	02/06/2021	18.11	EO	Attending Hot spot of stub bus Y phase jumper.
Pune(GIS)-A'bad(Waluj) Ckt 2	IntraState	02/06/2021	16.15	02/06/2021	16.31	EO	To take line reactor in service
Karad-Jaigad - I	IntraState	02/06/2021	22.13		Continued.	T	Distance Protection
Karad - Jaigad - II	IntraState	02/06/2021	22.13		Continued.	T	Distance Protection
400 KV ICT Outages/Trippings							
400/220kv 315 MVA ICT I @ KOLHAPUR-III (TALANDGE)	IntraState	10/08/2020	09.58		Continued.	PO	Replacement of existing 315 MVA ICT by 3*167 MVA ICT.(FTC DT 16/08/2021 At 14.42)
400/132 Kv 200 Mva Ict 2 @Khadka	IntraState	01/06/2021	07.58	01/06/2021	13.40	PO	For premonsoon maintenance work.
400/220/33 Kv 500 MVA ICT-III @Parali (Girwali)	IntraState	01/06/2021	10.01	01/06/2021	17.10	PO	Pre- monsoon Maintenance Viz. covering of Buchholz PRV and Bay Maintenance.
400/220KV 315MVA ICT-II @Akola (M)	IntraState	01/06/2021	10.07	01/06/2021	17.17	PO	Pre-monsoon, routine maint & testing work.
400/220/33kv 315MVA ICT-I @Lonikand	IntraState	02/06/2021	07.07	02/06/2021	10.06	T	Y-Phase oil temperature tripped.
167 Mva Spare Ict @Lamboti	IntraState	02/06/2021	10.16	02/06/2021	16.32	PO	Diagnostic testing work
400/220kv, 500 MVA ICT-III @Babhleshwar	IntraState	02/06/2021	21.08	02/06/2021	23.54	PO	Premonsoon maintenance work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule(Charge from Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule(Close at Chikodi end only)
PARLY (PG) - OLD GCR PARLI	InterState	01/06/2021	15.43	01/06/2021	18.58	T	Distance Protection
Mahalakshmi Amona	InterState	01/06/2021	16.09	01/06/2021	18.40	T	Distance Protection
PARLY (PG) - OSMANABAD	InterState	01/06/2021	20.15	01/06/2021	21.04	T	Tripped due to lbb operated 33 kv fault 220 kv osmanabad bus-bar operated.
Solapur (Pg) South Solapur li	InterState	02/06/2021	11.33	02/06/2021	17.54	PO	Outage is required for stringing at Loc no. 238 to 239 of proposed 220KV Narangwadi solapur (PGCIL) DCDC line.
Solapur (Pg) South Solapur I	InterState	02/06/2021	11.33	02/06/2021	17.52	PO	Outage is required for stringing at Loc no. 238 to 239 of proposed 220KV Narangwadi solapur (PGCIL) DCDC line.
Uran - Kharghar I	IntraState	30/05/2021	08.55	01/06/2021	21.52	PO	Tower erection at proposed Ulwe GIS from 30.05.2021 to 01.06.2021.
Kandalgaon - Sona Alloys	IntraState	31/05/2021	12.40	01/06/2021	12.32	T	Y-Phase Conductor Snapped At Loc 138 & 139.
BOISAR BORIVALI	IntraState	01/06/2021	10.19	01/06/2021	21.28	PO	Retrofitting work of Earth Isolator.
Mururd - Tuljapur	IntraState	01/06/2021	10.29	01/06/2021	13.15	PO	Line Maintenance work
Pargaon(Kathapur)-Lonikand	IntraState	01/06/2021	11.43	01/06/2021	15.41	EO	Work of attending re stringing of earth wire at Loc No 68 to 69 in view of tripping on dtd. 29.05.2021.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2021

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Ranjangaon-Lonikand	IntraState	01/06/2021	11.52	01/06/2021	15.28	EO	Work of attending re stringing of earth wire at Loc No 68 to 69 for 220Kv kathapur Lonikand II line in view of tripping on dtd. 29.05.2021.
Karad - Vita Ckt- I	IntraState	01/06/2021	13.35	01/06/2021	19.22	PO	Relay testing for Auto Reclose work and CB maintenance work.
Ghatghar - Jindal	IntraState	01/06/2021	17.18	01/06/2021	18.39	T	Distance Protection
Eklahare (Gcr)(Nashik)- Ghatghar	IntraState	01/06/2021	17.19	01/06/2021	17.54	T	Distance Protection
Khaparkheda-Ambazari-I	IntraState	02/06/2021	09.47	02/06/2021	17.09	PO	Replacement of flashover string at various locations.
Boisar Versova Line	IntraState	02/06/2021	14.21	02/06/2021	15.13	PO	Premonsoon maintenance work.
Sadawaghapur Karad Ckt 2	IntraState	02/06/2021	15.31	02/06/2021	17.31	EO	Removal of R ph LA jump.
Karad -Mudshingi Ckt- IV	IntraState	02/06/2021	23.04		Continued.	EO	Sparking at Loc no.174 R-ph string replacement work.
220 KV ICT Outages/Trippings							
220/132 KV 150MVA ICT I @ Boisar	IntraState	17/05/2021	11.19		Continued.	T	ICT Failed due to internal fault.
220/132 Kv 200 Mva Vijay Ict 1 @Chalisgaon	IntraState	01/06/2021	08.21	01/06/2021	10.17	PO	Premonsoon maintenance work.
220/132 Kv 200 Mva Vijay Ict 2 @Chalisgaon	IntraState	01/06/2021	10.01	01/06/2021	11.40	PO	Premonsoon and testing work.
220/132kv 100MVA ICT I @Satara Midc	IntraState	01/06/2021	11.01	01/06/2021	16.35	PO	Quarterly maintenance & Tan delta testing work.
200/132KV 100MVA ICT-1@Butibori	IntraState	02/06/2021	08.28	02/06/2021	09.18	PO	Pre-monsoon maintenance work.
220/132 kv 100 MVA ICT II @ Butibori	IntraState	02/06/2021	09.21	02/06/2021	10.03	PO	Pre-monsoon maintenance work.
220/132 kv 200 MVA ICT- I @ Nanded	IntraState	02/06/2021	10.10	02/06/2021	13.03	PO	Pre-monsoon maintenance work.
220/100 Kv 200 MVA ICT-II @Trombay	IntraState	02/06/2021	10.14	02/06/2021	20.00	PO	1)Premonsoon maintenance work 2)Routine maintenance work 3)100kv isolator work.
220/132 KV 200MVA ICT I @ Kanhan	IntraState	02/06/2021	10.16	02/06/2021	11.04	PO	Pre-monsoon maintenance work.
220/132 Kv 100 Mva Cgl Ict 1 @Bhugaon	IntraState	02/06/2021	10.39	02/06/2021	12.22	PO	Pre-monsoon maintenance work.
220/132 Kv 150 Mva Cgl Ptr No 7 @Chinchwad	IntraState	02/06/2021	10.58	02/06/2021	12.38	PO	Premonsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 1 @Beed	IntraState	02/06/2021	11.01	02/06/2021	12.05	PO	Pre-monsoon maintenance work.
220/132kv 200 Mva Aditya Vidyut Ict 2 @Kanhan	IntraState	02/06/2021	11.10	02/06/2021	11.54	PO	Pre-monsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 2 @Beed	IntraState	02/06/2021	12.11	02/06/2021	12.56	PO	Pre-monsoon maintenance work.
220/132 Kv 200mva Cgl Ptr No 3 @Chinchwad	IntraState	02/06/2021	12.54	02/06/2021	14.14	PO	Premonsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 1 @Kalmeshwar	IntraState	02/06/2021	13.45	02/06/2021	15.25	PO	Pre-monsoon maintenance work.
220/132 Kv 200 MVA ICT II @Kalmeshwar	IntraState	02/06/2021	15.53	02/06/2021	17.08	PO	Pre-monsoon maintenance work.
220/132 Kv 200 Mva Bbl Ict 2 @Waghala Nanded	IntraState	02/06/2021	16.25	02/06/2021	17.52	PO	Pre-monsoon maintenance work.
220/132 Kv 100 Mva Ict 1 @Bhokardan	IntraState	02/06/2021	17.01	02/06/2021	18.46	PO	Pre-monsoon maintenance work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage