

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Jun/2023 THURSDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	144.292	144.292	1) Gujrat	-1.854	-1.854
2) Hydro	28.486	28.486	2) Madhya Pradesh	10.320	10.320
3) Gas	5.549	5.549	3) Chattisgarh	4.850	4.850
Total MSPGCL	178.327	178.327	4) Maharashtra	223.083	223.083
B) 1) APMIL	64.890	64.890	5) Goa (Amona)	-1.226	-1.226
2) JSWEL	27.000	27.000	Total	235.173	235.173
3) VIPL	0.000	0.000	a) Mumbai Schedule	45.891	45.891
4) RPL(AMT)	30.955	30.955	b) Mumbai Drawl	49.236	49.236
5) SWPGPL	9.877	9.877			
6) Other IPP	2.810	2.810	c) MSEDCL Bilateral *	118.628	118.628
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	13.148	13.148	d) Mumbai Bilateral *	45.891	45.891
2) TPCL Hydro	6.309	6.309	Include PX	0.000	0.000
3) TPCL Gas	2.142	2.142	Standby	0.000	0.000
4) AEML Thermal	7.545	7.545			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	300.517	300.517	1) MSEDCL	529.130	529.130
2) Hydro (A2+C2)	34.795	34.795	2) Mumbai Discoms	78.380	78.380
3) Gas (A3+B7+C3)	7.691	7.691	3) Other Discoms	10.707	10.707
4) Wind	23.727	23.727			
6) SOLAR	16.314	16.314	TOTAL STATE	618.217	618.217
TOTAL STATE	383.044	383.044			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	5715	5974	6114	6072
MSPGCL Hydro	877	1137	1091	511
MSPGCL Gas	204	201	288	227
MSPGCL Total Generation	6796	7312	7493	6810
Central Sector Receipt	11392	11252	8319	9835
WIND	347	438	1923	686
CPP / IPP Thermal	5195	5213	5670	5858
CPP / IPP Gas	0	0	0	0
SOLAR	2156	1716	0	620
Exchange with Mumbai	-2540	-2573	-1831	-1838
MSEDCL DEMAND MET	22867	22881	21071	21528
Load Shedding	0	816	0	0
MSEDCL DEMAND	22867	23697	21071	21528
TPCL GENERATION	875	947	1153	555
AEML GENERATION	351	381	285	289
MUMBAI DEMAND	3766	3901	3269	2682
OTHER DISCOM DEMAND	479	477	503	443
STATE DEMAND MET	27112	27258	24843	24653
STATE DEMAND	27112	28074	24843	24653
Frequency (Hz)	50.04	49.93	49.98	50.03

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.25 Hz at 08.02 Hrs	49.78 Hz at 14.11 Hrs	50.02	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Jun/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.72	4.72	205	185
Unit 8	0.00	0.00	0	0
Unit 9	0.00	0.00	0	0
Unit 10	12.44	12.44	580	465
Total	17.16	17.16		
Bhusawal				
Unit 3	3.29	3.29	150	115
Unit 4	9.32	9.32	440	290
Unit 5	9.36	9.36	465	315
Total	21.98	21.98		
Parli				
Unit 6	5.79	5.79	250	193
Unit 7	5.38	5.38	248	187
Unit 8	3.99	3.99	190	141
Total	15.15	15.15		
Chandrapur				
Unit 3	3.33	3.33	150	118
Unit 4	3.62	3.62	156	146
Unit 5	0.00	0.00	0	0
Unit 6	9.28	9.28	400	360
Unit 7	9.56	9.56	415	362
Unit 8	11.52	11.52	491	449
Unit 9	11.65	11.65	499	469
Total	48.97	48.97		
Paras				
Unit 3	4.77	4.77	223	185
Unit 4	4.92	4.92	225	186
Total	9.69	9.69		
Khaparkheda				
Unit 1	3.20	3.20	140	120
Unit 2	3.19	3.19	142	108
Unit 3	1.26	1.26	180	0
Unit 4	4.51	4.51	192	182
Unit 5	11.20	11.20	475	450
Total	23.36	23.36		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	4.01	4.01	176	145
Unit 5	3.97	3.97	173	158
Total	7.98	7.98		
Uran				
All Units	5.55	5.55	310	201
Total	5.55	5.55		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.04	0.04	16	0
Total	0.04	0.04		
Koyna				
Stage 1-2	6.26	6.26	505	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	13.49	13.49	1003	0
Stage 3	4.64	4.64	320	80
Total	24.39	24.39		
Hydro				
KDPH	0.49	0.49	21	20
VTRNA	1.16	1.16	61	0
TILLARI	0.46	0.46	58	0
BHIRA T.R.	0.40	0.40	80	0
SMLHY_PTN	1.55	1.55	74	61
GHATGHAR	0.00	0.00	0	0
Total	4.06	4.06		
Wind				
Total	23.73	23.73	0	0
Total	23.73	23.73		
CPP				
APML(Mus)	64.89	64.89	0	0
JSWEL(Mus)	27.00	27.00	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	30.96	30.96	0	0
SWPGPL-Mus	9.88	9.88	0	0
Dhariwal	0.00	0.00	0	0
IEPL	0.00	0.00	0	0
Other(Mus)	2.81	2.81	0	0
Total	135.53	135.53		
SOLAR				
Total	16.31	16.31	0	0
Total	16.31	16.31		
Tata				
Trombay 5	8.57	8.57	424	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.18	1.18	88	38
Trombay 7B	0.96	0.96	57	35
TATA Hydro	6.31	6.31	422	69
Trombay 8	4.58	4.58	230	126
Total	21.60	21.60		
AEML				
DTPS U-1&2	7.54	7.54	381	285
Total	7.54	7.54		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	144.29	144.29	MSPGCL Total	178.33	178.33
			MSPGCL Thml+Gas	149.84	149.84	Koyna 1,2 & 4 Total	19.75	19.75
			MSPGCL Hydro	28.49	28.49	State Total	383.04	383.04

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Jun/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6048	1996	310	8354	1038	6094	0	0	8842	9278	-1829	22534	0	0	22534	3264	401	26199	49.98
2	6139	1983	239	8361	854	6090	0	0	9400	9275	-1686	22527	0	0	22527	3038	367	25932	50.01
3	6160	1829	223	8212	795	6094	0	0	9371	9533	-1681	22604	0	0	22604	2825	349	25778	49.99
4	6155	1098	224	7477	847	6099	0	0	9945	9674	-1699	22063	0	0	22063	2663	335	25061	50.00
5	6150	853	224	7227	700	6155	0	0	10007	10169	-1692	22217	0	0	22217	2593	342	25152	50.03
6	6194	1109	224	7527	788	6205	0	2	10044	9969	-1727	22380	0	0	22380	2590	384	25354	49.98
7	6172	1092	227	7491	877	6050	0	174	9608	9612	-1724	22072	0	0	22072	2553	408	25033	50.07
8	6072	511	227	6810	686	5858	0	620	9645	9835	-1838	21528	0	0	21528	2682	443	24653	50.03
9	5884	346	223	6453	609	5553	0	1203	10060	9910	-2097	21160	0	0	21160	3010	471	24641	50.06
10	5848	312	216	6376	708	5346	0	1652	10530	10388	-2284	21699	0	0	21699	3360	486	25546	49.95
11	5769	522	204	6495	526	5326	0	2001	10601	10819	-2516	22170	0	0	22170	3624	481	26275	50.01
12	5715	877	204	6796	347	5195	0	2156	11016	11392	-2540	22867	0	24	22867	3766	479	27112	50.04
13	5757	559	203	6519	312	5230	0	2114	11481	11632	-2472	22860	0	36	22860	3783	475	27118	50.06
14	5848	409	202	6459	309	5186	0	1999	11445	11687	-2466	22698	0	7	22698	3757	476	26931	49.99
15	5974	1137	201	7312	438	5213	0	1716	10888	11252	-2573	22881	816	127	23697	3901	477	28074	49.93
16	6028	1472	202	7702	753	5302	0	1332	11102	11012	-2524	23083	481	104	23564	3952	494	28010	50.02
17	5989	1356	250	7595	896	5521	0	876	11173	10907	-2402	22892	0	43	22892	3831	502	27224	49.98
18	6017	1055	289	7361	1394	5529	0	397	10551	10005	-2292	21887	0	1	21887	3613	507	26007	50.07
19	6063	1172	292	7527	2079	5531	0	72	8690	8245	-2121	20838	0	0	20838	3346	495	24679	50.04
20	6114	1091	288	7493	1923	5670	0	0	8476	8319	-1831	21071	0	0	21071	3269	503	24843	49.98
21	6103	1830	209	8142	1733	5630	0	0	7546	7731	-1911	20846	0	0	20846	3219	479	24544	50.02
22	6065	1931	221	8217	1537	5627	0	0	7328	7629	-1747	20785	0	0	20785	3201	478	24464	50.04
23	6018	1957	224	8199	1829	5516	0	0	8084	8392	-1754	21733	0	0	21733	3233	449	25415	50.05
24	6010	1989	223	8222	1749	5512	0	0	8652	8509	-1830	21735	0	0	21735	3307	427	25469	50.03
MUs	144.29	28.49	5.55	178.33	23.73	135.53	0.00	16.31	234.49	235.17	-49.24	529.13	1.30	0.34	530.43	78.38	10.71	619.51	50.02

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1)DLS done as per instructions from 220 kV Baramati due to overloading of 220 KV Jejuri Baramati line.2) ELR carried out at 220KV GCR and 132 KV due to overloading.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Jun/2023

Position as on 6.30 Hrs of 02/Jun/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Nasik Unit 3	210	20/05/2023	08:45		Continued.	Boiler Tube Leakage(under tolling from 22.25Hrs DT. 20-5-2023)	
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	27/06/2023
IPP	IEPL Unit 1	270	24/05/2023	20:10		Continued.	Clinker formation in furnace	04/06/2023
IPP	SWPGPL U-1	135	29/05/2023	03:57	01/06/2023	05:30	ID Fan Problem	
MSPGCL	Koradi Unit 8	660	29/05/2023	05:36		Continued.	Boiler Tube Leakage	04/06/2023
MSPGCL	Koradi Unit 9	660	30/05/2023	00:08		Continued.	Boiler Tube Leakage	03/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	01:06	01/06/2023	16:08	No Schedule	
MSPGCL	Khaparkheda Unit 3	210	01/06/2023	07:43		Continued.	Boiler Tube Leakage	02/06/2023
IPP	Adani U-2	660	01/06/2023	08:04	01/06/2023	Continued.	Air heater problem	03/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-4	250	02/06/2023	07:28		Continued.	Governor accumulator oil pressure very low and quick stop requested.	
IPP	JSW (J) U1	300	02/06/2023	08:32		Continued.	Electrical fault	
MSPGCL	Parli Unit 7	250	02/06/2023	12:55		Continued.	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY (402) OF TAPTITANDA CKT - 2 @ EKTUNI	IntraState	02/06/2023	10:59			PO	Diagnostic Testing of CB, CT & Routine Maintenance
400 KV MAINBAY Outages/Trippings							
MAIN BAY 401 OF STN T/F 1	InterState	02/06/2023	06:09			PO	ST-1 (401bay) following work to be carried out 1. all three poles circuit breakers maintenance and testing work(DCRM,timing and CRM testing) 2. 3 nos. Bay CT tan testing work 3. 401 Bay protection relay testing work 4.isolator maintenance work.
400/6.9KV 63MVA STN T/F 1	InterState	02/06/2023	06:09			PO	ST-1 transformer oil leakage arresting, maintenance , diagnostic testing, Metering CT and CVT testing and ST1 transformer protection relay testing work. ST-1transformer painting work
MAIN BAY (401) OF TAPTITANDA CKT - 2 @ EKTUNI	IntraState	01/06/2023	10:48	01/06/2023	19:03	PO	Diagnostic Testing of CB, CT & Routine Maintenance
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
LAMBOTI - SOLAPUR (PG)	InterState	31/05/2023	16:36	01/06/2023	00:34	PO	Hardware tieghtning and washing
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	01/06/2023	18:07	02/06/2023	06:14	T	Tripped on distance protection
PADGHE - BOISAR (PG)	InterState	01/06/2023	18:24	01/06/2023	21:50	EO	To replace the broken R-ph CVT clamp
CHANDRAPUR GCR - CHANDRAPUR HVDC - 1	IntraState	20/05/2023	13:31	01/06/2023	09:12	PO	1. Replacement of CB with new Siemens make Quad CB along with its commissioning and testing. "400KV HVDC CKT-1" will be in service via 400KV TBC-2.
DABHOL - NEW KOYNA CKT - 2	IntraState	22/05/2023	13:26			PO	Dismantling of exising tilted old tower at location no 94 and erection of new tower (B+9ST) with foundation and stringing of conductor.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	23/05/2023	09:46			HT	For load management
KHADKA- DEEPNAGAR CKT 2	IntraState	25/05/2023	10:02				Servicing &overhauling of 400kv areva make kdk ckt-2 main c.b. mechanism.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
CHANDRAPUR GCR - CHANDRAPUR HVDC - 1	IntraState	01/06/2023	03:33	01/06/2023	09:12	EO	1. To attend the problem of low SF6 gas/N2/Oil alarm of 400kV BHEL make Quad CB of TBC-2 bay. 2. Protection trials newly erected Siemens Ltd. Make 420kV, 3150Amp. Quad Break Circuit Breaker of 400kV GCR Chandrapur-HVDC ckt. no-1 bay. 3. Charging of new 420kV, 3150Amp. Quad Break Circuit Breaker of 400kV GCR Chandrapur-HVDC ckt. no-1 bay.
JEJURI- KOYNA STAGE-IV	IntraState	01/06/2023	08:22	01/06/2023	15:24	PO	PID Faulty disc replacement work & Hot Spot attending Work at Loc No 1
DHARIWAL- CHANDRAPUR 2 CKT I	IntraState	01/06/2023	10:17	02/06/2023	11:10	PO	Work of MSEDCL/MSETCL energy meters disconnection work
DHARIWAL- CHANDRAPUR 2 CKT II	IntraState	02/06/2023	12:54			PO	Work of MSEDCL/MSETCL energy meters disconnection
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33KV ICT - 167 MVA SPARE ICT @LAMBOTI	IntraState	02/06/2023	10:10	02/06/2023	12:29	PO	Routine Testing and pre-monsoon activities
400/220kv 500MVA ICT-2 @ TAPTITANDA	IntraState	02/06/2023	10:48	02/06/2023	15:23	PO	Pre monsoon activity and relay testing work
400 KV BUSBAR Outages/Trippings							
MAIN BUS - 1 @ DHARIWAL	IntraState	01/06/2023	10:51	02/06/2023	11:10	PO	Line- 1 : Isolator 4-689B rectification work which is to be connected to Bus-II, so bus-II needs off loaded.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
AAREY - AEML SAKI CKT - 1	IntraState	28/05/2023	17:23			T	Tripped on Differential protection.
URSE-CHINCHWAD	IntraState	31/05/2023	17:56	01/06/2023	02:55	T	Tripped on distance protection
VERSOVA - GHODBUNDER	IntraState	01/06/2023	00:57	01/06/2023	07:14	PO	Erection of U-Girder at LOC P146-147 RHS along metro 9 near silver park - Mira Road. Outage proposed on behalf of MMRDA for Metro 9 project work.
PALGHAR - PANCHALI TSS	IntraState	01/06/2023	02:27	01/06/2023	08:06	PO	Replacement of Old rusted disc insulator with porcelain long rod insulator at various locations.
WAGHIVALI - DHARAVI 8	IntraState	01/06/2023	04:57	01/06/2023	07:36	PO	Installation of Split Core CT at Chunabhatti, Differential CT wiring at Dharavi
PANDHARPUR - KHANAPUR	IntraState	01/06/2023	07:51	01/06/2023	10:58	PO	Cold line washing work from Loc No.219-20
PARLI NEW TPS - BEED CKT 2	IntraState	01/06/2023	08:46	01/06/2023	10:16	PO	Pre-monsoon maintenance work, Bird nest removal work.
PETH- MUDSHINGI 1 LINE	IntraState	01/06/2023	10:18	01/06/2023	13:02	PO	Structure Painting Work
KANDALGAON - ONGC PANVEL	IntraState	01/06/2023	10:31	01/06/2023	15:47	PO	Routine maintenance & emergency tree cutting work & cold line cleaning of disc & polymer insulator

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 01/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
JEJURI-PHURSUNGI 1	IntraState	01/06/2023	11:36	01/06/2023	19:18	PO	For attending hot spot, double jumpering and replacement of nut bolts at loc no 11(B-ph), 16(B-ph), 19 (B-ph), 30 (B-ph), 71 (B-ph) and double jumpering work at loc no 01
KARAD -MUDSHINGI CKT 2-TAK	IntraState	01/06/2023	12:38	01/06/2023	15:54	EO	For checking noise in R ph CT secondary box
CHIKHALI-JALNA I	IntraState	01/06/2023	12:45	01/06/2023	16:57	EO	Replacement of Damaged B-phase conductor.
LONIKAND (400 KV)-THEUR II	IntraState	01/06/2023	14:10			PO	220kV Theur Ckt 2, C.B mechanism overhauling work by shifting its load on 220kV T.B.C Bay
GHATGHAR - JINDAL	IntraState	01/06/2023	16:40	01/06/2023	17:50	T	tripped on distance protection
RAYMOND - WASHALA	IntraState	01/06/2023	16:40	01/06/2023	19:17	T	Tripped on distance protection
KHADKI- CENTURY ENKA	IntraState	01/06/2023	18:46	01/06/2023	19:42	T	Tripped on distance protection
KALWA - COLOURCHEM	IntraState	01/06/2023	23:51	02/06/2023	02:46	HT	To replace Y Ph CT jumper at Colorchem Ss
VERSOVA - GHODBUNDER	IntraState	02/06/2023	01:24	02/06/2023	06:32	PO	Erection of U-Girder at LOC P147-148 LHS along metro line 9 near silver park - Metro Road. Outage proposed on behalf on MMRDA for Metro 9 project work.
GHODBUNDER - GORAI	IntraState	02/06/2023	01:42	02/06/2023	06:22	PO	Erection of U-Girder at LOC P147-148 RHS along metro line 9 near silver park-Mira Road. Outage proposed on behalf on MMRDA for Metro-9 project work.
CHEMBUR (AEML) - NERUL (M)	IntraState	02/06/2023	04:42	02/06/2023	09:35	PO	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL
SONKHAR - TROMBAY	IntraState	02/06/2023	05:15	02/06/2023	09:31	PO	Outage is required for safety purpose during stringing of 400KV Khargar-Vikhroli line between loc no. AP 56- AP 57 by M/s KVTL
PADGHE - JINDAL	IntraState	02/06/2023	08:14			PO	1)Installation & commissioning of 220KV isolator before metering 2)Servicing of 220KV PASS 3) Maintenance of 22KV switchgears and substation equipments
GHATGHAR - JINDAL	IntraState	02/06/2023	08:36			PO	1)Installation & commissioning of 220KV isolator before metering 2)Servicing of 220KV PASS 3) Maintenance of 22KV switchgears and substation equipments
NERLE - PEDAMBE	IntraState	02/06/2023	08:50			PO	For replacement of damaged conductor at loc no 51- Top ph Nerale side and Y ph Pedhambe side and At loc no 73 bottom ph Nerale side and at loc no 74 bottom ph Pedhambe side. . For replacement of damaged insulator string at loc no- 51.
SIEMENS - RELIANCE GIS	IntraState	02/06/2023	09:33	02/06/2023	13:03	PO	Premonsoon by maintenance work at both ends of substation
NAGAR BELWANDI CKT 1	IntraState	02/06/2023	10:00			PO	Replacement of Y ph (Cut point) flashover insu. String at loc 110 & 140 (Found during monkey patrolling)
BOISAR II - TARAPUR	IntraState	02/06/2023	10:20			HT	PLANNED OUTAGE AVAILED AT TARAPUR END

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2023

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WADA - BHAVEGHAR	IntraState	02/06/2023	10:40			PO	For Bus Isolator Maintenance work with the help of Hot Line Unit team.
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220 / 110 / 22kv 250 MVA ICT 2 @ SALSETTE	IntraState	10/11/2022	10:35			EO	For attending to abnormal Nosie from ICT
220/132 KV 100 MVA ICT 2 @ LONIKAND 2	IntraState	01/06/2023	06:16	01/06/2023	12:52	PO	For Rph LV Bushing replacement work
220/100 KV 200 MVA ICT 4 @ APTA	IntraState	02/06/2023	10:40			PO	HVCB Neumatic Drive overhauling work
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
WAGHIVALI - CHEMBUR	IntraState	01/06/2023	08:33	01/06/2023	09:41	PO	Removing Bird Nest at loc 66,67 and 68

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage