

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Jun/2024 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	168.141	168.141	1) Gujrat	3.867	3.867
2) Hydro	15.911	15.911	2) Madhya Pradesh	4.047	4.047
3) Gas	7.088	7.088	3) Chattisgarh	2.430	2.430
Total MSPGCL	191.140	191.140	4) Maharashtra	203.260	203.260
B) 1) APMIL	69.016	69.016	5) Goa (Amona)	-2.284	-2.284
2) JSWEL	27.554	27.554	Total	211.320	211.320
3) VIPL	0.000	0.000	a) Mumbai Schedule	44.184	44.184
4) RPL(AMT)	25.683	25.683	b) Mumbai Drawl	44.464	44.464
5) SWPGPL	11.842	11.842	c) MSEDCL Bilateral *	99.107	99.107
6) Other IPP	15.984	15.984	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	44.184	44.184
C) 1) TPCL Thermal	14.697	14.697	Include PX	0.000	0.000
2) TPCL Hydro	5.449	5.449	Standby	0.000	0.000
3) TPCL Gas	4.128	4.128	H) ENERGY CATERED (MUs)		
4) AEML Thermal	11.470	11.470	1) MSEDCL	540.732	540.732
D) STATE			2) Mumbai Discoms	80.208	80.208
1) Thermal	344.387	344.387	3) Other Discoms	11.185	11.185
(A1+C1+C4+(B1-B6))			TOTAL STATE	632.125	632.125
2) Hydro	21.360	21.360			
(A2+C2)					
3) Gas	11.216	11.216			
(A3+B7+C3)					
4) Wind	26.733	26.733			
6) SOLAR	17.109	17.109			
TOTAL STATE	420.805	420.805			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 8 Hrs
MSPGCL Thermal	6578	7165	7138	6690
MSPGCL Hydro	175	607	1008	184
MSPGCL Gas	279	279	283	286
MSPGCL Total Generation	7032	8051	8429	7160
Central Sector Receipt	9751	9956	8969	8537
WIND	500	608	1482	963
CPP / IPP Thermal	5282	6549	6612	6067
CPP / IPP Gas	0	0	0	0
SOLAR	2330	1333	0	595
Exchange with Mumbai	-2117	-2149	-1918	-1677
MSEDCL DEMAND MET	22284	23855	23084	21194
Load Shedding	0	0	0	0
MSEDCL DEMAND	22284	23855	23084	21194
TPCL GENERATION	1050	1238	1014	697
AEML GENERATION	504	503	438	374
MUMBAI DEMAND	3671	3890	3370	2748
OTHER DISCOM DEMAND	494	492	491	451
STATE DEMAND MET	26449	28238	26945	24393
STATE DEMAND	26449	28238	26945	24393
Frequency (Hz)	49.95	50.07	49.99	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 08.59 Hrs	49.78 Hz at 13.43 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Jun/2024

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.90	3.90	192	0
Unit 8	14.07	14.07	610	538
Unit 9	0.00	0.00	0	0
Unit 10	13.58	13.58	600	523
Total	31.54	31.54		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	10.98	10.98	480	410
Unit 5	10.72	10.72	475	420
Total	21.71	21.71		
Parli				
Unit 6	5.05	5.05	249	140
Unit 7	5.03	5.03	248	144
Unit 8	4.59	4.59	238	145
Total	14.67	14.67		
Chandrapur				
Unit 3	3.76	3.76	165	140
Unit 4	3.83	3.83	169	134
Unit 5	9.50	9.50	425	295
Unit 6	9.20	9.20	417	320
Unit 7	9.34	9.34	409	335
Unit 8	10.67	10.67	450	431
Unit 9	11.45	11.45	500	444
Total	57.74	57.74		
Paras				
Unit 3	5.21	5.21	232	200
Unit 4	0.58	0.58	250	0
Total	5.78	5.78		
Khaparkheda				
Unit 1	3.72	3.72	165	135
Unit 2	4.15	4.15	201	135
Unit 3	3.66	3.66	162	145
Unit 4	4.15	4.15	184	159
Unit 5	11.31	11.31	500	450
Total	26.99	26.99		
Nasik				
Unit 3	2.87	2.87	165	0
Unit 4	3.32	3.32	145	125
Unit 5	3.52	3.52	163	116
Total	9.70	9.70		
Uran				
All Units	7.09	7.09	376	276
Total	7.09	7.09		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	4.76	4.76	525	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	6.29	6.29	1000	0
Stage 3	2.53	2.53	320	0
Total	13.58	13.58		
Hydro				
KDPH	0.50	0.50	21	21
VTRNA	0.41	0.41	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.00	0.00	0	0
SMLHY_PTN	1.42	1.42	61	58
GHATGHAR	0.00	0.00	0	0
Total	2.33	2.33		
Wind				
Total	26.73	26.73	0	0
Total	26.73	26.73		
CPP				
APML(Mus)	69.02	69.02	0	0
JSWEL(Mus)	27.55	27.55	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.68	25.68	0	0
SWPGPL-Mus	11.84	11.84	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.08	6.08	269	236
Other(Mus)	5.45	5.45	0	0
JPL	4.46	4.46	269	129
Total	150.08	150.08		
SOLAR				
Total	17.11	17.11	0	0
Total	17.11	17.11		
Tata				
Trombay 5	9.66	9.66	469	267
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.59	2.59	108	108
Trombay 7B	1.54	1.54	64	64
TATA Hydro	5.45	5.45	407	35
Trombay 8	5.04	5.04	229	131
Total	24.27	24.27		
AEML				
DTPS U-1&2	11.47	11.47	504	374
Total	11.47	11.47		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	168.14	168.14	MSPGCL Total	191.14	191.14
			MSPGCL Thml+Gas	175.23	175.23	Koyna 1,2 & 4 Total	11.05	11.05
			MSPGCL Hydro	15.91	15.91	State Total	420.80	420.80

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Jun/2024

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	7408	1917	376	9701	1696	6809	0	0	7441	7334	-1824	23265	0	0	23265	3523	451	27239	50.00
2	7448	1739	367	9554	1569	6825	0	0	7337	6900	-1653	22776	0	0	22776	3293	418	26488	49.99
3	7116	1265	288	8669	1583	6815	0	0	7960	7545	-1548	22657	0	0	22657	3096	407	26160	49.94
4	7024	423	289	7736	1447	6751	0	0	8393	8155	-1449	22257	0	0	22257	2961	382	25601	49.99
5	7035	375	290	7700	1389	6629	0	0	8352	8265	-1446	22128	0	0	22128	2866	410	25403	49.95
6	7028	667	290	7985	1205	6676	0	1	8494	8405	-1447	22403	0	0	22403	2828	422	25653	49.97
7	7158	336	287	7781	1111	6632	0	154	8551	7903	-1335	21801	0	0	21801	2749	445	24995	50.01
8	6690	184	286	7160	963	6067	0	595	8551	8537	-1677	21194	0	0	21194	2748	451	24393	49.98
9	6649	190	286	7125	900	5144	0	1214	8917	9161	-1889	21177	0	1	21177	2960	479	24615	50.02
10	6871	150	281	7302	849	5261	0	1752	9024	8901	-2061	21516	0	8	21516	3240	488	25244	50.02
11	6805	120	282	7207	678	5073	0	2183	9770	9591	-2031	22203	0	10	22203	3525	497	26226	49.97
12	6578	175	279	7032	500	5282	0	2330	10009	9751	-2117	22284	0	54	22284	3671	494	26449	49.95
13	6698	126	279	7103	591	5418	0	2302	9955	9713	-2091	22548	0	48	22548	3702	488	26738	49.95
14	6582	146	280	7008	468	5391	0	2134	10029	9881	-2060	22348	0	6	22348	3670	474	26492	49.97
15	7020	275	276	7571	522	6090	0	1753	9964	10044	-2135	23373	0	5	23373	3804	472	27649	49.99
16	7165	607	279	8051	608	6549	0	1333	10122	9956	-2149	23855	0	69	23855	3890	492	28238	50.07
17	7133	323	280	7736	814	6555	0	882	10491	10109	-2132	23460	0	89	23460	3759	504	27723	49.99
18	7151	185	282	7618	1143	6551	0	415	10297	9577	-2035	22774	0	16	22774	3576	495	26845	50.01
19	6909	328	282	7519	1380	6113	0	61	9831	9375	-1970	21986	0	0	21986	3378	491	25856	50.00
20	7138	1008	283	8429	1482	6612	0	0	9200	8969	-1918	23084	0	0	23084	3370	491	26945	49.99
21	7145	1051	286	8482	1502	6711	0	0	8885	8605	-2003	22814	0	0	22814	3359	484	26656	49.90
22	7149	822	285	8256	1519	6697	0	0	8653	8475	-2033	22431	0	0	22431	3352	483	26266	50.02
23	7142	1774	299	9215	1452	6700	0	0	7767	7863	-1718	23020	0	0	23020	3405	492	26917	50.00
24	7099	1725	376	9200	1362	6730	0	0	8472	8305	-1743	23377	0	0	23377	3483	476	27337	49.95
MUs	168.14	15.91	7.09	191.14	26.73	150.08	0.00	17.11	216.46	211.32	-44.46	540.73	0.00	0.31	540.73	80.21	11.19	632.13	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

1) 132 KV BBLR TO Rahuri line over Load Alarm 488 AMP/102.10 MW.2)Due to higher loading DLS carried out at palghar district.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 01/Jun/2024

Position as on 6.30 Hrs of 02/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE								
MSPGCL								
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/08/2024
MSPGCL	Ghatghar Unit-2	125	26/05/2024	13:17		Continued.	Stator Earth Fault	26/07/2024
MSPGCL	Koradi Unit 9	660	28/05/2024	22:12	02/06/2024	14:25	Boiler Tube Leakage	02/06/2024
MSPGCL	Bhusawal Unit 3	210	29/05/2024	02:31	02/06/2024	06:24	Boiler Tube Leakage	02/06/2024
MSPGCL	Nasik Unit 3	210	01/06/2024	02:15	01/06/2024	05:30	Low furnace pressure	
MSPGCL	Paras Unit 4	250	01/06/2024	02:27		Continued.	Drum level low	04/06/2024
MSPGCL	Koradi Unit 6	210	01/06/2024	11:00	01/06/2024	13:20	Generator master trip relay malfunction	
MSPGCL	Khaparkheda Unit 3	210	02/06/2024	03:05		Continued.	Boiler Tube Leakage	04/06/2024
MSPGCL	Paras Unit 3	250	02/06/2024	06:16		Continued.	Valve malfunction operate.	
MSPGCL	Bhusawal Unit 3	210	02/06/2024	06:37	02/06/2024	06:56	Low Vaccum	02/06/2024
MSPGCL	Chandrapur Unit 9	500	02/06/2024	22:52		Continued.	Condenser Vacuum low	03/06/2024
Total Capacity MSPGCL		2955						
IPP								
IPP	RPL(AMT) U-4	270	28/05/2024	18:57		Continued.	Due to ID Fan tripped on high vibration..	28/06/2024
IPP	SWPGPL U-3	135	01/06/2024	11:51	01/06/2024	13:20	Turbine feedwater Pump failure.	
Total Capacity IPP		405						
CENT.SECTOR								
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/08/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	30/09/2024
Total Capacity CENT.SECTOR		320						
Total Capacity FORCED OUTAGE		3680						
UNIT UNDER ZERO SCHEDULE / RSD								
MSPGCL								
MSPGCL	Uran Unit 5	108	19/05/2024	02:00		Continued.	As per MSEDCL zero schedule.	
MSPGCL	Uran Unit 6	108	01/06/2024	02:00	01/06/2024	22:42	Due to Zero Schedule given by MSEDCL.	
MSPGCL	Uran Unit 6	108	02/06/2024	02:00		Continued.	Due to Zero Schedule given by MSEDCL.	
Total Capacity MSPGCL		324						
Total Capacity UNIT UNDER ZERO SCHEDULE / RSD		324						

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Jun/2024

Position as on 6.30 Hrs of 02/Jun/2024

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
FORCED OUTAGE DUE TO NO PPA								
IPP								
IPP	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
Total Capacity IPP		988						
Total Capacity FORCED OUTAGE DUE TO NO PPA		988						

* Other generator generating power instead of contracted genertaor with tri-party agreement in between generatos & discom (Case-IV bidding)

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV LINE Outages/Trippings							
AKOLA II - EKTUNI CKT - 2	IntraState	26/05/2024	18:11			T	Tripped on distance protection.(Due to tower
400 KV LINE Outages/Trippings							
AURANGABAD(MS) - AURANGABAD(PG) CKT -2	InterState	01/06/2024	18:17	01/06/2024	22:08	EO	Attending Hotspot by PGCIL
BUS REACTOR (50MVAR) @ PARLI	IntraState	27/09/2023	15:30			PO	Replacement of old 50 MVAR bus reactor by new 125 MVAR bus reactor.
CHANDRAPUR 2 - WARORA CKT-1	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
CHANDRAPUR 2 - WARORA CKT-2	IntraState	22/04/2024	17:27			T	Tripped on distance protection.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	14/05/2024	12:30			HT	HT for load Management
220 KV PARLI (400 KV)- GIRWALI I/C -2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
220 KV KHADKA (400 KV)- CHALISGAON CKT -1	IntraState	01/06/2024	08:13	01/06/2024	16:50	PO	Work of restringing of conductor between Loc no.299 to 313
BABLESHWAR- AURANGABAD (WALUJ)	IntraState	01/06/2024	11:49	01/06/2024	13:40	T	Line tripped on distance protection.
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220KV 500 MVA ICT - 3 @ VIKHROLI GIS	IntraState	10/02/2024	17:40			HT	H/T For LV only.
400/220/33 KV 500MVA ICT - 2 @ WARORA	IntraState	20/05/2024	11:25			PO	RELAY TESTING WORK AND ALLIED WORK
400/220KV 500 MVA ICT - 2 @ VIKHROLI GIS	IntraState	22/05/2024	17:41			HT	HT for Load management
400/220KV 500 MVA ICT - 1 @ VIKHROLI GIS	IntraState	01/06/2024	00:26	01/06/2024	06:25	HT	HT for Load Management
400/220/33 KV 501MVA ICT - 4 @ BABHALESHWAR	IntraState	01/06/2024	11:15	01/06/2024	20:55	PO	For obtaining sufficient clearance so as to carry out connection of jumper of 501 MVA ICT V to 400 KV Main Bus II by Hot Line method
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	01/06/2024	18:02	01/06/2024	20:20	PO	Premansoon activity and bay maintenance work
400/220/33KV 315MVA ICT - 2 @ LONIKAND	IntraState	01/06/2024	20:38	01/06/2024	22:30	PO	Premansoon activity and bay maintenance work
400/220 KV 3X200 MVA ICT - 2 @ KALWA	IntraState	02/06/2024	07:15	02/06/2024	10:20	PO	Pre-monsoon maintenance activity
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION BAY @ PEDAMBE	IntraState	03/04/2024	15:55			T	Tripped due to Y ph CT burst
220 KV LINE Outages/Trippings							
HINJEWADI 2 - HINJEWADI 3 CKT - 1	IntraState	24/05/2024	12:34			PO	Attending SF6 Gas Leakage at G-9 Chamber of 'B' phase of 220kV Hinjawadi2 Line 1 bay
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	25/05/2024	13:25	01/06/2024	22:40	HT	For load management
132 kv GHATODI ARNI	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104) .
132 KV GHATODI (220 KV) - DIGRAS CKT	IntraState	26/05/2024	15:36			T	6 Nos. Tower collapsed (Loc no 99-104).
PARLI (OLD GCR) - PARLI (PG) CKT 2	IntraState	26/05/2024	15:40			T	6 Nos. Tower collapsed (Loc no 36- 41) .
LAMBOTI - KARKAMB	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
LAMBOTI - PANDHARPUR	IntraState	26/05/2024	17:25			T	TOWER COLLAPSED AT LOC.414-419.
GORAI -MSETCL BORIVALI CKT -1	IntraState	28/05/2024	17:59			T	Bus fault
GORAI -MSETCL BORIVALI CKT -2	IntraState	28/05/2024	17:59	02/06/2024	20:00	T	Bus fault
MAIN BUS - 1 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220KV GIS DCHI - COLOURCHEM	IntraState	31/05/2024	04:30			PO	For de-stringing & stringing of old circuit at new tower Loc. No. 6.
GADCHANDUR - VIRUR-I	IntraState	01/06/2024	05:12	01/06/2024	15:15	PO	Diagnostic testing work
PALGHAR - NALASOPARA	IntraState	01/06/2024	06:25	01/06/2024	09:09	PO	Replacement of Insulator String Identified in PID.
NERLE - PEDAMBE	IntraState	01/06/2024	07:13	01/06/2024	11:15	PO	220 KV Nerale Bay for Bay P/M work.
VSNL- KHADKI	IntraState	01/06/2024	07:13	01/06/2024	17:41	PO	For Stringing of R,Y,B phase conductors between New Monopole Loc No. 29A to 30 (River Crossing)
WAGHIVALI - DHARAVI 8	IntraState	01/06/2024	07:30	01/06/2024	10:15	PO	Project work- For dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	IntraState	01/06/2024	07:40	01/06/2024	10:19	PO	For dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.
BUTIBORI-INOX	IntraState	01/06/2024	09:13	01/06/2024	00:04	PO	SF6 BREAKER MAINTENANCE & N2 SYSTEM INSTALLATION AT M/S. INOX (220KV INOX S/S.)
ISMT TAP LINE TO JEJURI-BARAMATI	IntraState	01/06/2024	11:01	01/06/2024	15:12	PO	Replacement of B-ph LA of Jejuri-ISMT-Baramati line at 220 kV Baramati S/S.
MHAISAL - ALKUD	IntraState	01/06/2024	17:48	02/06/2024	02:24	PO	Wedge connector work
BUTIBORI 3-PURTI	IntraState	01/06/2024	19:28	02/06/2024	02:57	T	Distance protection
KALWA - SIEMENS	IntraState	01/06/2024	22:26	02/06/2024	06:33	PO	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48 (Total 18 sets out of 18 sets are to be installed)
KHARGHAR - BORIVALI CKT - 2	IntraState	01/06/2024	22:27	02/06/2024	06:39	PO	For the installation of saver assembly sets at TL no. 43, 45, 46, 47 & 48, 27/3 & 28 (Total 24 sets out of 66 sets are to be installed, total completed - 6 sets
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	01/06/2024	22:53	02/06/2024	03:44	PO	Replacement of old disc insulator with porcelain long rod insulator strings,
KAMBA - VASAI	IntraState	02/06/2024	04:39		Continued.		1) Cut point formation over newly erected monopole & work will be carried out at loc no 4 9 and also related de-stringing & stringing work will be carried out. 2) Dismantling of old existing tower no. 53 & 54. 3) After cut point formation & conductor stringing work kamba-Vasai line will be charged at 22:00 Hrs of 02.06.2024.
KAMBA - VASAI	IntraState	02/06/2024	04:39		Continued.		Work of replacement of old C&R panel by new and diagnostic testing work

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
KAMBA - VASAI	IntraState	02/06/2024	04:39		Continued.	PO	work 1) Cut point formation over newly erected Monopole work will be carry out at loc.no.48,49 and amp;49A on 220kV Kamba-Vasai line and also related tower 65533;s conductor destringing & stringing work will be carry out of above said ckt. 2) Dismantling work of old existing tower at Loc.No.48 &49
WAGHIVALI - DHARAVI 8	IntraState	02/06/2024	05:59	02/06/2024	15:57	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site
WAGHIVALI - DHARAVI 7 - ANTOP HILL - 1	IntraState	02/06/2024	06:03	02/06/2024	16:00	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site
GADCHANDUR - VIRUR-I	IntraState	02/06/2024	09:54	02/06/2024	11:13	EO	Attending Hotspot work R-ph CT clamp
BHUGAON - WARDHA (PG)	IntraState	02/06/2024	23:10		Continued.	HT	H/T due to State OD at Low frequency.
220 KV ICT Outages/Trippings							
220/33kV 125 MVA TF 2 @ GORAI	IntraState	28/05/2024	17:59			T	Bus Fault
220/100 KV 200 MVA ICT 3 @ TROMBAY	IntraState	01/06/2024	06:34	01/06/2024	10:55	PO	For 1) Premonsoon maintenance work & 2) RM work.
220/132 KV 200 MVA ICT 2 @ RAYMOND	IntraState	01/06/2024	07:15	01/06/2024	08:02	PO	Premonsoon Maintenance
220/132 KV 200 MVA ICT 1 @ RAYMOND	IntraState	01/06/2024	08:30	01/06/2024	11:31	PO	1. Replacement of 132kV LA 2. Premonsoon maintenance 3. Complete bay maintenance work
220/33 KV 25 MVA PTR 1 @ AHMEDNAGAR	IntraState	01/06/2024	09:55	01/06/2024	14:17	PO	Premonsoon maintenance and attending oil leakage
220/33 KV 25 MVA PTR 2 @ AHMEDNAGAR	IntraState	01/06/2024	15:30	01/06/2024	18:38	PO	Premonsoon maintenance and attending oil leakage
220 / 110 / 33kV 250MVA AT 1 @ BACKBAY	IntraState	02/06/2024	10:14	02/06/2024	17:45	PO	33KV side cable termination replacement work
220/33KV 50MVA T/F-I @ BRIDGESTONE	IntraState	02/06/2024	10:35	02/06/2024	14:10	PO	Diagnostic testing work, half Yearly and pre monsoon maintenance .
220/33 KV 50 MVA PTR NO 3 @ ALEPHATA	IntraState	02/06/2024	12:14	02/06/2024	15:27	PO	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance
220/33 KV, 50MVA, PTR NO 2 @ ALEPHATA	IntraState	02/06/2024	15:34	02/06/2024	17:17	PO	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance
220/33 KV 50MVA PTR NO 1 @ ALEPHATA	IntraState	02/06/2024	17:21	02/06/2024	19:49	PO	For wrapping of plastic cover (Pre monsoon maintenance) & general bay maintenance
220 KV BUSBAR Outages/Trippings							
MAIN BUS-1 @ HINJEWADI 3(GIS)	IntraState	01/06/2024	11:43	01/06/2024	11:15	PO	Bus Extension for Bay 208 of 220kV Nextra2 Ss for project work
132 KV LINE Outages/Trippings							
132KV RENAPUR- TWENTY ONE SUGAR AT LATUR	IntraState	26/05/2024	16:19			T	TOWER COLLAPSED AT LOC.11.
110 KV LINE Outages/Trippings							
WAGHIVALI - MANKHURD	IntraState	01/06/2024	07:50	01/06/2024	10:29	PO	Project Work - for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jun/2024

Statement-VII

Position as on 6.30 Hrs of 02/Jun/2024

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
WAGHIVALI - CHEMBUR	IntraState	01/06/2024	08:13	01/06/2024	10:53	PO	Project work - For dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site.
WAGHIVALI - CHEMBUR	IntraState	02/06/2024	05:44	02/06/2024	16:19	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site
WAGHIVALI - MANKHURD	IntraState	02/06/2024	05:50	02/06/2024	16:29	PO	for dismantling of MSETCL Towers along with destringing of conductors at NMIA Airport project site

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage