

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Jul/2022 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	130.786	130.786	1) Gujrat	-6.541	-6.541
2) Hydro	9.359	9.359	2) Madhya Pradesh	7.954	7.954
3) Gas	6.461	6.461	3) Chattisgarh	3.640	3.640
Total MSPGCL	146.606	146.606	4) Maharashtra	157.438	157.438
B) 1) APML	49.414	49.414	5) Goa (Amona)	-1.079	-1.079
2) JSWEL	14.376	14.376	Total	161.412	161.412
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.754	33.754
4) RPL(AMT)	18.067	18.067	b) Mumbai Drawl	36.652	36.652
5) SWPGPL	6.251	6.251			
6) Other IPP	8.147	8.147	c) MSEDCL Bilateral *	81.664	81.664
7) PGPL	0.000	0.000	Include PX	0.000	0.000
C) 1) TPCL Thermal	10.537	10.537	d) Mumbai Bilateral *	33.754	33.754
2) TPCL Hydro	1.684	1.684	Include PX	0.000	0.000
3) TPCL Gas	0.407	0.407	Standby	0.000	0.000
4) AEML Thermal	9.496	9.496			
D) STATE			H) ENERGY CATERED (MUs)		
1) Thermal (A1+C1+C4+(B1-B6))	247.074	247.074	1) MSEDCL	408.689	408.689
2) Hydro (A2+C2)	11.043	11.043	2) Mumbai Discoms	58.775	58.775
3) Gas (A3+B7+C3)	6.868	6.868	3) Other Discoms	9.106	9.106
4) Wind	41.113	41.113			
6) SOLAR	9.061	9.061	TOTAL STATE	476.570	476.570
TOTAL STATE	315.159	315.159			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5572	5439	5422	5633
MSPGCL Hydro	430	283	685	244
MSPGCL Gas	272	269	262	264
MSPGCL Total Generation	6274	5991	6369	6141
Central Sector Receipt	7511	7338	6398	5810
WIND	1291	1399	2505	1299
CPP / IPP Thermal	4014	3720	4328	4049
CPP / IPP Gas	0	0	0	0
SOLAR	1063	1297	0	0
Exchange with Mumbai	-1933	-1928	-1673	-992
MSEDCL DEMAND MET	17799	17418	17502	15994
Load Shedding	0	0	0	0
MSEDCL DEMAND	17799	17418	17502	15994
TPCL GENERATION	626	621	605	520
AEML GENERATION	437	467	345	376
MUMBAI DEMAND	2996	3016	2623	1888
OTHER DISCOM DEMAND	421	399	425	313
STATE DEMAND MET	21216	20833	20550	18195
STATE DEMAND	21216	20833	20550	18195
Frequency (Hz)	50.04	50.03	50.01	49.97

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 13.02 Hrs	49.71 Hz at 08.56 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Jul/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	12.45	12.45	547	507
Unit 9	0.00	0.00	0	0
Unit 10	11.64	11.64	535	450
Total	24.08	24.08		
Bhusawal				
Unit 3	3.36	3.36	155	120
Unit 4	9.57	9.57	445	285
Unit 5	0.00	0.00	0	0
Total	12.92	12.92		
Parli				
Unit 6	5.08	5.08	246	149
Unit 7	4.85	4.85	231	137
Unit 8	0.00	0.00	0	0
Total	9.93	9.93		
Chandrapur				
Unit 3	1.91	1.91	125	0
Unit 4	3.04	3.04	134	110
Unit 5	7.64	7.64	339	280
Unit 6	7.96	7.96	355	305
Unit 7	0.00	0.00	0	0
Unit 8	10.85	10.85	482	395
Unit 9	10.73	10.73	455	440
Total	42.14	42.14		
Paras				
Unit 3	4.66	4.66	222	142
Unit 4	4.60	4.60	211	142
Total	9.27	9.27		
Khaparkheda				
Unit 1	3.41	3.41	145	135
Unit 2	3.58	3.58	155	130
Unit 3	4.20	4.20	186	152
Unit 4	0.00	0.00	0	0
Unit 5	11.02	11.02	475	400
Total	22.21	22.21		
Nasik				
Unit 3	3.77	3.77	175	117
Unit 4	3.31	3.31	155	121
Unit 5	3.16	3.16	157	103
Total	10.24	10.24		
Uran				
All Units	6.46	6.46	284	261
Total	6.46	6.46		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.68	2.68	370	35
Stage 4	0.43	0.43	200	0
Stage 3	0.73	0.73	80	0
Total	3.84	3.84		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.69	0.69	60	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.10	0.10	57	0
SMLHY_PTN	4.73	4.73	208	173
GHATGHAR	0.00	0.00	0	0
Total	5.52	5.52		
Wind				
Total	41.11	41.11	0	0
Total	41.11	41.11		
CPP				
APML(Mus)	49.41	49.41	0	0
JSWEL(Mus)	14.38	14.38	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.07	18.07	0	0
SWPGPL-Mus	6.25	6.25	0	0
Other(Mus)	8.15	8.15	0	0
Total	96.26	96.26		
SOLAR				
Total	9.06	9.06	0	0
Total	9.06	9.06		
Tata				
Trombay 5	6.75	6.75	368	258
Trombay 6	0.00	0.00	0	0
Trombay 7A	0.23	0.23	44	0
Trombay 7B	0.18	0.18	38	0
TATA Hydro	1.68	1.68	190	0
Trombay 8	3.79	3.79	222	132
Total	12.63	12.63		
AEML				
DTPS U-1&2	9.50	9.50	468	295
Total	9.50	9.50		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	130.79	130.79	MSPGCL Total	146.61	146.61
			MSPGCL Thml+Gas	137.25	137.25	Koyna 1,2 & 4 Total	3.11	3.11
			MSPGCL Hydro	9.36	9.36	State Total	315.16	315.16

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 01/Jul/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5580	252	264	6096	1351	4466	0	0	5785	6008	-1093	16490	0	16490	2112	338	18940	49.98
2	5607	248	274	6129	1341	4328	0	0	5968	5791	-1087	16167	0	16167	1986	335	18488	49.99
3	5633	244	264	6141	1299	4049	0	0	5902	5810	-992	15994	0	15994	1888	313	18195	49.97
4	5633	247	273	6153	1291	4028	0	0	5855	5976	-951	16208	0	16208	1825	289	18322	50.02
5	5635	247	264	6146	1271	4348	0	0	5884	6079	-958	16567	0	16567	1820	319	18706	49.94
6	5618	511	277	6406	1147	4632	0	1	6544	6761	-1136	17461	0	17461	1927	350	19738	49.91
7	5644	753	262	6659	1051	4513	0	85	7471	7431	-1248	18120	0	18120	2055	371	20546	49.94
8	5631	324	272	6227	1116	4056	0	399	8181	7875	-1441	17838	0	17838	2211	394	20443	50.00
9	5655	351	282	6288	1180	3871	0	644	7669	7663	-1678	17563	0	17563	2484	405	20452	49.91
10	5572	862	274	6708	1383	3864	0	873	7304	7233	-1801	17853	0	17853	2775	407	21035	49.92
11	5572	430	272	6274	1291	4014	0	1063	7523	7511	-1933	17799	0	17799	2996	421	21216	50.04
12	5584	339	261	6184	1380	3860	0	1123	7654	7563	-2007	17692	0	17692	3069	411	21172	50.06
13	5439	283	269	5991	1399	3720	0	1297	7779	7338	-1928	17418	0	17418	3016	399	20833	50.03
14	5165	285	263	5713	1897	3452	0	1218	7231	7005	-1790	17107	0	17107	2843	388	20338	50.02
15	5078	286	272	5636	2383	3454	0	945	7286	7205	-1928	17313	0	17313	2812	382	20507	50.00
16	5076	268	261	5605	2789	3143	0	649	7085	6760	-1943	16615	0	16615	2769	388	19772	50.05
17	5033	270	272	5575	2526	3081	0	471	6655	7148	-1952	16450	0	16450	2727	399	19576	50.09
18	5088	409	262	5759	2706	3194	0	239	6553	6722	-1891	16329	0	16329	2694	400	19423	50.00
19	5278	330	272	5880	2787	3548	0	54	6550	6723	-1742	16838	0	16838	2687	412	19937	50.03
20	5422	685	262	6369	2505	4328	0	0	6450	6398	-1673	17502	0	17502	2623	425	20550	50.01
21	5455	479	272	6206	2064	4595	0	0	6301	6443	-1545	17364	0	17364	2536	399	20299	50.01
22	5447	322	261	6030	1924	4584	0	0	5946	6085	-1402	16818	0	16818	2417	403	19638	49.96
23	5477	614	272	6363	1562	4597	0	0	5750	6000	-1285	16846	0	16846	2306	391	19543	49.91
24	5464	320	284	6068	1470	4530	0	0	6107	5884	-1248	16336	0	16336	2198	368	18902	49.99
MUs	130.79	9.36	6.46	146.61	41.11	96.26	0.00	9.06	161.43	161.41	-36.65	408.69	0.00	408.69	58.78	9.11	476.57	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Jul/2022

Position as on 6.30 Hrs of 02/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Khaparkheda Unit 4	210	05/06/2022	00:07		Continued.	Annual Overhaul	20/07/2022
MSPGCL	Koyna STG-IV Unit-2	250	13/06/2022	00:00		Continued.	Commissioning and installation of New TSLG governor	04/07/2022
IPP	RPL(AMT) U-5	270	15/06/2022	00:00		Continued.	Annual Overhaul	25/07/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Parli Unit 8	250	25/06/2022	00:00		Continued.	Short overhauling	10/07/2022
IPP	Adani U-2	660	25/06/2022	04:18		Continued.	Stator Earth Fault (Converted into AOH from 00:00Hrs dt.01/07/2022.	22/07/2022
MSPGCL	Koyna Unit 5	80	01/07/2022	08:15	01/07/2022	17:30	Governing Card Replacement	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	15/07/2022
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/09/2022
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Turbine Gland steam temperature not maintained	18/07/2022
MSPGCL	Ghatghar Unit-2	125	18/06/2022	10:00		Continued.	for Hydraulic Intake Gate Work	07/07/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
MSPGCL	Koradi Unit 9	660	27/06/2022	13:45		Continued.	Air Filter Problem	04/07/2022
MSPGCL	Bhusawal Unit 5	500	29/06/2022	12:09	02/07/2022	03:36	CLINKER FORMATION	01/07/2022
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	05/07/2022
MSPGCL	Koradi Unit 6	210	30/06/2022	21:35	02/07/2022	17:13	Boiler Tube Leakage	02/07/2022
IPP	SWPGPL U-4	135	30/06/2022	23:23		Continued.	Vibration High in feed pump.	03/07/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Jul/2022

Position as on 6.30 Hrs of 02/Jul/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
IPP	SWPGPL U-1	135	01/07/2022	00:07	01/07/2022	19:54	Turbine Vibration	
TPC-G	Trombay 7B	60	01/07/2022	04:53		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	01/07/2022	05:14		Continued.	Gas shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vabration high	10/07/2022
MSPGCL	Chandrapur Unit 3	210	01/07/2022	15:23	01/07/2022	23:43	Furnace Pressure High	
IPP	SWPGPL U-1	135	02/07/2022	07:09	02/07/2022	10:25	Master fuel trip	
MSPGCL	Uran Unit 5	108	02/07/2022	13:18		Continued.	Gas shortage	
MSPGCL	Nasik Unit 5	210	02/07/2022	21:55		Continued.	Economizer Tube Leakage.	03/07/2022

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 02/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 409 OF GT - 5 @KHAPARKHEDA S/s	IntraState	02/07/2022	10:45	02/07/2022	20:15	PO	2. Bus isolator 89A IPS tube replacement/ interchanging work of 125MVAr Reactor
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV MAIN BUS - 2 @ 400 KV KHAPARKHEDA 2	InterState	02/07/2022	11:01	02/07/2022	20:08	PO	2. Bus isolator 89A IPS tube replacement/ interchanging work of 125MVAr Reactor
MAIN BAY (431) OF 167 MVA SPARE ICT @ KORADI II	IntraState	16/06/2022	11:23			PO	1) Premonsoon maintenance work& 2) Routine Bay Maintenance.
400 KV LINE Outages/Trippings							
WARORA - WARDHA (PG)	InterState	20/06/2022	10:10			PO	1. Tower Erection of loc. No. 01 under 400 kv Wardha-Warora line. 2. Connecting 400kv Warora (MSETCL) to 400kv Warora (PGCIL)
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	30/06/2022	07:24			HT	H/T FOR CONTROLLING LINE LOADING
CHANDRAPUR-PARLI CKT-3	IntraState	30/06/2022	11:05	01/07/2022	16:10	EO	To attend the hot spot having temperature of more than 119 Degree Celsius on 4-way clamps of Hanger Rod assembly of Y-ph Main Bus-2 Isolator by hot line tehcnique.
KORADI-NANDGAONPETH (RPL)	IntraState	01/07/2022	09:57	01/07/2022	19:58	PO	Shifting of 400kv Koradi-Nandgaonpeth(RPL) Ckt on TBC for attending 29B isolator gear problem and alignment.
JAIGAD - KARAD CKT - 1	IntraState	02/07/2022	00:10	02/07/2022	06:36	HT	H/T TO CONTROL O/V
LONIKAND I -JEJURI	IntraState	02/07/2022	09:05	02/07/2022	17:54	EO	Attending hot spot on 29B isolator(Y ph) temp. -160 deg. C) & replacement of faulty Aux switch (CB).
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	01/07/2022	14:43	01/07/2022	19:58	EO	Replacement of faulty Neutral Displacement relay.
400/220 KV 3X105 MVA ICT - 1 @ KHARGHAR	IntraState	02/07/2022	05:08	02/07/2022	15:27	PO	For MTAMC work, Buchholz along with GCD replacement work and RM Work
220 KV LINE Outages/Trippings							
EKLAHARA(GCR)(NASIK)-BABLESHWAR 2	IntraState	27/04/2022	12:21			EO	Shifting of 220kv GCR-BBLR-2 line on 220kv TBC bay.
RANJANGAON-FIAT 1	IntraState	01/07/2022	09:30	01/07/2022	14:15	PO	For Isolator Box Replacement & Isolator Alignment work.
EKLAHARA(OCR)-RAYMOND	IntraState	01/07/2022	09:56	01/07/2022	16:15	PO	1. Attending Red hot spot of B ph wave trap bottom side 2. Replacement of pilot string of R ph and B ph.
OSMANABAD - PARLY (PG)	IntraState	01/07/2022	10:06	01/07/2022	19:51	PO	AMP work line terminal equipment
ANANDNAGAR - PALAVA	IntraState	01/07/2022	10:12	01/07/2022	17:00	PO	Work of replacement of old conductor between loc no 134A-134-133
PAL DOMBIVALI - PALAVA	IntraState	01/07/2022	10:19	01/07/2022	17:03	PO	Work of replacement of old conductor between loc no 134A-134-133

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 02/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
RANJANGAON-FIAT 2	IntraState	01/07/2022	14:30	01/07/2022	21:12	PO	For Isolator Box Replacement & Isolator Alignment work.
BHIRA - KARANJADE 7	IntraState	02/07/2022	00:05	02/07/2022	03:18	PO	Closure inspection of Insulator at Bhira Generating station Gantry.
THEUR-JEJURI	IntraState	02/07/2022	04:35	02/07/2022	18:43	T	TRIPPED ON DIST.PROTECTION
NERLE - DASGAON	IntraState	02/07/2022	05:27	02/07/2022	06:33	T	TRIPPED ON DIST.PROTECTION
NEW KOYNA - LOTEPARSHURAM	IntraState	02/07/2022	09:30	02/07/2022	16:51	PO	For dismantling of old damaged tower at Loc. No. 56 of 220kV New Koyna - Lote & 220kV Pophali & Kandalgaon D/C Line.
KANDALGAON - KOYNA (POPHALI)	IntraState	02/07/2022	09:40	02/07/2022	16:42	PO	For dismantling of old damaged tower at Loc. No. 56 of 220kV New Koyna - Lote & 220kV Pophali & Kandalgaon D/C Line.
TROMBAY - MULUND	IntraState	02/07/2022	15:42	02/07/2022	19:31	EO	For attending hot spot on: 1. Yph top CB pad (85.6 deg.) 2. Bph top CB pad (82.5 deg.)
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ KANDALGAON	IntraState	14/12/2021	16:55			EO	For dismantling said 50MVA T/f 1 at 220 kV K'gaon S/s
220/100 KV 200 MVA ICT 3 @ KALWA	IntraState	28/06/2022	08:51			PO	220 KV Road side Auxiliary bus(C BUS) conductor replacement work.
220/22KV 50MVA PTR 1 @ NANDED CITY	IntraState	30/06/2022	22:58	01/07/2022	01:18	PO	Overhauling of OLTC
220/22KV 50MVA PTR 2 @ NANDED CITY	IntraState	01/07/2022	01:26	01/07/2022	03:51	PO	Overhauling of OLTC
220/100 KV 200 MVA ICT 2 @ PADGHE	IntraState	01/07/2022	08:45	01/07/2022	19:20	PO	100 Kv BUS Outage on partial portion of Bus section 3 . for strengthen/Twin arrangement of 100kv Pdg-Bhiwandi-2 Line & Bus Isolators servicing & alignment work.
220/33-22 KV 50 MVA PTR 2 @ NERUL	IntraState	01/07/2022	10:44	01/07/2022	11:55	PO	For OLTC trials for TAMS installation work.
220/132KV 200MVA ICT 1 @ KURKUMBH	IntraState	01/07/2022	11:05	01/07/2022	16:40	PO	REPLACEMENT OF HV R-PH LA
220/110KV 100MVA ICT 1 @ PANDHARPUR	IntraState	02/07/2022	09:01	02/07/2022	18:50	PO	Outage is required for Oil Leakage attending work
220/22 KV 50 MVA PTR NO 4 @ THEUR	IntraState	02/07/2022	09:57	02/07/2022	13:43	PO	220/22 kv 50 MVA TF 04 HV R PH Bushing replacement work due to high tan delta
220/22 KV 50 MVA PTR 1 @ KALWA	IntraState	02/07/2022	10:43	02/07/2022	18:16	EO	For replacing of Line Isolator Damage Palm.
220/132-110KV 200MVA ICT 2 @ MIRAJ	IntraState	02/07/2022	14:00	02/07/2022	16:40	PO	Washing of bay equipments by Hotline Unit
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jul/2022

Statement-VII

Position as on 6.30 Hrs of 02/Jul/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
BHIRA (T) - KHOPOLI 2	IntraState	01/07/2022	05:19	01/07/2022	13:37	PO	Inspection of Gantry insulators at Khopoli

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage