

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Jul/2023 SATURDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	141.584	141.584	1) Gujrat	-4.186	-4.186
2) Hydro	5.660	5.660	2) Madhya Pradesh	6.639	6.639
3) Gas	0.000	0.000	3) Chattisgarh	0.970	0.970
Total MSPGCL	147.244	147.244	4) Maharashtra	145.590	145.590
B) 1) APLM	59.251	59.251	5) Goa (Amona)	-1.165	-1.165
2) JSWEL	18.882	18.882	Total	147.848	147.848
3) VIPL	0.000	0.000	a) Mumbai Schedule	34.829	34.829
4) RPL(AMT)	24.866	24.866	b) Mumbai Drawl	38.231	38.231
5) SWPGPL	8.421	8.421	c) MSEDCL Bilateral *	93.374	93.374
6) Other IPP	6.798	6.798	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	34.743	34.743
C) 1) TPCL Thermal	6.642	6.642	Include PX	0.000	0.000
2) TPCL Hydro	3.940	3.940	Standby	0.087	0.087
3) TPCL Gas	2.957	2.957	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.295	8.295	1) MSEDCL	424.233	424.233
D) STATE			2) Mumbai Discoms	60.065	60.065
1) Thermal	274.739	274.739	3) Other Discoms	9.844	9.844
(A1+C1+C4+(B1-B6))			TOTAL STATE	494.142	494.142
2) Hydro	9.600	9.600			
(A2+C2)					
3) Gas	2.957	2.957			
(A3+B7+C3)					
4) Wind	46.929	46.929			
6) SOLAR	12.069	12.069			
TOTAL STATE	346.294	346.294			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	5743	5166	6341	6207
MSPGCL Hydro	194	172	742	148
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5938	5338	7083	6356
Central Sector Receipt	7529	7592	5977	4593
WIND	2146	2458	1932	1472
CPP / IPP Thermal	4235	4202	5574	5306
CPP / IPP Gas	0	0	0	0
SOLAR	1373	1420	0	0
Exchange with Mumbai	-2105	-2331	-1616	-1046
MSEDCL DEMAND MET	18666	18240	18510	16373
Load Shedding	0	0	0	0
MSEDCL DEMAND	18666	18240	18510	16373
TPCL GENERATION	518	330	719	557
AEML GENERATION	352	307	415	325
MUMBAI DEMAND	2975	2968	2750	1928
OTHER DISCOM DEMAND	450	440	440	308
STATE DEMAND MET	22091	21647	21700	18608
STATE DEMAND	22091	21647	21700	18608
Frequency (Hz)	50.00	50.00	49.92	50.00

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.23 Hz at 18:04 Hrs	49.75 Hz at 02:17 Hrs	49.99	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 01/Jul/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.82	3.82	175	130
Unit 8	12.20	12.20	557	380
Unit 9	11.42	11.42	538	372
Unit 10	11.81	11.81	535	376
Total	39.26	39.26		
Bhusawal				
Unit 3	3.20	3.20	150	120
Unit 4	10.08	10.08	490	280
Unit 5	9.60	9.60	485	280
Total	22.88	22.88		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	3.40	3.40	160	122
Unit 4	3.37	3.37	155	121
Unit 5	0.00	0.00	0	0
Unit 6	8.05	8.05	385	270
Unit 7	8.28	8.28	385	292
Unit 8	9.73	9.73	466	273
Unit 9	10.64	10.64	500	333
Total	43.47	43.47		
Paras				
Unit 3	4.08	4.08	193	148
Unit 4	4.44	4.44	211	146
Total	8.52	8.52		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	2.51	2.51	122	88
Unit 3	3.91	3.91	182	128
Unit 4	4.00	4.00	198	125
Unit 5	10.69	10.69	470	395
Total	21.11	21.11		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.29	3.29	158	117
Unit 5	3.05	3.05	149	113
Total	6.34	6.34		
Uran				
All Units	0.00	0.00	0	0
Total	0.00	0.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.00	0.00	0	0
Total	0.00	0.00		
Koyna				
Stage 1-2	1.46	1.46	360	40

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.00	0.00	0	0
Stage 3	0.70	0.70	160	0
Total	2.16	2.16		
Hydro				
KDPH	0.14	0.14	9	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.38	0.38	40	0
SMLHY_PTN	2.41	2.41	108	98
GHATGHAR	0.58	0.58	125	0
Total	3.50	3.50		
Wind				
Total	46.93	46.93	0	0
Total	46.93	46.93		
CPP				
APML(Mus)	59.25	59.25	0	0
JSWEL(Mus)	18.88	18.88	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.87	24.87	0	0
SWPGPL-Mus	8.42	8.42	0	0
Dhariwal	0.00	0.00	0	0
IEPL	5.14	5.14	270	175
Other(Mus)	1.66	1.66	0	0
Total	118.22	118.22		
SOLAR				
Total	12.07	12.07	0	0
Total	12.07	12.07		
Tata				
Trombay 5	3.11	3.11	273	0
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.75	1.75	108	38
Trombay 7B	1.20	1.20	65	36
TATA Hydro	3.94	3.94	438	26
Trombay 8	3.53	3.53	226	129
Total	13.54	13.54		
AEML				
DTPS U-1&2	8.30	8.30	492	285
Total	8.30	8.30		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	141.58	141.58
MSPGCL Thml+Gas	141.58	141.58
MSPGCL Hydro	5.66	5.66

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	147.24	147.24
Koyna 1,2 & 4 Total	1.46	1.46
State Total	346.29	346.29

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Jul/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLA R	CS SHAR E	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planne d	*Trans mission Constraint					
1	6125	156	0	6280	1508	5000	0	0	5433	5207	-1214	16399	0	0	16399	2243	382	19024	49.97
2	6110	148	0	6258	1442	4912	0	0	5517	5180	-1142	16300	0	0	16300	2113	351	18764	49.93
3	6152	168	0	6320	1449	4975	0	0	5179	5052	-1082	16397	0	0	16397	2012	318	18727	49.90
4	6207	148	0	6356	1472	5306	0	0	5177	4593	-1046	16373	0	0	16373	1928	308	18608	50.00
5	6234	152	0	6386	1510	5110	0	0	5533	5035	-1024	16691	0	0	16691	1907	327	18925	49.98
6	6260	146	0	6406	1627	5281	0	1	6226	5978	-1119	17808	0	0	17808	2004	367	20179	49.95
7	6254	146	0	6400	1671	5586	0	128	6877	6469	-1198	18658	0	0	18658	2070	398	21126	50.03
8	6288	192	0	6480	1530	5404	0	460	7109	6678	-1414	18710	0	0	18710	2218	428	21356	50.02
9	6171	192	0	6364	1802	4900	0	869	7030	6762	-1629	18627	0	0	18627	2464	441	21532	50.02
10	5963	190	0	6152	2014	4568	0	1265	7020	7135	-1873	18809	0	0	18809	2756	451	22017	49.97
11	5743	194	0	5938	2146	4235	0	1373	7504	7529	-2105	18666	0	0	18666	2975	450	22091	50.00
12	5454	244	0	5698	2262	4205	0	1401	7711	7486	-2158	18451	0	0	18451	3029	444	21924	49.99
13	5166	172	0	5338	2458	4202	0	1420	7872	7592	-2331	18240	0	0	18240	2968	440	21647	50.00
14	4658	148	0	4806	2640	3797	0	1426	7631	7186	-2132	17306	0	0	17306	2793	417	20516	50.04
15	4720	148	0	4868	2768	3973	0	1348	7356	7049	-2078	17506	0	0	17506	2759	421	20686	49.98
16	5032	148	0	5180	2845	4208	0	1102	7017	6647	-2089	17464	0	0	17464	2754	429	20647	49.95
17	5645	139	0	5784	2925	4200	0	806	6555	6091	-2004	17346	0	0	17346	2722	456	20524	50.00
18	5908	145	0	6053	2730	4311	0	416	6412	6335	-1958	17433	0	0	17433	2715	454	20602	50.04
19	6249	197	0	6446	2446	4953	0	54	6449	6099	-1873	17672	0	0	17672	2728	453	20853	50.03
20	6341	742	0	7083	1932	5574	0	0	6227	5977	-1616	18510	0	0	18510	2750	440	21700	49.92
21	6353	519	0	6872	1752	5755	0	0	6264	5937	-1455	18434	0	0	18434	2688	427	21549	49.97
22	6283	475	0	6758	1466	5916	0	0	5883	5472	-1332	17855	0	0	17855	2591	424	20871	49.99
23	6272	428	0	6700	1335	5911	0	0	5517	5140	-1186	17490	0	0	17490	2476	411	20376	49.97
24	5996	320	0	6316	1199	5936	0	0	5627	5219	-1173	17088	0	0	17088	2402	408	19899	50.02
MUs	141.58	5.66	0.00	147.24	46.93	118.22	0.00	12.07	155.13	147.85	-38.23	424.23	0.00	0.00	424.23	60.06	9.84	494.14	49.99

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Jul/2023

Position as on 6.30 Hrs of 02/Jul/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
MSPGCL	Parli Unit 8	250	18/06/2023	23:55		Continued.	Annual Overhaul	15/07/2023
MSPGCL	Khaparkheda Unit 1	210	30/06/2023	00:18		Continued.	Annual Overhaul	24/07/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	31/07/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/07/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Material replacement work.	01/03/2024
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	29/06/2023
MSPGCL	Uran Unit 6	108	01/06/2023	19:57		Continued.	No Schedule	
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Nasik Unit 3	210	08/06/2023	11:40		Continued.	Tolling Agreement with IEPL synchronised at 9:19 Hrs	
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	
MSPGCL	Uran Unit 7	108	24/06/2023	19:03		Continued.	On boiler protection	
IPP	JSW (J) U2	300	27/06/2023	23:44		Continued.	No schedule	
MSPGCL	Parli Unit 6	250	29/06/2023	00:45		Continued.	Zero Schedule	
MSPGCL	Parli Unit 7	250	29/06/2023	14:31		Continued.	On Zero Schedule	
TPC-G	Trombay 5	500	01/07/2023	11:51		Continued.	Coal feeding problem	
IPP	SWPGPL U-1	135	02/07/2023	02:54		Continued.	PA Fan problem	10/07/2023

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 02/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	27/06/2023	09:46			HT	H/T for load Management.
JAIGAD - KARAD CKT - 2	IntraState	30/06/2023	20:35	01/07/2023	08:06	HT	H/T for controlling overvoltages.
KHADKA-AURANGABAD (WALUJ)	IntraState	30/06/2023	21:03	01/07/2023	09:20	HT	H/T For controlling overvoltages.
LONIKAND I - KOYNA STAGE-IV	IntraState	30/06/2023	21:07	01/07/2023	08:17	HT	H/T For controlling overvoltages.
JEJURI - KARAD	IntraState	01/07/2023	09:24	01/07/2023	17:37	PO	PID Faulty string replacement work
CHANDRAPUR 2- KUMBHARGAON (NANDED) CKT - 1	IntraState	01/07/2023	09:25	01/07/2023	20:33	PO	Replacement of Faulty Insulator string at LOC 264 (Found in PID)
CHANDRAPUR - KHAPERKHEDA	IntraState	01/07/2023	11:07	02/07/2023	15:33	EO	To attend hotspot on Yph wavetrap of 400kV Chandrapur-Khaperkheda Ckt.
JAIGAD - KARAD CKT - 1	IntraState	01/07/2023	21:14	02/07/2023	09:50	HT	H/T FOR O/V
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33KV 315MVA ICT - 3 @ LONIKAND	IntraState	01/07/2023	08:55	01/07/2023	19:24	PO	CT Replacement work
400/220/33 KV 315MVA ICT - 2 @ BABHALESHWAR	IntraState	02/07/2023	13:30			PO	ABB Circuit Breaker Mechanism overhauling ICT 2 on TBC
220 KV TBC Outages/Trippings							
BUS COUPLER @ SAYNE	IntraState	01/07/2023	09:23	01/07/2023	11:26	PO	Bay Diagnostic Testing & Quarterly Maintenance.
220 KV MAINBAY Outages/Trippings							
220 KV WANI - PANDHARKAWDA CKT I BAY (TEST CHARGED)	IntraState	02/06/2023	10:10			HT	For rectification of punch points of 220kv wani- pandharkawada line ph-i line.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 1	IntraState	10/02/2023	09:45			PO	Breaker overhauling work. (RFC AT 21:23 HRS DT.10/02/2023 AND KEPT OPENED FOR LOAD MANAGEMENT)
EKLAHARE (OCR) - PADGHE	IntraState	05/03/2023	08:55			HT	For load management
GOREGAON - AAREY CKT - 2	IntraState	17/06/2023	18:14			PO	Shifting of existing 220kV AIS Bay no. 2 to New GIS Bay no. 19 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
URAN - KHARGHAR 1	IntraState	23/06/2023	17:36			PO	LILO and commissioning of 220kV Ulwe GIS

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 02/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
EKLAHARE (GCR) - AIROLI KNOW PARK	IntraState	29/06/2023	13:04			PO	For providing 2nd source to 220KV Bapgaon S/stn by making bunching on 220 KV AKP Nashik line at loc. 397 during the work of:Erection of cable termination kit and LA on newly erected CTT Monopole on 220 KV Kalwa Bapgaon line in between Loc No-398 to 399 for the Work of newly proposed 220KV GIS substation of M/s. Estela Enterprises Pvt. Ltd
BAPGAON - KALWA	IntraState	29/06/2023	13:06			PO	Erection of cable termination kit and LA on newly erected CTT Monopole on 220 KV Kalwa Bapgaon line in between Loc No-398 to 399 for the Work of newly proposed 220KV GIS substation of M/s. Estela Enterprises Pvt. Ltd
MAHAPE - RELIANCE GIS	IntraState	01/07/2023	08:25	01/07/2023	17:48	PO	Routine Bay Maintenance work at both ends of substation.
WPCL-WARORA 2	IntraState	01/07/2023	09:32	01/07/2023	19:19	EO	1. Hot spot attending on SWPGPL Circuit-2 Y-Phase Bus-1 isolator at MSETCL Warora. 2. Ckt-2 Bus-1 Isolator B-phase male contact replacement with spare 3. Ckt-2 Bus-1 isolator alignment and Line isolator maintenance. 4. Ckt-2 Line isolator maintenance at SWPGPL end.
TROMBAY - CARNAC - 7	IntraState	01/07/2023	09:37	01/07/2023	12:50	PO	B-PH CT Clamp replacement
NAGOTHANE - SPCL	IntraState	01/07/2023	11:30	01/07/2023	16:48	EO	B-PH LA REPLACEMENT WORK
MUDSHINGI - CHIKODI	IntraState	01/07/2023	11:55	01/07/2023	19:14	EO	For safety purpose only for jump replacement work of 220kV Talandge- Mudshingi ckt-1 on multicircuit tower no. 12- Yph, MC-16 - Y & B ph, MC- 22, Bph. On MC towers upper circuit is 220kV Talandge- Mudshingi ckt-1 & lower circuit is 220kV Mudshingi - Chikodi line. For jump work on upper circuit, outage on lower circuit also required as safety purpose. Outage was proposed for dt. 26.06.2023 in monthly outage proposal but NOC was not received from NLDC. Outage on 20kV Talandge- Mudshingi ckt-1 is also proposed for dt.01.07.2023 and is approved by SLDC Kalwa.
NIWALI - PAWAS LINE	IntraState	01/07/2023	12:25	01/07/2023	19:45	T	Tripped on distance protection
TALANDGE - MUDSHINGI CKT - 1	IntraState	01/07/2023	12:26	01/07/2023	18:40	PO	To attend jump work at loc no. M/C- 12, Y ph, MC-22, B ph., loc no. 305, B ph.
MAIN BUS - 1 @ AAREY	IntraState	01/07/2023	19:47	01/07/2023	20:56	EO	Shifting of existing 220kV AIS Bay no. 6 to New GIS Bay no. 22 under MERC approved Aarey 220kV AIS to GIS conversion project scheme.
KARAD -MUDSHINGI CKT 2-TAK	IntraState	02/07/2023	06:57	02/07/2023	07:45	T	Tripped on Distance Protection.
MAHAPE - TFIPL	IntraState	02/07/2023	08:31	02/07/2023	13:50	PO	Routine Bay Maintenance work at both ends of substation.
WPCL-WARORA 1	IntraState	02/07/2023	09:05	02/07/2023	20:15	PO	Attending Hot Spot.
BOISAR II - TARAPUR	IntraState	02/07/2023	10:57	02/07/2023	17:36	PO	Replacement of old hardware at critical location.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Jul/2023

Statement-VII

Position as on 6.30 Hrs of 02/Jul/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BOISAR II - BOISAR (PG) CKT - 3	IntraState	02/07/2023	11:09	02/07/2023	17:24	PO	Replacement of old hardware at critical location
SAHARA-URSE	IntraState	02/07/2023	12:04	02/07/2023	17:59	HT	For load management and to facilitate Urse Talegaon ambi ckt 1 outage
URSE - TALEGAON (AMBI) CKT 1	IntraState	02/07/2023	12:15	02/07/2023	17:53	PO	1) Replacement of disc insulator strings by polymer insulator string. 2)Emergency tree cutting.
GHODBUNDER - MSETCL BOISAR	IntraState	02/07/2023	16:10		Continued.	T	Tripped on distance protection
BORIVALI - BOISAR II LINE	IntraState	02/07/2023	16:10		Continued.	T	Tripped on distance protection
BOISAR II - TARAPUR	IntraState	02/07/2023	16:10	02/07/2023	17:36	T	Tripped on distance protection
DAHANU - GHODBUNDER CKT - 2	IntraState	02/07/2023	18:25	02/07/2023	22:18	T	Tripped on distance protection
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132-110 KV 100 MVA ICT 2	IntraState	21/06/2023	11:00			EO	Replacement of HV CB
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	01/07/2023	09:52	01/07/2023	16:01	PO	for NIFPS maintenance of ICT
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
KHOPOLI - KARANJADE	IntraState	02/07/2023	10:05	02/07/2023	14:58	PO	Repair of C ph conductor in span 185-186.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage