

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Aug/2022 MONDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	122.514	122.514	1) Gujrat	12.108	12.108
2) Hydro	9.049	9.049	2) Madhya Pradesh	11.538	11.538
3) Gas	3.859	3.859	3) Chattisgarh	2.450	2.450
Total MSPGCL	135.422	135.422	4) Maharashtra	180.448	180.448
B) 1) APML	45.394	45.394	5) Goa (Amona)	-1.330	-1.330
2) JSWEL	13.861	13.861	Total	205.214	205.214
3) VIPL	0.000	0.000	a) Mumbai Schedule	40.553	40.553
4) RPL(AMT)	18.338	18.338	b) Mumbai Drawl	43.533	43.533
5) SWPGPL	5.368	5.368	c) MSEDCL Bilateral *	73.799	73.799
6) Other IPP	6.555	6.555	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	40.553	40.553
C) 1) TPCL Thermal	9.798	9.798	Include PX	0.000	0.000
2) TPCL Hydro	4.978	4.978	Standby	0.000	0.000
3) TPCL Gas	3.095	3.095	H) ENERGY CATERED (MUs)		
4) AEML Thermal	4.413	4.413	1) MSEDCL	403.965	403.965
D) STATE			2) Mumbai Discoms	65.817	65.817
1) Thermal	226.241	226.241	3) Other Discoms	9.176	9.176
(A1+C1+C4+(B1-B6))			TOTAL STATE	478.958	478.958
2) Hydro	14.027	14.027			
(A2+C2)					
3) Gas	6.954	6.954			
(A3+B7+C3)					
4) Wind	16.163	16.163			
6) SOLAR	10.359	10.359			
TOTAL STATE	273.744	273.744			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 17 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5073	5406	5324	4866
MSPGCL Hydro	382	299	996	285
MSPGCL Gas	133	129	230	133
MSPGCL Total Generation	5588	5834	6550	5284
Central Sector Receipt	9352	9308	9047	7030
WIND	464	537	716	934
CPP / IPP Thermal	3617	3789	4341	3321
CPP / IPP Gas	0	0	0	0
SOLAR	1103	564	0	0
Exchange with Mumbai	-2226	-2344	-1826	-1293
MSEDCL DEMAND MET	17471	17275	18392	14976
Load Shedding	0	0	0	0
MSEDCL DEMAND	17471	17275	18392	14976
TPCL GENERATION	663	668	842	694
AEML GENERATION	160	162	234	167
MUMBAI DEMAND	3049	3174	2902	2154
OTHER DISCOM DEMAND	427	412	436	300
STATE DEMAND MET	20947	20862	21730	17430
STATE DEMAND	20947	20862	21730	17430
Frequency (Hz)	50.02	50.02	49.93	50.02

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 11:37 Hrs	49.76 Hz at 14:14 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Aug/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.02	3.02	140	110
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Unit 9	9.70	9.70	415	385
Unit 10	11.52	11.52	493	430
Total	24.24	24.24		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.90	8.90	445	280
Unit 5	6.98	6.98	330	255
Total	15.88	15.88		
Parli				
Unit 6	4.13	4.13	199	161
Unit 7	3.86	3.86	187	144
Unit 8	3.70	3.70	173	140
Total	11.69	11.69		
Chandrapur				
Unit 3	1.81	1.81	122	0
Unit 4	1.87	1.87	87	72
Unit 5	5.39	5.39	245	190
Unit 6	6.01	6.01	285	195
Unit 7	0.00	0.00	0	0
Unit 8	10.14	10.14	461	315
Unit 9	10.23	10.23	445	320
Total	35.46	35.46		
Paras				
Unit 3	3.57	3.57	190	0
Unit 4	3.94	3.94	177	138
Total	7.52	7.52		
Khaparkheda				
Unit 1	3.08	3.08	135	120
Unit 2	3.16	3.16	145	125
Unit 3	3.78	3.78	170	118
Unit 4	3.54	3.54	164	131
Unit 5	8.03	8.03	375	275
Total	21.59	21.59		
Nasik				
Unit 3	3.05	3.05	152	108
Unit 4	0.00	0.00	0	0
Unit 5	3.09	3.09	143	116
Total	6.13	6.13		
Uran				
All Units	3.86	3.86	266	128
Total	3.86	3.86		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.61	0.61	26	24
Total	0.61	0.61		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.46	1.46	220	40
Stage 4	0.47	0.47	348	0
Stage 3	0.37	0.37	80	0
Total	2.30	2.30		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.31	0.31	58	0
BHIRA T.R.	0.39	0.39	77	0
SMLHY_PTN	5.14	5.14	223	203
GHATGHAR	0.30	0.30	125	0
Total	6.14	6.14		
Wind				
Total	16.16	16.16	0	0
Total	16.16	16.16		
CPP				
APML(Mus)	45.39	45.39	0	0
JSWEL(Mus)	13.86	13.86	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	18.34	18.34	0	0
SWPGPL-Mus	5.37	5.37	0	0
Other(Mus)	6.56	6.56	0	0
Total	89.52	89.52		
SOLAR				
Total	10.36	10.36	0	0
Total	10.36	10.36		
Tata				
Trombay 5	6.55	6.55	380	265
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.85	1.85	112	41
Trombay 7B	1.24	1.24	66	35
TATA Hydro	4.98	4.98	440	114
Trombay 8	3.25	3.25	196	129
Total	17.87	17.87		
AEML				
DTPS U-1&2	4.41	4.41	246	148
Total	4.41	4.41		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	122.51	122.51	MSPGCL Total	135.42	135.42
			MSPGCL Thml+Gas	126.37	126.37	Koyna 1,2 & 4 Total	1.93	1.93
			MSPGCL Hydro	9.05	9.05	State Total	273.74	273.74

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 01/Aug/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5135	285	133	5553	702	3552	0	0	7381	7366	-1473	15369	0	15369	2462	331	18162	50.01
2	5000	286	133	5419	929	3533	0	0	7180	7292	-1386	15485	0	15485	2284	302	18071	50.01
3	4866	285	133	5284	934	3321	0	0	7435	7030	-1293	14976	0	14976	2154	300	17430	50.02
4	4769	280	134	5183	909	3248	0	0	7355	7479	-1211	15316	0	15316	2065	292	17673	50.00
5	4899	285	134	5318	923	3243	0	0	7610	7875	-1195	15863	0	15863	2035	301	18199	50.01
6	5170	344	134	5648	755	3634	0	0	8124	8497	-1340	16851	0	16851	2140	343	19334	50.00
7	5170	332	144	5646	696	3619	0	62	9494	9467	-1469	17642	0	17642	2273	379	20294	50.02
8	5211	326	134	5671	540	3595	0	325	9254	9256	-1555	17447	0	17447	2451	385	20283	50.05
9	5187	385	134	5706	583	3968	0	678	9218	8701	-1861	17370	0	17370	2751	405	20526	50.04
10	5073	382	133	5588	464	3617	0	1103	9198	9352	-2226	17471	0	17471	3049	427	20947	50.02
11	5128	345	131	5604	336	3430	0	1335	9355	9230	-2338	17180	0	17180	3161	417	20758	49.99
12	5162	346	130	5638	328	3441	0	1386	9276	9093	-2438	17044	0	17044	3273	404	20721	50.05
13	4936	322	129	5387	468	3388	0	1364	9071	9131	-2425	16904	0	16904	3239	409	20552	50.01
14	4549	326	129	5004	500	3316	0	1227	9012	9137	-2289	16491	0	16491	3135	404	20030	50.00
15	4949	370	128	5447	443	3322	0	1136	8970	9370	-2304	17023	0	17023	3165	391	20579	49.95
16	5270	324	128	5722	505	3772	0	834	8977	9129	-2331	17235	0	17235	3192	396	20823	50.02
17	5406	299	129	5834	537	3789	0	564	9189	9308	-2344	17275	0	17275	3174	412	20862	50.02
18	5442	280	148	5870	563	4038	0	295	9397	8823	-2151	17015	0	17015	3067	423	20505	50.03
19	5349	283	184	5816	576	3987	0	52	9557	9265	-1937	17312	0	17312	2936	447	20695	50.03
20	5324	996	230	6550	716	4341	0	0	8879	9047	-1826	18392	0	18392	2902	436	21730	49.93
21	5250	639	260	6149	831	4401	0	0	8671	8501	-1662	17806	0	17806	2795	414	21015	49.95
22	5104	621	260	5985	1024	4412	0	0	7955	8032	-1618	17421	0	17421	2749	414	20584	50.00
23	5099	358	266	5723	980	4381	0	0	7761	7842	-1625	16918	0	16918	2693	383	19994	50.00
24	5066	350	261	5677	921	4168	0	0	7716	6991	-1236	16157	0	16157	2672	364	19193	50.05
MUs	122.51	9.05	3.86	135.42	16.16	89.52	0.00	10.36	206.04	205.21	-43.53	403.96	0.00	403.96	65.82	9.18	478.96	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center, Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 01/Aug/2022

Position as on 6.30 Hrs of 02/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Chandrapur Unit 7	500	15/06/2022	05:01		Continued.	Annual Overhaul	14/08/2022
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	30/09/2022
MSPGCL	Koradi Unit 8	660	04/07/2022	21:55		Continued.	Annual Overhaul	10/08/2022
IPP	Adani U-3	660	27/07/2022	00:05		Continued.	Annual Overhaul	17/08/2022
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	22/10/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
IPP	JSW (J) U1	300	16/03/2022	23:16		Continued.	Turbine Vibration	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	01/08/2022
MSPGCL	Uran Unit B0	120	24/06/2022	06:28		Continued.	Excitation channel fault(Converted to Gas Shortage from 26-06-22)	
MSPGCL	Uran Unit 8	108	24/06/2022	15:33		Continued.	Gas shortage	
IPP	RPL(AMT) U-3	270	30/06/2022	15:00		Continued.	Coal Shortage	
IPP	JSW (J) U4	300	01/07/2022	13:03		Continued.	Turbine bearing Vibration high	24/08/2022
AEML	AEML Unit 2	250	13/07/2022	00:38	02/08/2022	15:27	Coal Shortage	
IPP	SWPGPL U-3	135	14/07/2022	14:58		Continued.	FD Fan Problem(converted to coal shortage from 19-7-2022)	
MSPGCL	Nasik Unit 4	210	14/07/2022	19:55		Continued.	Wet Coal Problem.	
MSPGCL	Bhusawal Unit 3	210	16/07/2022	06:30		Continued.	Critical coal stock	
IPP	SWPGPL U-2	135	20/07/2022	01:00		Continued.	Coal Shortage	
IPP	RPL(AMT) U-5	270	20/07/2022	10:00	02/08/2022	13:33	Coal Shortage	
MSPGCL	Uran Unit 5	108	24/07/2022	13:14	01/08/2022	17:03	Gas shortage	
MSPGCL	Chandrapur Unit 3	210	01/08/2022	00:03	01/08/2022	04:43	DRUM LEVEL HIGH	01/08/2022
MSPGCL	Paras Unit 3	250	01/08/2022	20:30	01/08/2022	22:56	Furnace Pressure High	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Aug/2022

Position as on 6.30 Hrs of 02/Aug/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Chandrapur Unit 4	210	02/08/2022	07:48		Continued.	Wet coal problem	06/08/2022
MSPGCL	Koyna Unit 3	70	02/08/2022	21:40		Continued.	major and minor governor failure	04/08/2022
IPP	RPL(AMT) U-4	270	02/08/2022	22:00		Continued.	Bottom Ash Problem,	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 02/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
400 KV LINE Outages/Trippings							
PARLI(MS) - PARLI (PG) CKT -2	InterState	01/08/2022	07:55	01/08/2022	21:05	HT	outage proposed by PG
400 KV AKOLA - AURANGABAD(PG) CKT -1	InterState	02/08/2022	09:53	02/08/2022	20:58	PO	For Line Bays, L/R & Line AMP works at both ends, Dia to be kept in open condition at both ends.
SOLAPUR PG - ALKUD	InterState	02/08/2022	13:08	02/08/2022	23:01	PO	Line side equipments AMP
BUS COUPLER @ PADGHE	IntraState	22/07/2022	13:05	02/08/2022	14:10	PO	1) Replacement of old Bhel make CB under LES scheme . 2) MTAMC work 3) Diagnostic Testing work
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	26/07/2022	11:09			HT	H/T FOR 400KV TALEGAON PG-CHAKAN LINE LOADING
KHADKA-AURANGABAD (WALUJ)	IntraState	29/07/2022	20:19	01/08/2022	06:36	HT	H/T DUE TO O/V
JAIGAD - KARAD CKT - 2	IntraState	30/07/2022	21:10	01/08/2022	06:34	HT	H/T DUE TO O/V
MAIN BUS - 2 @ LAMBOTI	IntraState	01/08/2022	14:47	01/08/2022	16:29	EO	For investigating no voltage from R phase metering core of CVT
BABHALESHWAR - PADGHE CKT - 2	IntraState	01/08/2022	17:45	02/08/2022	00:58	EO	For attending Hot Spot on B bus Bph PG isoaltor jaw temp 127deg & 29D isolator yph CB side 106deg (Sparking observed on B bus Bph PG isolator)
KHADKA-AURANGABAD (WALUJ)	IntraState	01/08/2022	21:45	02/08/2022	06:55	HT	H/T DUE TO O/V
PADGHE - KALWA CKT - 2	IntraState	01/08/2022	23:25	02/08/2022	05:25	EO	Work of :- 1) Replacement of damaged Rph CT to Gantry jumper Temp 127deg.conductor strands are broken 2) Attending Hot spot on Yph CT line side temp 102 deg & Bph line isolator CB side 103 deg 3)Attending Hot Spot at loc. no. 1017 Y-Phase (230 deg. celsius) by 400kV Line Maintenance S/Dn, Kalwa
JAIGAD - KARAD CKT - 1	IntraState	02/08/2022	00:51	02/08/2022	07:03	HT	H/T Due to Control Over Voltage.
BUS COUPLER @ KARAD	IntraState	02/08/2022	10:02	02/08/2022	18:23	PO	Alignment of Horizontal Cu bar of Bus-II B ph PG Isolator Quadriple bus for proper closing of PG isolator with the help of Hot line Unit, Ogalewadi. Also CB DCRM, CRM & CB timing measurement of CGL make CB. Quarterly Maint Work
PADGHE - KALWA CKT - 1	IntraState	02/08/2022	11:27		Continued.	EO	Conductor replacement work to attend the Hot Spot at Loc. No. 1112 R-Phase (image is attached)
JAIGAD - KARAD CKT - 2	IntraState	02/08/2022	21:07		Continued.	HT	To control OV
KHADKA-AURANGABAD (WALUJ)	IntraState	02/08/2022	22:56		Continued.	HT	H/T to Control Over Voltage.
400 KV ICT Outages/Trippings							
400/220 KV 3X105 MVA ICT - 2 @ NAGOTHANE	IntraState	01/08/2022	14:52	01/08/2022	19:30	EO	To attend the Hot spot on Y-ph MV & B-PH MV Bushing & Preventive maintenance will be done.
400/220/33 KV 315 MVA ICT - 1 @ LONIKAND	IntraState	01/08/2022	23:26	02/08/2022	01:40	HT	TRIPPED ON OLTC BUCHHOLZ B- PHASE
220 KV MAINBAY Outages/Trippings							

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 02/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
BUS SETION - 4 @ KANDALGAON	IntraState	02/08/2022	10:46	02/08/2022	12:13	PO	For Overhauling of 220 kV Hybrid Pass No:03 .
BUS SETION - 3 @ KANDALGAON	IntraState	02/08/2022	12:58	02/08/2022	15:15	PO	For Overhauling Of Hybrid Pass No :03
220 KV LINE Outages/Trippings							
BORIVALI - BOISAR (PG)	IntraState	18/07/2022	16:18	01/08/2022	16:39	EO	Shifting of Line on TBC due to damaged B-Ph jumper (Twin) between Main Bus & Bus Isolator.
EKLAHARE (OCR) - PADGHE	IntraState	26/07/2022	10:04	01/08/2022	05:25	HT	H/T DUE TO 220KV BBSLR-NASIK LINE LOADING
HINJAWADI I- CHINCHWAD	IntraState	30/07/2022	08:35	01/08/2022	21:00	PO	Box cross arm & aux cross arm erection & dismentling of chinch-Hinj I line-2 Nos spans & restringing of 2 nos span of line on MDN +3 tower charging of Line. CB overhauling work
KHARGHAR - CTRLS CKT	IntraState	31/07/2022	08:28	01/08/2022	06:50	PO	For carrying out the work of Charging of 220 KV Net magic S/S as a radial feeder at Loc. No 46.
KALWA - TFIPL	IntraState	31/07/2022	08:34	01/08/2022	06:00	PO	Outage required for safety purpose for For carrying out the work of Charging of 220 KV Net magic S/S as a radial feeder at Loc. No 46 of 220KV Kharghar-CTRLS Line (M/C Line)
DHARAVI - MAHALAXMI	IntraState	01/08/2022	00:10	01/08/2022	05:28	PO	PROTECTION TESTING
HINJAWADI I- CHINCHWAD	IntraState	01/08/2022	06:48	01/08/2022	21:00	EO	To Complete the balance work of erection of MDN+ 3 tower & stringing upto gantry tower of hinjewadi I S.s
TALANDGE - ICHALKARANJI 2	IntraState	01/08/2022	09:29	01/08/2022	14:25	PO	1) For Quarterly bay maintenance work. 2) Bay Diagnostic testing work 3) Hot spot attending work
MUDSHINGI- BELEWADI LINE	IntraState	01/08/2022	13:08	01/08/2022	14:29	PO	Replcement of broken suspension Clamp at LOC. M/C.22 Pilot String
TALANDGE - MUDSHINGI CKT - 1	IntraState	01/08/2022	14:32	01/08/2022	19:30	PO	To attend hot spot observed in Thermoscanning at T.L no. 1 (R, Y & B ph) , 2 (Y & B ph), D/C-7 (B-ph) , M/C-3 (Y ph.),
TALANDGE - MUDSHINGI CKT - 1	IntraState	01/08/2022	14:32	01/08/2022	19:30	PO	Quarterly maintenance work.
NEW KOYNA - POPHALI	IntraState	01/08/2022	15:39	01/08/2022	19:02	EO	Y Phase Line side isolator to Outgoing Conductor most of the conductor strands found broken at pophali Switchyard. also, conductor found weak. Outage is required for attending damaged conductor.
SALSETTE BORIVLI - 1	IntraState	02/08/2022	08:37			PO	MBS+6 Tower erection with conductor shifting at new tower no. 2A for customer funded project (third party)
KANDALGAON - BHIRA	IntraState	02/08/2022	14:13	02/08/2022	17:38	EO	Hotspot/Redspot attending work at Loc.No.1 R ph jumper.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/22 KV 50 MVA PTR 1 @ MAHAD	IntraState	01/08/2022	10:22	01/08/2022	12:53	PO	Hotspot attending work .

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Aug/2022

Statement-VII

Position as on 6.30 Hrs of 02/Aug/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/33KV 100MVA PTR 2 @ 5 STAR MIDC, KAGAL	IntraState	01/08/2022	10:52	01/08/2022	17:30	PO	For attending oil leakage, maintaining ground clearance of LA jump.
220/22 KV 50 MVA PTR 2 @ MAHAD	IntraState	01/08/2022	14:25	01/08/2022	16:14	PO	Hotspot attending work and Jumper replacement work.
110 KV LINE Outages/Trippings							
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
WAGHIVALI - MANKHURD	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
WAGHIVALI - CHEMBUR	IntraState	04/02/2022	10:30			PO	Construction of 400KV M/C Kharghar-Vikhroli Transmission line along with Dismantling, De-Stringining of existing 110KV Waghivali-Mankhurd and Waghivali-Chembur lines and shfiting these lines on new Multicircuit Towers between Darave to Vashi.
TATA BORIVLI MSETCL BORIVLI 1	IntraState	01/08/2022	09:52	01/08/2022	18:32	PO	TREE TRIMMING
KARANJADE - BHOKARPADA	IntraState	01/08/2022	10:38	01/08/2022	15:28	PO	For tree trimming work .
KARANJADE - BHOKARPADA	IntraState	01/08/2022	10:38	01/08/2022	15:28	PO	TREE TRIMMING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage