

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Aug/2023 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	115.860	115.860	1) Gujrat	7.547	7.547
2) Hydro	11.115	11.115	2) Madhya Pradesh	4.963	4.963
3) Gas	0.000	0.000	3) Chattisgarh	1.470	1.470
Total MSPGCL	126.975	126.975	4) Maharashtra	148.126	148.126
B) 1) APML	41.466	41.466	5) Goa (Amona)	-1.809	-1.809
2) JSWEL	17.896	17.896	Total	160.297	160.297
3) VIPL	0.000	0.000	a) Mumbai Schedule	33.350	33.350
4) RPL(AMT)	24.290	24.290	b) Mumbai Drawl	39.276	39.276
5) SWPGPL	6.583	6.583	c) MSEDCL Bilateral *	94.901	94.901
6) Other IPP	6.002	6.002	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	33.350	33.350
C) 1) TPCL Thermal	9.898	9.898	Include PX	0.000	0.000
2) TPCL Hydro	4.358	4.358	Standby	0.000	0.000
3) TPCL Gas	2.579	2.579	H) ENERGY CATERED (MUs)		
4) AEML Thermal	8.117	8.117	1) MSEDCL	405.930	405.930
D) STATE			2) Mumbai Discoms	64.228	64.228
1) Thermal	230.112	230.112	3) Other Discoms	9.996	9.996
(A1+C1+C4+(B1-B6))			TOTAL STATE	480.154	480.154
2) Hydro (A2+C2)	15.473	15.473			
3) Gas (A3+B7+C3)	2.579	2.579			
4) Wind	60.947	60.947			
6) SOLAR	10.746	10.746			
TOTAL STATE	319.857	319.857			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 18 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 3 Hrs
MSPGCL Thermal	5017	5110	5111	4703
MSPGCL Hydro	472	292	1030	355
MSPGCL Gas	0	0	0	0
MSPGCL Total Generation	5489	5402	6141	5058
Central Sector Receipt	8180	7111	7148	5522
WIND	2489	2535	2325	2466
CPP / IPP Thermal	3710	3854	5053	3721
CPP / IPP Gas	0	0	0	0
SOLAR	954	415	31	0
Exchange with Mumbai	-2131	-1920	-1540	-1051
MSEDCL DEMAND MET	18240	16946	18711	15382
Load Shedding	0	0	0	0
MSEDCL DEMAND	18240	16946	18711	15382
TPCL GENERATION	601	763	936	646
AEML GENERATION	311	329	433	316
MUMBAI DEMAND	3043	3012	2909	2013
OTHER DISCOM DEMAND	451	451	447	334
STATE DEMAND MET	21734	20409	22067	17729
STATE DEMAND	21734	20409	22067	17729
Frequency (Hz)	49.94	49.95	50.01	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.21 Hz at 13.03 Hrs	49.75 Hz at 09.24 Hrs	50.01	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Aug/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.38	3.38	160	120
Unit 8	11.14	11.14	552	378
Unit 9	11.90	11.90	565	381
Unit 10	0.00	0.00	0	0
Total	26.41	26.41		
Bhusawal				
Unit 3	2.85	2.85	130	105
Unit 4	8.58	8.58	455	280
Unit 5	6.78	6.78	425	0
Total	18.20	18.20		
Parli				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	2.14	2.14	137	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	7.16	7.16	325	277
Unit 7	6.90	6.90	308	230
Unit 8	9.24	9.24	431	280
Unit 9	10.04	10.04	464	300
Total	35.48	35.48		
Paras				
Unit 3	4.26	4.26	206	145
Unit 4	3.86	3.86	174	142
Total	8.12	8.12		
Khaparkheda				
Unit 1	2.26	2.26	100	85
Unit 2	2.77	2.77	128	107
Unit 3	3.57	3.57	181	131
Unit 4	3.58	3.58	188	127
Unit 5	8.94	8.94	430	285
Total	21.11	21.11		
Nasik				
Unit 3	3.36	3.36	175	113
Unit 4	0.00	0.00	0	0
Unit 5	3.18	3.18	160	116
Total	6.53	6.53		
Uran				
All Units	0.00	0.00	0	0
Total	0.00	0.00		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.21	1.21	55	48
Total	1.21	1.21		
Koyna				
Stage 1-2	1.69	1.69	280	35

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	0.86	0.86	503	0
Stage 3	1.56	1.56	80	0
Total	4.11	4.11		
Hydro				
KDPH	0.74	0.74	36	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.46	0.46	80	0
SMLHY_PTN	4.18	4.18	184	171
GHATGHAR	0.41	0.41	125	0
Total	5.79	5.79		
Wind				
Total	60.95	60.95	0	0
Total	60.95	60.95		
CPP				
APML(Mus)	41.47	41.47	0	0
JSWEL(Mus)	17.90	17.90	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	24.29	24.29	0	0
SWPGPL-Mus	6.58	6.58	0	0
Dhariwal	0.00	0.00	0	0
IEPL	4.82	4.82	255	153
Other(Mus)	1.18	1.18	0	0
Total	96.24	96.24		
SOLAR				
Total	10.75	10.75	0	0
Total	10.75	10.75		
Tata				
Trombay 5	6.52	6.52	314	260
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.48	1.48	108	39
Trombay 7B	1.09	1.09	65	36
TATA Hydro	4.36	4.36	370	100
Trombay 8	3.37	3.37	196	129
Total	16.84	16.84		
AEML				
DTPS U-1&2	8.12	8.12	444	290
Total	8.12	8.12		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	115.86	115.86	MSPGCL Total	126.98	126.98
			MSPGCL Thml+Gas	115.86	115.86	Koyna 1,2 & 4 Total	2.56	2.56
			MSPGCL Hydro	11.12	11.12	State Total	319.86	319.86

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Aug/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	5057	356	0	5413	2193	4161	0	0	5692	5224	-1205	15406	0	0	15406	2302	380	18088	50.05
2	4961	355	0	5316	2345	3777	0	0	5925	5415	-1103	15397	0	0	15397	2133	353	17883	50.00
3	4703	355	0	5058	2466	3721	0	0	5769	5522	-1051	15382	0	0	15382	2013	334	17729	50.01
4	4824	360	0	5184	2454	3747	0	0	5602	5466	-1035	15490	0	0	15490	1949	326	17765	50.00
5	5036	375	0	5411	2470	3728	0	0	6023	5929	-1048	16144	0	0	16144	1942	346	18432	50.04
6	5270	355	0	5625	2430	3885	0	0	6835	6850	-1141	17275	0	0	17275	2063	374	19712	50.05
7	5280	359	0	5639	2630	4274	0	39	7674	7419	-1341	18260	0	0	18260	2235	400	20895	50.01
8	5156	462	0	5618	2344	3988	0	228	8359	7940	-1555	18144	0	0	18144	2442	419	21005	50.01
9	5042	459	0	5501	2585	3717	0	611	8391	8121	-1799	18306	0	0	18306	2758	430	21494	50.05
10	5017	472	0	5489	2489	3710	0	954	7947	8180	-2131	18240	0	0	18240	3043	451	21734	49.94
11	4594	397	0	4991	2569	3719	0	1148	8061	7949	-2257	17666	0	0	17666	3212	453	21331	50.01
12	4132	439	0	4571	2785	3410	0	1180	7934	7924	-2219	17205	0	0	17205	3216	446	20867	49.99
13	4223	370	0	4593	2847	3292	0	1375	7606	6968	-2269	16361	0	0	16361	3180	445	19986	50.05
14	4174	371	0	4545	2925	3205	0	1345	7111	6920	-2179	16313	0	0	16313	3070	448	19831	50.05
15	4220	638	0	4858	2829	3500	0	1362	6571	6573	-2182	16501	0	0	16501	3108	439	20048	49.97
16	4908	454	0	5362	2732	3773	0	1095	6736	6436	-2190	16762	0	0	16762	3123	446	20331	50.01
17	4902	294	0	5196	2524	3646	0	811	7299	7056	-2108	16677	0	0	16677	3077	448	20202	49.97
18	5110	292	0	5402	2535	3854	0	415	7581	7111	-1920	16946	0	0	16946	3012	451	20409	49.95
19	5201	445	0	5646	2564	4508	0	152	7370	6760	-1669	17493	0	0	17493	2966	468	20927	49.99
20	5111	1030	0	6141	2325	5053	0	31	7270	7148	-1540	18711	0	0	18711	2909	447	22067	50.01
21	4790	1064	0	5854	2553	5169	0	0	6811	6436	-1468	18110	0	0	18110	2796	434	21340	49.98
22	4649	471	0	5120	2582	5086	0	0	6403	6057	-1355	17048	0	0	17048	2678	442	20168	49.99
23	4705	522	0	5227	2392	4585	0	0	6150	5827	-1355	16258	0	0	16258	2549	418	19225	50.02
24	4795	427	0	5222	2379	4729	0	0	5552	5059	-1156	15834	0	0	15834	2452	399	18685	50.05
MUs	115.86	11.11	0.00	126.97	60.95	96.24	0.00	10.75	166.67	160.30	-39.28	405.93	0.00	0.00	405.93	64.23	10.00	480.15	50.01

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Aug/2023

Position as on 6.30 Hrs of 02/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	RPL(AMT) U-3	270	13/06/2023	00:01		Continued.	Annual Overhaul	04/08/2023
IPP	JSW (J) U3	300	07/07/2023	09:06		Continued.	Annual Overhaul	08/08/2023
MSPGCL	Koyana Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	16/08/2023
MSPGCL	Koyana Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
IPP	Adani U-1	660	16/07/2023	00:00		Continued.	Annual Overhaul	07/08/2023
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	23/08/2023
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhauled.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault	16/08/2023
MSPGCL	Koyana STG-IV Unit-1	250	05/06/2023	16:30		Continued.	The KGSC Stg-4 Unit No-1(250MW) not available due to foreign material impact at Guide vane no 4	18/09/2023
MSPGCL	Uran Unit 8	108	24/06/2023	10:05		Continued.	Compressor Surge Protection	15/08/2023
MSPGCL	Uran Unit B0	120	24/06/2023	19:01		Continued.	On RR end bearing high vibrations	12/08/2023
MSPGCL	Nasik Unit 4	210	19/07/2023	10:50		Continued.	ID Fan Problem(under tolling from 06.04 Hrs DT. 20-7-2023)	
IPP	SWPGPL U-3	135	21/07/2023	01:54		Continued.	Non-availability of linkage coal stock and due to continuous rains.	03/08/2023
MSPGCL	Parli Unit 6	250	21/07/2023	23:44		Continued.	BTL,(Converted into Zero schedule wef 23:00hrs dated 23.07.23)	
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	DUE TO HPT DIFFERENTIAL EXPANSION ON HIGHER SIDE	22/08/2023
MSPGCL	Uran Unit 6	108	27/07/2023	20:10		Continued.	No Schedule	
MSPGCL	Chandrapur Unit 3	210	27/07/2023	22:09	01/08/2023	02:25	Boiler Tube Leakage	31/07/2023

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Aug/2023

Position as on 6.30 Hrs of 02/Aug/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 7	250	28/07/2023	15:30		Continued.	Zero Schedule.	
MSPGCL	Parli Unit 8	250	28/07/2023	21:07		Continued.	Zero Schedule.	
MSPGCL	Bhusawal Unit 5	500	01/08/2023	19:34	01/08/2023	23:15	Flame Failure	
IPP	JSW (J) U1	300	02/08/2023	06:42		Continued.	Condenser cooling water problem heavy leakage	06/08/2023
MSPGCL	Bhusawal Unit 5	500	02/08/2023	07:47	02/08/2023	10:19	Flame Failure	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 02/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV ICT Outages/Trippings							
765KV/21KV GT - 1 @ TIRORA	IntraState	16/07/2023	10:20			PO	Annual Maintenance, Testing and Painting of Transformer. Annual maintenance of main bay and tie bay equipments.
765/400KV 1500 MVA ICT-1 @ TIRORA	IntraState	02/08/2023	09:42			PO	Annual Maintenance of Transformer. Annual maintenance of main bay and tie bay equipments.
400 KV TIEBAY Outages/Trippings							
TIE BAY - 411 OF WARDHA PGCIL @ KORADI 2	IntraState	23/06/2023	01:22			PO	Diagnostic testing of Circuit Breaker & Current transformer Routine nut bolt tightening
400 KV TBC Outages/Trippings							
BUS COUPLER @ BABHALESHWAR	IntraState	02/08/2023	09:20			PO	ABB Circuit Breaker Pole & Mechanism overhauling
400 KV LINE Outages/Trippings							
TALANDGE - KOLHAPUR (PG) CKT - 2	InterState	20/03/2023	07:49			PO	For reconductoring of Moose conductor with HTLS conductor for sytem improvement. AR to be kept in non Auto mode for 400KV-KOLHAPUR-MS-KOLHAPUR GIS -1
KHADKA-AURANGABAD (WALUJ)	IntraState	31/07/2023	22:09	01/08/2023	09:59	HT	H/T on overvoltage
JAIGAD - KARAD CKT - 2	IntraState	31/07/2023	22:40	01/08/2023	08:51	HT	H/T on overvoltage
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\epsilon Y \epsilon$ phase Protection CT Of NTPP I (RPL 1)
PARLI-SOLAPUR (LAMBOTI)	IntraState	01/08/2023	11:07	01/08/2023	19:28	EO	Flashover is observed on loc no-69 and loc no-140
MAIN BUS - 1 @ CHAKAN	IntraState	01/08/2023	15:19	01/08/2023	17:27	EO	For replacement of damaged hanger rod assembly of B Phase 89A 400KV PG isolator at 400KV Bus Coupler Bay.
PADGHE - PADGHE HVDC CKT- 1	IntraState	01/08/2023	17:03			PO	1.Replacement of old BHEL make Quad CB with new siemens Quad CB. 2.A & B Bus PG Isolator Maintenance work. 3.400KV HVDC-1 in service through TBC, Power restriction of 1300MW.
KHADKA-AURANGABAD (WALUJ)	IntraState	01/08/2023	22:15	02/08/2023	07:46	HT	H/T on overvoltage
JAIGAD - KARAD CKT - 1	IntraState	02/08/2023	00:00	02/08/2023	07:45	HT	H/T on overvoltage
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220/33 KV 167 MVA SPARE ICT @ KHAPARKHEDA	IntraState	14/07/2023	12:08			PO	Ongoing work of Rapid Restoration Scheme (RRS) For spare ICT
400/220/33 KV 500 MVA ICT - 3 @ DHULE	IntraState	31/07/2023	09:47	01/08/2023	18:12	PO	IPS tube errection & other pending work under RRS scheme for ICT-3
400/220KV 167 MVA SPARE ICT @ DHULE	IntraState	31/07/2023	10:03	01/08/2023	18:18	PO	IPS tube errection work of 400/220KV ICT-3 pending under RRS Scheme
STATION TF-3 @ KORADI 2	IntraState	01/08/2023	10:44			PO	1) Oil filtration & inspection work at PCR end 2) LV 1 & LV 2 Bus Duct inspection work at PCR end.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Aug/2023

Statement-VII

Position as on 6.30 Hrs of 02/Aug/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400/220/33 KV 315 MVA ICT - 2 @ WALUJ	IntraState	01/08/2023	11:56	01/08/2023	17:56	PO	1. CTR fire fighting system work for SCADA compatibility. 2. Routine Maintenance and diagnostic testing.
220 KV LINE Outages/Trippings							
EKLAHARE (OCR) - NAVASARI CKT - 2	IntraState	24/05/2023	09:21			HT	H/T to control line loading
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
TROMBAY - MULUND	IntraState	01/08/2023	05:02	01/08/2023	08:47	HT	Overhead Power Line Crossing between AP 59- AP 60 & 61-62 of existing Line.
TROMBAY - KALWA	IntraState	01/08/2023	05:03	01/08/2023	13:11	HT	Overhead Power Line Crossing between AP 59- AP 60 & 61-62 of existing Line.
NEW KOYNA - PEDAMBE	IntraState	01/08/2023	09:08	01/08/2023	11:18	EO	Y Phase breaker clamp Red hot attending work.
PETH- MUDSHINGI 1 LINE	IntraState	01/08/2023	10:02	01/08/2023	14:16	PO	Replacement Work of LMU & LMDU
NAGOTHANE - WADKHAL (GIS) CKT-2	IntraState	01/08/2023	10:12	01/08/2023	15:01	EO	Attending hot spot at wavetrap jumper at Wadkhal gantry
GHODBUNDER - MSETCL BOISAR	IntraState	01/08/2023	13:36	01/08/2023	19:39	PO	For the replacement of old hardwares at various critical locations.
BORIVALI - BOISAR II LINE	IntraState	01/08/2023	13:49	01/08/2023	19:41	PO	For the replacement of old hardwares at various critical locations.
GHODBUNDER - MSETCL BOISAR	IntraState	02/08/2023	07:43			PO	For the replacement of old hardwares at various critical locations.
BORIVALI - BOISAR II LINE	IntraState	02/08/2023	07:52			PO	For the replacement of old hardwares at various critical locations.
LONAND-BARAMATI	IntraState	02/08/2023	08:30			HT	For load management
LONAND - KANDALGAON (SONA ALLOY TAP)	IntraState	02/08/2023	08:46			PO	Replacement of Damaged conductor at cut point locations.
MUMEWADI -HALKARNI 2 LINE	IntraState	02/08/2023	09:13	02/08/2023	14:24	PO	For replacement of Puncture insulator
URAN - KHARGHAR 2	IntraState	02/08/2023	09:25			PO	OPGW stringing work by Project Dn Kalwa
TEMBHURNI - JEUR	IntraState	02/08/2023	10:40	02/08/2023	12:50	PO	Outage is required for Quarterly Maintenance
MAIN BUS @ TEMBHURNI	IntraState	02/08/2023	10:40	02/08/2023	12:50	PO	Outage is required for Quarterly Maintenance
220 KV ICT Outages/Trippings							
220 / 110 / 22kv 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/100 KV 100 MVA ICT 1 @ VASAI-II	IntraState	02/08/2023	07:05	02/08/2023	10:05	EO	To check & attend oil leakage from Top Plate of 220/100 KV 100 MVA ICT 1 @ VASAI-II.
220/132 KV 200 MVA ICT 1@ BALE(SOLAPUR)	IntraState	02/08/2023	10:47			PO	Outage is required for Quarterly Maintenance
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
132 KV LINE Outages/Trippings							
RISOD-YELDARI	IntraState	20/04/2023	17:57			HT	TO CONTROL LOADING ON RISOD - MALEGAON CKT
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
BHIVPURI - AMBERNATH CKT - 1	IntraState	02/08/2023	10:11	02/08/2023	12:35	PO	Tree trimming

