

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Sep/2023 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	146.921	146.921	1) Gujrat	7.495	7.495
2) Hydro	30.923	30.923	2) Madhya Pradesh	7.020	7.020
3) Gas	6.843	6.843	3) Chattisgarh	2.110	2.110
Total MSPGCL	184.687	184.687	4) Maharashtra	198.997	198.997
B) 1) APLM	61.354	61.354	5) Goa (Amona)	-1.669	-1.669
2) JSWEL	26.944	26.944	Total	213.953	213.953
3) VIPL	0.000	0.000	a) Mumbai Schedule	27.612	27.612
4) RPL(AMT)	25.660	25.660	b) Mumbai Drawl	33.776	33.776
5) SWPGPL	11.953	11.953	C) 1) TPCL Thermal	16.180	16.180
6) Other IPP	6.989	6.989	2) TPCL Hydro	7.175	7.175
7) PGPL	0.000	0.000	3) TPCL Gas	1.985	1.985
			4) AEML Thermal	11.537	11.537
D) STATE			c) MSEDCL Bilateral *	83.612	83.612
1) Thermal	307.538	307.538	Include PX	0.000	0.000
(A1+C1+C4+(B1-B6))			d) Mumbai Bilateral *	27.577	27.577
2) Hydro	38.098	38.098	Include PX	0.000	0.000
(A2+C2)			Standby	0.035	0.035
3) Gas	8.828	8.828	H) ENERGY CATERED (MUs)		
4) Wind	7.679	7.679	1) MSEDCL	510.031	510.031
6) SOLAR	15.175	15.175	2) Mumbai Discoms	70.653	70.653
			3) Other Discoms	10.587	10.587
TOTAL STATE	377.318	377.318	TOTAL STATE	591.271	591.271

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 12 Hrs	B. Day Peak at 15 Hrs	C. Evening Peak at 20 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6161	6112	6058	6007
MSPGCL Hydro	960	1517	1301	1096
MSPGCL Gas	281	279	285	289
MSPGCL Total Generation	7402	7908	7644	7392
Central Sector Receipt	10852	10075	7733	7240
WIND	116	69	510	507
CPP / IPP Thermal	5523	5550	5533	5562
CPP / IPP Gas	0	0	0	0
SOLAR	2064	1667	0	0
Exchange with Mumbai	-2021	-1886	-1407	-1083
MSEDCL DEMAND MET	23469	22927	19505	19219
Load Shedding	0	371	2742	419
MSEDCL DEMAND	23469	23298	22247	19638
TPCL GENERATION	1017	1033	1245	1057
AEML GENERATION	488	500	503	501
MUMBAI DEMAND	3526	3419	3155	2641
OTHER DISCOM DEMAND	467	456	508	399
STATE DEMAND MET	27462	26802	23168	22259
STATE DEMAND	27462	27173	25910	22678
Frequency (Hz)	50.00	49.80	49.94	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.12 Hz at 13:01 Hrs	49.52 Hz at 14:50 Hrs	49.95	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation, Maximum, Minimum for 01/Sep/2023

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.10	4.10	180	150
Unit 8	13.38	13.38	593	503
Unit 9	11.48	11.48	507	440
Unit 10	0.00	0.00	0	0
Total	28.96	28.96		
Bhusawal				
Unit 3	3.16	3.16	140	125
Unit 4	9.08	9.08	435	340
Unit 5	9.40	9.40	415	370
Total	21.63	21.63		
Parli				
Unit 6	4.92	4.92	238	177
Unit 7	4.75	4.75	220	147
Unit 8	4.49	4.49	198	166
Total	14.16	14.16		
Chandrapur				
Unit 3	3.59	3.59	168	130
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	8.05	8.05	355	315
Unit 7	6.43	6.43	315	231
Unit 8	10.12	10.12	456	385
Unit 9	10.69	10.69	489	410
Total	38.89	38.89		
Paras				
Unit 3	4.87	4.87	227	171
Unit 4	4.83	4.83	220	150
Total	9.70	9.70		
Khaparkheda				
Unit 1	3.01	3.01	155	110
Unit 2	2.51	2.51	119	80
Unit 3	3.81	3.81	170	143
Unit 4	3.93	3.93	177	150
Unit 5	10.78	10.78	460	442
Total	24.04	24.04		
Nasik				
Unit 3	2.22	2.22	130	0
Unit 4	3.64	3.64	159	145
Unit 5	3.67	3.67	164	145
Total	9.54	9.54		
Uran				
All Units	6.84	6.84	292	274
Total	6.84	6.84		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.05	1.05	50	22
Total	1.05	1.05		
Koyna				
Stage 1-2	5.09	5.09	375	30

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 4	15.42	15.42	759	401
Stage 3	4.38	4.38	240	80
Total	24.88	24.88		
Hydro				
KDPH	0.43	0.43	18	18
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.46	0.46	80	0
SMLHY_PTN	4.10	4.10	177	158
GHATGHAR	0.00	0.00	0	0
Total	4.99	4.99		
Wind				
Total	7.68	7.68	0	0
Total	7.68	7.68		
CPP				
APML(Mus)	61.35	61.35	0	0
JSWEL(Mus)	26.94	26.94	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.66	25.66	0	0
SWPGPL-Mus	11.95	11.95	0	0
Dhariwal	0.00	0.00	0	0
IEPL	6.17	6.17	259	255
Other(Mus)	0.82	0.82	0	0
Total	132.90	132.90		
SOLAR				
Total	15.18	15.18	0	0
Total	15.18	15.18		
Tata				
Trombay 5	10.61	10.61	453	402
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.07	1.07	83	37
Trombay 7B	0.91	0.91	56	34
TATA Hydro	7.18	7.18	443	169
Trombay 8	5.57	5.57	238	224
Total	25.34	25.34		
AEML				
DTPS U-1&2	11.54	11.54	503	390
Total	11.54	11.54		

* Infirm Power		
Particulars	Daily (Mus)	Monthly

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Thermal	146.92	146.92
MSPGCL Thml+Gas	153.76	153.76
MSPGCL Hydro	30.92	30.92

Summary		
Particulars	Daily (Mus)	Monthly (Mus)
MSPGCL Total	184.69	184.69
Koyna 1,2 & 4 Total	20.51	20.51
State Total	377.32	377.32

State Load Despatch Center, Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Sep/2023

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	Load Shedding		MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS						Planned	*Transmission Constraint					
1	6007	1096	289	7392	507	5562	0	0	7431	7240	-1083	19219	419	0	19638	2641	399	22678	49.98
2	5966	1244	291	7501	444	5590	0	0	7710	7871	-954	20107	41	0	20148	2449	345	22942	49.99
3	6028	1455	289	7772	343	5602	0	0	7822	7966	-844	20508	41	0	20549	2294	331	23174	49.97
4	6040	1496	290	7826	251	5571	0	0	7993	8363	-819	20840	126	0	20966	2206	352	23524	49.98
5	6048	1487	290	7825	261	5574	0	0	8154	8475	-828	20952	655	0	21607	2183	355	24145	49.95
6	6061	1563	290	7914	269	5563	0	0	8338	8531	-848	21056	2142	0	23198	2287	373	25858	49.96
7	6152	1521	292	7965	220	5540	0	82	8041	8076	-977	20489	1967	0	22456	2432	417	25305	49.98
8	6191	1312	290	7793	174	5521	0	470	8848	8910	-1182	21252	226	0	21478	2607	434	24519	50.03
9	6163	1000	287	7450	187	5504	0	1105	9952	9935	-1552	22163	0	0	22163	2926	466	25555	50.04
10	6204	856	289	7349	188	5500	0	1564	10408	10335	-1863	22608	0	0	22608	3243	465	26316	50.01
11	6248	1096	282	7626	174	5508	0	1930	10303	10231	-1993	22997	0	0	22997	3458	479	26934	50.04
12	6161	960	281	7402	116	5523	0	2064	10848	10852	-2021	23469	0	0	23469	3526	467	27462	50.00
13	6203	790	280	7273	68	5500	0	1958	10824	10638	-2049	22930	0	0	22930	3492	458	26880	50.00
14	6180	975	278	7433	62	5546	0	1929	10336	10113	-1899	22735	0	0	22735	3362	449	26546	50.01
15	6112	1517	279	7908	69	5550	0	1667	9865	10075	-1886	22927	371	0	23298	3419	456	27173	49.80
16	6067	1589	274	7930	126	5545	0	1228	9760	9620	-1857	22122	854	0	22976	3473	470	26919	49.79
17	6106	1360	279	7745	180	5544	0	788	9331	9204	-1733	21242	1116	0	22358	3418	486	26262	49.92
18	6064	1329	280	7673	193	5543	0	360	8935	8790	-1614	20445	1044	0	21489	3319	500	25308	49.94
19	6041	1623	281	7945	276	5530	0	30	8524	8625	-1440	20439	1701	0	22140	3184	527	25851	49.76
20	6058	1301	285	7644	510	5533	0	0	8356	7733	-1407	19505	2742	0	22247	3155	508	25910	49.94
21	6138	1165	286	7589	716	5532	0	0	8252	8166	-1298	20204	988	0	21192	3030	501	24723	49.99
22	6194	1214	284	7692	776	5523	0	0	8187	8023	-1235	20320	655	0	20975	2904	459	24338	49.98
23	6289	1430	288	8007	814	5501	0	0	7944	8203	-1208	20855	160	0	21015	2838	462	24315	49.87
24	6200	1544	289	8033	755	5495	0	0	7718	7978	-1186	20648	551	0	21199	2807	427	24433	49.97
MUs	146.92	30.92	6.84	184.69	7.68	132.90	0.00	15.18	213.88	213.95	-33.78	510.03	15.80	0.00	525.83	70.65	10.59	607.07	49.95

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

*Load Shedding due to Transmission Constraint :-

State Load Despatch Center, Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Sep/2023

Position as on 6.30 Hrs of 02/Sep/2023

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Uran Unit 5	108	12/11/2022	13:23		Continued.	Major overhaul.	05/10/2023
MSPGCL	Chandrapur Unit 5	500	22/05/2023	19:00		Continued.	Stator Earth Fault(converted to Capital overhaul from 00.00Hrs DT.27-07-2023)	13/09/2023
MSPGCL	Koyna STG-IV Unit-1	250	05/06/2023	16:30		Continued.	Annual Overhaul	18/09/2023
MSPGCL	Koyna Unit 11	80	10/07/2023	09:40		Continued.	COH	07/12/2023
MSPGCL	Koradi Unit-10	660	11/07/2023	00:45		Continued.	Capital Overhaul.	07/09/2023
MSPGCL	Koyna Unit 8	80	11/07/2023	08:05		Continued.	COH	23/09/2023
MSPGCL	Chandrapur Unit 4	210	27/07/2023	03:00		Continued.	OVERHAUL	05/09/2023
IPP	Adani U-4	660	12/08/2023	23:44		Continued.	Annual Overhaul	05/09/2023
FORCED OUTAGE								
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	01/04/2024
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	01/05/2024
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	08/11/2023
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	31/03/2024
MSPGCL	Koyna Unit 7	80	13/08/2023	09:00		Continued.	Spherical Valve maintenance	10/09/2023
IPP	RPL(AMT) U-4	270	22/08/2023	18:46		Continued.	Generator Stator Earth Fault	01/10/2023
MSPGCL	Nasik Unit 3	210	31/08/2023	14:50	01/09/2023	02:30	BOTH EMERGENCY LIFT PUMP TRIPPED	
MSPGCL	Uran Unit 6	108	31/08/2023	23:56	02/09/2023	01:32	Gas shortage	
MSPGCL	Koyna STG-IV Unit-2	250	02/09/2023	00:27	02/09/2023	02:10	Main cooling water level low	
MSPGCL	Koyna STG-IV Unit-4	250	02/09/2023	00:27	02/09/2023	01:05	Main cooling water level low	
MSPGCL	Koyna STG-IV Unit-3	250	02/09/2023	00:27	02/09/2023	01:00	Main cooling water level low	
MSPGCL	Uran Unit 6	108	02/09/2023	07:16		Continued.	Gas shortage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 02/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
400 KV MAINBAY Outages/Trippings							
MAIN BAY (401) OF ICT - 1 @ KORADI 3	IntraState	01/09/2023	09:37	01/09/2023	19:41	HT	Annual maintenance of CB
400 KV LINE Outages/Trippings							
400KV-PARLI NEW-PARLI-M-1	InterState	19/08/2023	22:49			PO	For reconductoring
KOLHAPUR - SOLAPUR (PG) CKT - 2	InterState	01/09/2023	15:25	01/09/2023	22:48	PO	Line terminal equipments AMP at 765kV Solapur Substation.
CHAKAN - TALEGAON(PG)	InterState	02/09/2023	01:01	02/09/2023	07:39	T	Tripped on Distance protection.
BABHALESHWAR - RPL(NSK) CKT - 1	IntraState	01/08/2023	09:21			EO	For attending Oil Leakage Problem of $\Delta Y \Delta$ phase Protection CT Of NTPP I (RPL 1)
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	24/08/2023	06:20		Continued.	HT	H/T to control loading
KHADKA-AURANGABAD (WALUJ)	IntraState	31/08/2023	11:24	01/09/2023	10:30	PO	1) Installation of new Digital LA Monitoring Device. 2) Routine Maintenance and Diagnostic Testing work.
EKTUNI - BABLESHWAR CKT - 1	IntraState	01/09/2023	12:52	01/09/2023	18:29	PO	Main I/II relay testing;CB DCRM and timing and bay maintenance work
KHADKA-AURANGABAD (WALUJ)	IntraState	01/09/2023	19:41	02/09/2023	08:20	HT	HAND TRIPPED TO CONTROL OVER VOLTAGE
MAIN BUS - 2 @ LONIKAND 2	IntraState	02/09/2023	12:15	02/09/2023	18:45	PO	RRS Jumpering work
PADGHE - KALWA CKT - 1	IntraState	02/09/2023	23:24	02/09/2023	02:31	HT	Emergency Outage for attending hotspot
400 KV ICT Outages/Trippings							
STATION TF No 3 @ CHANDRAPUR GCR	IntraState	01/03/2023	15:07			PO	1) Oil filtration work 2) Testing of Station transformer 3) Preventive maintenance work.
400/220 KV 500MVA ICT - 4 @ KALWA	IntraState	02/09/2023	05:20	02/09/2023	08:51	PO	LV CT (all phase) clamp replacement work.
400/220 KV 167MVA SPARE ICT @ LONIKAND 2	IntraState	02/09/2023	12:15	02/09/2023	18:51	PO	RRS Jumpering work.
220 KV MAINBAY Outages/Trippings							
220KV BUS SECTION 1	IntraState	01/09/2023	11:25	01/09/2023	23:08	PO	Making temp. overhead bus jumpering work for erection of 220kv Hybrid GIS
220 KV LINE Outages/Trippings							
PARLI (OLD GCR) - PARLY (PG) CKT 1	InterState	01/09/2023	19:04	01/09/2023	21:44	HT	HAND TRIPPED TO CONTROL OVER DRAWAL
EKLAHARE (OCR) - PADGHE	IntraState	22/07/2023	21:09			HT	As per usual practice line is H/T
AAREY - MSETCL BORIVALI CKT - 2	IntraState	15/08/2023	06:02			T	Tripped on Distance Protection
GOREGAON - AAREY CKT - 2	IntraState	19/08/2023	07:13			PO	Outage proposed for bunching of 220kV Aarey-AEML Borivali Line (which is under outage) with 220kV Aarey-Goregaon Line-2. Work to be executed under MERC approved Aarey AIS to GIS project conversion scheme.
TROMBAY - SALSETTE CKT - 1	IntraState	31/08/2023	23:12	01/09/2023	07:29	PO	A-Ph conductor replacement in view of annealing AND R/M
URAN - KHARGHAR 2	IntraState	01/09/2023	08:09	01/09/2023	14:15	PO	For Removing of bunching at Loc. No. 88 & 89 for restoration of Uran - Kharghar Ckt. II.

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 02/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
HINJAWADI I- CHINCHWAD	IntraState	01/09/2023	08:36	01/09/2023	20:00	PO	On. 30.08.23 Conductor paying out & Final sag (Location 161 to 161 A) ∩ Circuit II ∩ Top circuit On. 31.08.23 Conductor paying out & Final sag (Location 161 to 161 A) ∩ circuit ∩ I ∩ Bottom Circuit On. 01.09.23 Conductor paying out & Final sag (Location 161 to 161 A) ∩ Circuit II ∩ Bottom Circuit
WALUJ - CHITEGAON I	IntraState	01/09/2023	09:36	01/09/2023	23:21	PO	Diagnostic testing CT Tan delta will be carried out.
BABLESHWAR -BHENDA	IntraState	01/09/2023	09:55	01/09/2023	17:36	PO	Replacement of damage conductor observed while patrolling of the line by LMSD BBLR employees between loc no 99 and 100 B ph.
CHITEGAON- CHITEPIMPALGAON (PG) CKT - 2	IntraState	01/09/2023	11:04	01/09/2023	23:08	PO	Outage required for taking outage on 220kV Bus section 1
BUS - A @ PADGHE	IntraState	01/09/2023	12:18	01/09/2023	15:53	PO	Partial A Bus Outage in upper section for replacement of B phase conductor of HBB Pass due to broken
MIRAJ - MHAISHAL	IntraState	01/09/2023	13:00	01/09/2023	16:48	PO	Y & B Ph CT Replacement Work
BHUGAON - WARDHA (PG)	IntraState	01/09/2023	14:35	01/09/2023	22:27	HT	HAND TRIPPED TO CONTROL OVER DRAWAL
WARDHA - WARDHA (PG)	IntraState	01/09/2023	14:36	01/09/2023	22:26	HT	HAND TRIPPED TO CONTROL OVER DRAWAL BY WRDC
SHENDRA - CHITTEPIMPALGAON (PG) CKT - 2	IntraState	01/09/2023	15:40	01/09/2023	21:04	HT	HAND TRIPPED TO CONTROL OVER DRAWAL
BHANDARA-SUNFLAG 2	IntraState	02/09/2023	10:18	02/09/2023	17:12	PO	Routine Maintenance work
BELEWADI - MUMEWADI LINE	IntraState	02/09/2023	10:33	02/09/2023	13:14	PO	For Diagnostic Testing of CB & Maintenance work of bay equipments
BIDRI - SAWANTWADI	IntraState	02/09/2023	12:05	02/09/2023	15:06	PO	For 220kV Bidri-Sawantwadi Line Bay LMU replacement work
BOMBAY DYEING - SAHARA	IntraState	02/09/2023	12:50	02/09/2023	19:26	PO	For OPGW installation work between T. No .111 to T. No .114 . The existing earth wire is missing in this section.
HAMIDWADA - MUMEWADI	IntraState	02/09/2023	14:24	02/09/2023	18:42	PO	For Diagnostic Testing of CB & Maintenance work of bay equipments
CHALISGAON -KOPARGAON	IntraState	02/09/2023	16:24	02/09/2023	19:34	PO	Replacement of Flash over Disc
CHALISGAON -KOPARGAON	IntraState	02/09/2023	16:24	02/09/2023	19:35	PO	To attain following work. 1)For replace the flash over disc at cut point tower Loc No. 69 Yph & 77 R ph
220 KV PARLI (OLD GCR)- GIRWALI (400 KV) CKT 4	IntraState	02/09/2023	17:01	02/09/2023	19:24	EO	To attend Hot Spot
AAREY - MSETCL BORIVALI CKT - 1	IntraState	02/09/2023	23:26		Continued.	HT	Emergency Outage for testing of CKT 2
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 200MVA ICT 6 @ EKLHARE (GCR)	IntraState	01/09/2023	10:17	01/09/2023	14:15	PO	CTR maintenance and trial work also general bay maintenance.
100 MVA 220/132 KV ICT 2	IntraState	01/09/2023	11:05	01/09/2023	17:17	PO	Bushing, Winding & HV-LV CT Tan delta test.
220/132KV 200MVA PTR 2 @ LONAND	IntraState	01/09/2023	11:07	01/09/2023	15:32	PO	TBC Wiring & Testing Work
220/132 KV 100 MVA ICT 2	IntraState	01/09/2023	13:54	01/09/2023	17:50	PO	SFRA and DFR Testing work.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Sep/2023

Statement-VII

Position as on 6.30 Hrs of 02/Sep/2023

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/22-22 KV 50 MVA PTR 3 @ ANANDNAGAR	IntraState	01/09/2023	16:00	01/09/2023	18:52	PO	For Oil Leakage inspection work
220/132 KV 200 MVA ICT 2 @ AMALNER	IntraState	02/09/2023	06:20	02/09/2023	10:56	PO	Testing work
220 / 110 / 33kv 250MVA ICT 8 @ DHARAVI	IntraState	02/09/2023	10:08	02/09/2023	20:15	PO	220KV breaker will kept out between 0800 and 1700 hrs for CSD installation. ICT will be taken out in betwenn 1700 and 2300 hrs.
220 KV BUSBAR Outages/Trippings							
220KV AUXILLARY BUS @ BAMBHORI	IntraState	26/07/2023	15:03			T	Avoid mal operation of Aux bus zone, Blocking of busbar relay for aux bus zone is required.
MAIN BUS - 1 @ PHALTAN MIDC-220 KV	IntraState	30/08/2023	11:34	02/09/2023	17:42	PO	220kV Bus PT Extension Work
110 KV LINE Outages/Trippings							
SALSETTE POWAI	IntraState	27/03/2023	11:04			PO	Replacement of tower number 77 & 78 for TDS project work.
BHIRA (T) - KHOPOLI 2	IntraState	01/09/2023	09:42	01/09/2023	10:48	PO	TREE TRIMMING
TATA AMBERNATH MSETCL NERAL	IntraState	01/09/2023	11:05	01/09/2023	15:52	PO	TREE TRIMMING

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage