

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Nov/2019 FRIDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	79.024	79.024	1) Gujrat	3.496	3.496
2) Hydro	5.274	5.274	2) Madhya Pradesh	3.370	3.370
3) Gas	12.443	12.443	3) Chattisgarh	6.580	6.580
Total MSPGCL	96.741	96.741	4) Maharashtra	107.384	107.384
B) 1) APMIL	67.074	67.074	5) Goa (Amona)	-0.660	-0.660
2) JSWEL	18.990	18.990	Total	120.170	120.170
3) VIPL	0.000	0.000	a) Mumbai Schedule	24.428	24.428
4) RPL(AMT)	0.000	0.000	b) Mumbai Drawl	33.844	33.844
5) WPCL	0.000	0.000	c) MSEDCL Bilateral *	15.805	15.805
6) Other IPP	7.577	7.577	Include PX	0.032	0.032
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	24.428	24.428
C) 1) TPCL Thermal	12.392	12.392	Include PX	9.835	9.835
2) TPCL Hydro	4.969	4.969	Standby	0.000	0.000
3) TPCL Gas	4.241	4.241	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.170	7.170	1) MSEDCL	301.421	301.421
D) STATE			2) Mumbai Discoms	62.616	62.616
1) Thermal	192.227	192.227	TOTAL STATE	364.037	364.037
(A1+C1+C4+(B1-B6))					
2) Hydro	10.243	10.243			
(A2+C2)					
3) Gas	16.684	16.684			
(A3+B7+C3)					
4) Wind	21.423	21.423			
6) SOLAR	3.290	3.290			
TOTAL STATE	243.867	243.867			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 10 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 4 Hrs
MSPGCL Thermal	3276	3311	3619	3147
MSPGCL Hydro	295	93	910	81
MSPGCL Gas	503	501	518	517
MSPGCL Total Generation	4074	3905	5047	3745
Central Sector Receipt	6071	5574	5098	3626
WIND	1007	730	327	1324
CPP / IPP Thermal	3705	3655	4634	3668
CPP / IPP Gas	0	0	0	0
SOLAR	341	515	0	0
Exchange with Mumbai	-1623	-1876	-1204	-1150
MSEDCL DEMAND MET	13575	12503	13902	11213
Load Shedding	0	0	0	0
MSEDCL DEMAND	13575	12503	13902	11213
TPCL GENERATION	1046	919	1217	669
AEML GENERATION	196	350	486	191
MUMBAI DEMAND	2865	3145	2907	2010
STATE DEMAND MET	16440	15648	16809	13223
STATE DEMAND	16440	15648	16809	13223
Frequency (Hz)	49.97	50.03	49.88	49.98

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.2 Hz
50.24 Hz at 03.01 Hrs	49.68 Hz at 17.39 Hrs	49.97	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Shift Engineer

Shift Incharge

Daily and Progressive Generation,Maximum,Minimum for 01/Nov/2019

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	10.56	10.56	480	241
Unit 9	11.23	11.23	550	450
Unit 10	10.22	10.22	480	333
Total	32.01	32.01		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.56	8.56	370	345
Unit 5	8.56	8.56	390	345
Total	17.12	17.12		
Parli				
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	0.00	0.00	0	0
Total	0.00	0.00		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	0.00	0.00	0	0
Unit 6	0.00	0.00	0	0
Unit 7	0.00	0.00	0	0
Unit 8	8.74	8.74	420	360
Unit 9	8.54	8.54	402	302
Total	17.28	17.28		
Paras				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Total	0.00	0.00		
Khaparkheda				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	9.09	9.09	465	365
Total	9.09	9.09		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	0.00	0.00	0	0
Unit 5	3.52	3.52	160	130
Total	3.52	3.52		
Uran				
All Units	12.44	12.44	538	501
Total	12.44	12.44		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.96	0.96	54	19

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Total	0.96	0.96		
Koyna				
Stage 1-2	2.22	2.22	215	30
Stage 4	0.49	0.49	342	0
Stage 3	1.07	1.07	160	0
Total	3.78	3.78		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.24	0.24	60	0
BHTGR/VEER	0.00	0.00	0	0
BHIRA T.R.	0.34	0.34	80	0
RNGR+BHTSA	0.35	0.35	15	14
BHANDARDRA	0.00	0.00	0	0
ELDARY	0.00	0.00	0	0
SMLHY_PTN	0.36	0.36	16	14
GHATGHAR	0.22	0.22	125	0
Total	1.50	1.50		
Wind				
Total	21.42	21.42	0	0
Total	21.42	21.42		
CPP				
APML(Mus)	67.07	67.07	0	0
JSWEL(Mus)	18.99	18.99	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT(Mus)	0.00	0.00	0	0
WPCL(Mus)	0.00	0.00	0	0
Other(Mus)	7.58	7.58	0	0
Total	93.64	93.64		
SOLAR				
Total	3.29	3.29	0	0
Total	3.29	3.29		
Tata				
Trombay 5	7.67	7.67	421	304
Trombay 6	0.00	0.00	0	0
Trombay 7A	2.69	2.69	117	102
Trombay 7B	1.55	1.55	66	62
Trombay 8	4.72	4.72	198	195
TATA Hydro	4.97	4.97	435	0
Total	21.60	21.60		
AEML				
DTPS U-1&2	7.17	7.17	486	191
Total	7.17	7.17		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	79.02	79.02	MSPGCL Total	96.74	96.74
			MSPGCL Thml+Gas	91.47	91.47	Koyna 1,2 & 4 Total	2.71	2.71
			MSPGCL Hydro	5.27	5.27	State Total	243.87	243.87

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Nov/2019

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDCL DEM. MET	LOAD SHEDDI NG	MSEDCL DEM. WITH LS	MUMBAI DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS										
1	3050	75	529	3654	1362	3664	0	0	4663	4506	-1450	11736	0	11736	2399	14135	50.01
2	3101	70	528	3699	1368	3682	0	0	4091	3908	-1341	11316	0	11316	2216	13532	50.01
3	3134	70	517	3721	1399	3688	0	0	3543	3627	-1232	11203	0	11203	2093	13296	49.97
4	3147	81	517	3745	1324	3668	0	0	3492	3626	-1150	11213	0	11213	2010	13223	49.98
5	3163	160	518	3841	1374	3673	0	0	3819	3997	-1113	11772	0	11772	1972	13744	49.95
6	3201	150	528	3879	1229	3693	0	0	4584	4984	-1146	12639	0	12639	2024	14663	49.94
7	3220	231	518	3969	1236	4001	0	6	4969	5195	-1149	13258	0	13258	2078	15336	50.01
8	3236	145	517	3898	1206	4271	0	89	5114	5285	-1184	13565	0	13565	2244	15809	50.03
9	3244	90	504	3838	1076	4047	0	242	5595	6100	-1500	13803	0	13803	2545	16348	50.02
10	3276	295	503	4074	1007	3705	0	341	5799	6071	-1623	13575	0	13575	2865	16440	49.97
11	3325	159	504	3988	1012	3655	0	423	6105	5991	-1957	13112	0	13112	3080	16192	49.93
12	3321	129	509	3959	857	3646	0	533	5958	5803	-1957	12841	0	12841	3185	16026	49.97
13	3311	93	501	3905	730	3655	0	515	5425	5574	-1876	12503	0	12503	3145	15648	50.03
14	3323	79	520	3922	660	3643	0	436	5246	5198	-1721	12138	0	12138	3024	15162	50.03
15	3333	233	513	4079	546	3647	0	332	5194	5396	-1729	12271	0	12271	3057	15328	49.95
16	3326	219	515	4060	491	3642	0	236	5550	5443	-1735	12137	0	12137	3086	15223	50.01
17	3328	203	528	4059	352	3827	0	105	5536	5299	-1534	12108	0	12108	3008	15116	49.96
18	3392	397	517	4306	279	4058	0	32	5273	5341	-1409	12607	0	12607	2912	15519	49.87
19	3619	910	518	5047	327	4634	0	0	5296	5098	-1204	13902	0	13902	2907	16809	49.88
20	3624	464	538	4626	518	4792	0	0	5279	5103	-1065	13974	0	13974	2782	16756	49.99
21	3376	228	526	4130	735	4335	0	0	5058	4924	-1143	12981	0	12981	2656	15637	49.95
22	3312	329	529	4170	833	4177	0	0	4692	4811	-1201	12790	0	12790	2531	15321	49.94
23	3347	210	528	4085	781	3964	0	0	4741	4500	-1237	12093	0	12093	2461	14554	49.91
24	3315	254	518	4087	721	3874	0	0	4403	4390	-1188	11884	0	11884	2336	14220	49.94
MUs	79.02	5.27	12.44	96.74	21.42	93.64	0.00	3.29	119.42	120.17	-33.84	301.42	0.00	301.42	62.62	364.04	49.97

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Nov/2019

Position as on 6.30 Hrs of 02/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
CPP	SWPGL U-3	135	01/11/2018	00.28		Continued.	Annual Overhaul	
MSPGCL	Chandrapur Unit 7	500	27/07/2019	00.00		Continued.	Annual Overhaul	
MSPGCL	Ghatghar Unit-1	125	25/09/2019	04.20		Continued.	Withdrawn On Shaft Seal Water Leakage.Converted to AOH From 1 Nov 2019.	
MSPGCL	Koyna Unit 7	80	31/10/2019	16.30		Continued.	Turbine Vibration(converted to Capital Overhaul for 60 Days from 09.00Hrs DT.01-11-2019)	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
MSPGCL	Parli Unit 5	210	01/04/2016	00.00		Continued.	Economic shutdown	
MSPGCL	Parli Unit 4	210	01/04/2016	00.00		Continued.	Economic shutdown	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	SWPGL U-2	135	27/11/2018	00.00		Continued.	No Schedule.	
CPP	SWPGL U-4	135	15/12/2018	00.00		Continued.	No Schedule	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	25/08/2019	00.45		Continued.	Annual Overhaul Converted Zero Schedule From 28.10.2019 18.00	
MSPGCL	Koradi Unit 7	210	27/08/2019	09.52		Continued.	Coal Flow Problem Due To Wet Coal.(Converted To Zero Schedule From 12.09.2019 At 20.00 hrs)	
IPP	RPL(AMT) U-1	270	01/09/2019	09.11		Continued.	Generator Protection operated	
MSPGCL	Bhusawal Unit 3	210	01/09/2019	17.56		Continued.	Zero Schedule from 18:00hrs of 28/09/2019	
MSPGCL	Koradi Unit 6	210	06/09/2019	15.41		Continued.	Zero Schedule By MSEDCL	
AEML	AEML Unit 2	250	07/10/2019	21.18	01/11/2019	10.15	Coal Shortage	
MSPGCL	Nasik Unit 3	210	09/10/2019	23.57		Continued.	Under Case 4 Bidding.	
MSPGCL	Nasik Unit 4	210	09/10/2019	23.59	02/11/2019	23.48	Zero schedule.	
MSPGCL	Khaparkhedha Unit 1	210	12/10/2019	00.11		Continued.	Zero Schedule	
MSPGCL	Khaparkhedha Unit 2	210	12/10/2019	00.17		Continued.	Zero Schedule	
MSPGCL	Khaparkhedha Unit 3	210	13/10/2019	19.57		Continued.	Zero Schedule	
MSPGCL	Parli Unit 8	250	16/10/2019	01.36		Continued.	Flame Failure (Converted To Zero Schedule DT.23.10.2019 18.00.hrs)	
MSPGCL	Khaparkhedha Unit 4	210	22/10/2019	23.52		Continued.	Zero Schedule By MSEDCL.	
MSPGCL	Paras Unit 3	250	23/10/2019	00.00		Continued.	Zero Schedule	
MSPGCL	Parli Unit 6	250	23/10/2019	03.30		Continued.	Zero Schedule By MSEDCL.	

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Nov/2019

Position as on 6.30 Hrs of 02/Nov/2019

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Parli Unit 7	250	23/10/2019	17.00		Continued.	Zero Schedule.	
MSPGCL	Chandrapur Unit 5	500	25/10/2019	01.03		Continued.	Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).	
MSPGCL	Chandrapur Unit 3	210	25/10/2019	01.03		Continued.	Bus-1 LBB Operation (Converted into zero schedule 26.10.2019 at 00.23Hrs).	
IPP	RPL(AMT) U-3	270	25/10/2019	02.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-2	270	25/10/2019	22.00		Continued.	Zero Schedule By MSEDCL.	
IPP	RPL(AMT) U-5	270	26/10/2019	00.30		Continued.	Zero Schedule	
IPP	RPL(AMT) U-4	270	26/10/2019	08.00		Continued.	Zero Schedule	
MSPGCL	Chandrapur Unit 6	500	26/10/2019	21.52		Continued.	Zero Schedule	
MSPGCL	Chandrapur Unit 4	210	31/10/2019	08.16		Continued.	Excessive Consumption of Hydrogen Cylinder.	
MSPGCL	Koyna Unit 3	70	01/11/2019	07.55		Continued.	Injector No 1 Replacement	
MSPGCL	Koyna Unit 4	70	01/11/2019	08.05		Continued.	Injector No 1 Replacement	
MSPGCL	Uran Unit 8	108	02/11/2019	01.16	02/11/2019	18.35	Gas shortage	
MSPGCL	Khaparkheda Unit 5	500	02/11/2019	10.21		Continued.	Boiler Tube Leakage	
MSPGCL	Nasik Unit 5	210	02/11/2019	10.35		Continued.	Boiler Tube Leakage(Converted to Zero Schedule from 19.05Hrs DT.03-11-2019)	
MSPGCL	Uran Unit 8	108	02/11/2019	19.56		Continued.	Gas shortage	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 02/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
Chandrapur - Padghe HvdC Pole 2	IntraState	02/11/2019	16.14	02/11/2019	17.21	EO	Relay Testing Work.
400 KV LINE Outages/Trippings							
Karad Solapur (PG)	InterState	03/05/2017	11:49		Continued.	PO	Line Converted As 220 Kv Solapur (PG)- Jeur From LOC 403
Dhule Sar'Sarovar I	InterState	19/10/2019	23.13		Continued.	HT	Over Voltage
Dhule Khandwa I	InterState	21/10/2019	22.06	02/11/2019	09.40	HT	Over Voltage
Padgha Tarapur I	InterState	02/11/2019	03.38	02/11/2019	08.25	T	DT Recived At Padgha,Main Bus Protection Operated At Tarapur End.
Kolhapur Solapur (PG) II	InterState	02/11/2019	11.47	02/11/2019	13.01	T	During Transfer From TBC To Main. Taken On Main Bus.
Dhule Khandwa II	InterState	02/11/2019	13.42		Continued.	HT	Over Voltage
Jaigad-Karad Ckt-I	IntraState	19/10/2019	03.20		Continued.	HT	Over Voltage
Chandrapur-II - Nanded ckt II	IntraState	25/10/2019	03.15		Continued.	T	Over Voltage
Chandrapur - Parli	IntraState	26/10/2019	05.58		Continued.	T	Distance Protection (RFC from 26.10.2019 23:14Hrs).
Khadka-Aurangabad (Waluj)	IntraState	26/10/2019	14.55	02/11/2019	11.28	HT	Over Voltage
karad -kolhapur-II	IntraState	26/10/2019	22.52	02/11/2019	11.05	HT	Over Voltage
Akola II - RPL(Rattanindia) Ckt I	IntraState	27/10/2019	14.07		Continued.	HT	Over Voltage
Lonikand I - Koyna stage-IV	IntraState	31/10/2019	22.19	01/11/2019	09.02	HT	Over Voltage
Aurangabad - Aurangabad(PG) I	IntraState	02/11/2019	10.20	02/11/2019	18.01	HT	Rectification Of Transfer Bus On Waluj.
Khadka-Aurangabad (Waluj)	IntraState	02/11/2019	18.06		Continued.	HT	Over Voltage
400 KV ICT Outages/Trippings							
400/220/33 Kv 315 Mva ICT 1 @Padghe	IntraState	15/11/2018	10.07		Continued.	T	Differential Protection, Declared Faulty.
400/220/33 Kv 500 Mva Ict 1 @ CHANDRAPUR 2	IntraState	12/04/2019	17.10		Continued.	HT	Due To CVT Porcelain Collars Of The ICT-1 are Damaged.
500MVA ICT III @ Dhule	IntraState	01/11/2019	09.20	01/11/2019	13.25	PO	Routine Maintenance Work & Testing Work.
220 KV LINE Outages/Trippings							
Mudshingi Chikodi	InterState	24/09/2019	17.12		Continued.	PO	No Schedule.(close at Mudshingi end only)
Talandage - Chikodi	InterState	01/10/2019	17.10		Continued.	PO	No Schedule.(close at Chikodi end only)
EKLAHARE (OCR) Nasik - Navsari I	InterState	27/10/2019	17.53	01/11/2019	09.54	HT	Over Voltage
BOISAR BORIVALI	IntraState	24/07/2018	13.18		Continued.	HT	To Control Line Loading(H/T from Boisar end)
Trombay Dharavi 9	IntraState	23/10/2019	08.50	01/11/2019	14.42	PO	Erection Of Tower LoC.I No.23
Ranjangaon-Lonikand	IntraState	31/10/2019	15.29		Continued.	PO	Tower jumps opened.
Ranjangaon-Fiat 1	IntraState	01/11/2019	08.50	01/11/2019	20.30	PO	Yard Annual Maintenance,NOC Received From Consumer.
Ranjangaon-Fiat 2	IntraState	01/11/2019	08.50	01/11/2019	20.30	PO	Yard Annual Maintenance,NOC Received From Consumer.
Padghe - Jambhul 1	IntraState	01/11/2019	08.52	01/11/2019	18.37	PO	Aux Bus Isolator.
Pophali - Pedambe II	IntraState	01/11/2019	09.40	01/11/2019	10.25	EO	B-PH CB POLE gas Top Up.
Nagothane-Wadkhal II	IntraState	01/11/2019	09.54	02/11/2019	01.57	PO	Routine Maintenance Work
Khadka-Chalisgaon-2	IntraState	01/11/2019	10.29	01/11/2019	14.08	EO	To attend Hot Spot
Pophli Pedhmbe Line- 1	IntraState	01/11/2019	10.30	01/11/2019	11.45	EO	R & B-PH CB POLE gas Top Up.
Colourchem - Temghar	IntraState	01/11/2019	11.54	01/11/2019	17.36	PO	For Fascilating Outage On Temghar Bus section 1&3.
Padgha - Temghar I	IntraState	01/11/2019	12.04	01/11/2019	17.35	PO	For Fascilating Outage On Temghar Bus section 1&3.
Trombay - Kalwa	IntraState	01/11/2019	20.08	02/11/2019	14.11	PO	Pilling Work.

HT : Hand Tripping, MT : Multiple Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage, OO : Opportunity Outage

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Nov/2019

Statement-VII

Position as on 6.30 Hrs of 02/Nov/2019

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
Karad - Vita Ckt- II	IntraState	02/11/2019	09.40	02/11/2019	12.32	PO	C And Tan Delta Testing Work.
Chinchwad-Hinjewadi I	IntraState	02/11/2019	09.40	02/11/2019	18.01	PO	To Control Line Loading For Bhosari Main Bus 1 outage.
Trombay-Salsette II	IntraState	02/11/2019	10.10	02/11/2019	16.10	PO	For 29 C God O/H.
Jejuri (400 Kv)- Baramati li	IntraState	02/11/2019	10.23	02/11/2019	17.36	PO	Jumper And Nut Bolt Tighting.
Karad - Vita Ckt- II	IntraState	02/11/2019	14.30	02/11/2019	16.26	PO	C Tan Delta Testing Work.
Parly-Parly Extn-I	IntraState	02/11/2019	14.40	02/11/2019	17.40	EO	Attending Hot Spot
Sonkhar - Trombay	IntraState	02/11/2019	15.37	02/11/2019	20.15	PO	Jumper Replacment Work.
Trombay - Kalwa	IntraState	02/11/2019	20.24		Continued.	PO	Pilling Work.