

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Nov/2022 TUESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	143.897	143.897	1) Gujrat	-8.873	-8.873
2) Hydro	7.187	7.187	2) Madhya Pradesh	0.141	0.141
3) Gas	2.218	2.218	3) Chattisgarh	5.960	5.960
Total MSPGCL	153.302	153.302	4) Maharashtra	155.414	155.414
B) 1) APMIL	52.739	52.739	5) Goa (Amona)	-1.483	-1.483
2) JSWEL	12.672	12.672	Total	151.159	151.159
3) VIPL	0.000	0.000	a) Mumbai Schedule	31.851	31.851
4) RPL(AMT)	25.580	25.580	b) Mumbai Drawl	35.594	35.594
5) SWPGPL	5.352	5.352	c) MSEDCL Bilateral *	63.717	63.717
6) Other IPP	23.078	23.078	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	31.851	31.851
C) 1) TPCL Thermal	9.982	9.982	Include PX	0.000	0.000
2) TPCL Hydro	3.710	3.710	Standby	0.000	0.000
3) TPCL Gas	2.437	2.437	H) ENERGY CATERED (MUs)		
4) AEML Thermal	7.944	7.944	1) MSEDCL	400.398	400.398
D) STATE			2) Mumbai Discoms	59.667	59.667
1) Thermal	281.244	281.244	3) Other Discoms	9.469	9.469
(A1+C1+C4+(B1-B6))			TOTAL STATE	469.534	469.534
2) Hydro (A2+C2)	10.897	10.897			
3) Gas (A3+B7+C3)	4.655	4.655			
4) Wind	9.095	9.095			
6) SOLAR	12.484	12.484			
TOTAL STATE	318.375	318.375			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 16 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 1 Hrs
MSPGCL Thermal	6132	6460	6481	5625
MSPGCL Hydro	272	177	1278	172
MSPGCL Gas	91	89	91	94
MSPGCL Total Generation	6495	6726	7850	5891
Central Sector Receipt	7054	7087	6326	5074
WIND	543	233	380	500
CPP / IPP Thermal	4966	5140	5693	4399
CPP / IPP Gas	0	0	0	0
SOLAR	1683	929	0	0
Exchange with Mumbai	-1691	-2044	-1357	-1287
MSEDCL DEMAND MET	18617	17647	18451	14217
Load Shedding	0	0	0	0
MSEDCL DEMAND	18617	17647	18451	14217
TPCL GENERATION	819	578	1001	595
AEML GENERATION	467	284	462	302
MUMBAI DEMAND	2977	2906	2820	2184
OTHER DISCOM DEMAND	433	424	441	360
STATE DEMAND MET	22027	20977	21712	16761
STATE DEMAND	22027	20977	21712	16761
Frequency (Hz)	49.97	50.00	50.02	50.01

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.15 Hz at 14:01 Hrs	49.67 Hz at 07:36 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Nov/2022

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	4.72	4.72	210	180
Unit 7	0.00	0.00	0	0
Unit 8	12.30	12.30	546	481
Unit 9	12.18	12.18	540	472
Unit 10	9.19	9.19	400	350
Total	38.39	38.39		
Bhusawal				
Unit 3	0.00	0.00	0	0
Unit 4	8.45	8.45	415	285
Unit 5	9.06	9.06	460	280
Total	17.51	17.51		
Parli				
Unit 6	2.41	2.41	176	0
Unit 7	4.08	4.08	241	140
Unit 8	3.52	3.52	158	141
Total	10.01	10.01		
Chandrapur				
Unit 3	3.08	3.08	150	100
Unit 4	2.97	2.97	150	105
Unit 5	6.81	6.81	335	250
Unit 6	6.76	6.76	390	0
Unit 7	7.39	7.39	350	285
Unit 8	8.99	8.99	467	276
Unit 9	8.91	8.91	440	300
Total	44.90	44.90		
Paras				
Unit 3	5.52	5.52	241	219
Unit 4	0.00	0.00	0	0
Total	5.52	5.52		
Khaparkheda				
Unit 1	2.78	2.78	135	90
Unit 2	3.00	3.00	145	110
Unit 3	3.26	3.26	148	128
Unit 4	3.19	3.19	145	125
Unit 5	9.13	9.13	470	275
Total	21.36	21.36		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	3.23	3.23	177	118
Unit 5	2.98	2.98	165	105
Total	6.20	6.20		
Uran				
All Units	2.22	2.22	96	89
Total	2.22	2.22		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	1.03	1.03	48	35
Total	1.03	1.03		
Koyana				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	2.16	2.16	450	40
Stage 4	1.21	1.21	622	0
Stage 3	0.69	0.69	160	0
Total	4.06	4.06		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.04	0.04	30	0
SMLHY_PTN	1.67	1.67	79	64
GHATGHAR	0.39	0.39	125	0
Total	2.10	2.10		
Wind				
Total	9.10	9.10	0	0
Total	9.10	9.10		
CPP				
APML(Mus)	52.74	52.74	0	0
JSWEL(Mus)	12.67	12.67	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	25.58	25.58	0	0
SWPGPL-Mus	5.35	5.35	0	0
Other(Mus)	23.08	23.08	0	0
Total	119.42	119.42		
SOLAR				
Total	12.48	12.48	0	0
Total	12.48	12.48		
Tata				
Trombay 5	6.75	6.75	367	266
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.36	1.36	107	37
Trombay 7B	1.08	1.08	65	35
TATA Hydro	3.71	3.71	398	19
Trombay 8	3.23	3.23	163	127
Total	16.13	16.13		
AEML				
DTPS U-1&2	7.94	7.94	475	284
Total	7.94	7.94		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	143.90	143.90	MSPGCL Total	153.30	153.30
			MSPGCL Thml+Gas	146.12	146.12	Koyna 1,2 & 4 Total	3.37	3.37
			MSPGCL Hydro	7.19	7.19	State Total	318.38	318.38

State Load Despatch Center,Airoli (MSETCL)

Hourly Load Data As on 01/Nov/2022

Annexure-2

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAN D	OTHER DISCOM DEMAN D	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	5625	172	94	5891	500	4399	0	0	5066	5074	-1287	14217	0	14217	2184	360	16761	50.01
2	5554	164	94	5812	482	4569	0	0	4996	5104	-1205	14421	0	14421	2045	341	16807	50.01
3	5570	159	94	5823	424	4608	0	0	5161	5113	-1110	14556	0	14556	1919	302	16777	49.99
4	5561	159	94	5814	408	4579	0	0	5213	5378	-1040	14825	0	14825	1845	314	16984	50.01
5	5722	159	94	5975	325	4731	0	0	5337	5864	-1005	15582	0	15582	1814	308	17704	50.01
6	6271	159	95	6525	347	5040	0	0	5740	5814	-1122	16259	0	16259	1922	345	18526	50.00
7	6447	321	95	6863	361	5242	0	35	6416	6455	-1159	17427	0	17427	2025	370	19822	49.91
8	6571	189	96	6856	390	5366	0	370	6553	6500	-1296	17806	0	17806	2199	380	20385	49.86
9	6357	153	94	6604	363	5369	0	919	6616	6818	-1535	18131	0	18131	2487	407	21025	49.97
10	6145	264	92	6501	492	5052	0	1347	6911	7063	-1743	18288	0	18288	2776	424	21488	50.00
11	6132	272	91	6495	543	4966	0	1683	7164	7054	-1691	18617	0	18617	2977	433	22027	49.97
12	5630	231	92	5953	418	4708	0	1856	7385	7446	-1762	18206	0	18206	3017	413	21636	49.98
13	5475	149	90	5714	392	4515	0	1790	7663	7555	-1998	17568	0	17568	2964	400	20932	49.96
14	5371	146	89	5606	350	4515	0	1667	7485	7881	-1987	17632	0	17632	2843	400	20875	50.00
15	5746	196	89	6031	224	4644	0	1334	7331	7247	-2007	17064	0	17064	2868	409	20341	49.96
16	6460	177	89	6726	233	5140	0	929	7167	7087	-2044	17647	0	17647	2906	424	20977	50.00
17	6598	214	89	6901	184	5360	0	490	6823	6553	-1888	17163	0	17163	2872	437	20472	49.94
18	6530	1121	90	7741	285	5535	0	64	5775	5550	-1508	17221	0	17221	2811	446	20478	49.93
19	6481	1278	91	7850	380	5693	0	0	6148	6326	-1357	18451	0	18451	2820	441	21712	50.02
20	6450	370	91	6911	389	5500	0	0	6654	6632	-1305	17699	0	17699	2711	428	20838	50.02
21	6007	237	93	6337	402	5240	0	0	6213	6148	-1440	16247	0	16247	2585	440	19272	50.02
22	5772	373	93	6238	413	4922	0	0	5624	5954	-1441	15648	0	15648	2467	438	18553	50.02
23	5790	274	94	6158	369	4871	0	0	5401	5474	-1380	15075	0	15075	2356	417	17848	50.01
24	5632	248	95	5975	421	4857	0	0	5340	5071	-1284	14650	0	14650	2254	390	17294	49.90
MUs	143.90	7.19	2.22	153.30	9.09	119.42	0.00	12.48	150.18	151.16	-35.59	400.40	0.00	400.40	59.67	9.47	469.53	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Nov/2022

Position as on 6.30 Hrs of 02/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
MSPGCL	Koyna Unit 9	80	15/06/2022	08:00		Continued.	Capital Overhaul	15/11/2022
MSPGCL	Bhusawal Unit 3	210	15/10/2022	15:10		Continued.	ZERO SCHEDULE	
FORCED OUTAGE								
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
CENT.SECTOR	Tarapur 1	160	08/01/2020	10:37		Continued.	Refueling. While refueling preparation, some repair works identified which are being executed before refueling.	31/03/2023
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	30/12/2022
CENT.SECTOR	Tarapur 2	160	13/07/2020	04:38		Continued.	For cleaning of clogged basket strainer of cooling water system due to heavy ingress of debris from sea. The outage extended for repair and re-fueling.	31/03/2023
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Ghatghar Unit-1	125	20/04/2022	00:35		Continued.	Stator Earth Fault	15/11/2022
MSPGCL	Uran Unit A0	120	07/09/2022	16:30		Continued.	TURBINE TRIPPED ON HIGH VIBRATIONS	
IPP	RPL(AMT) U-5	270	06/10/2022	21:33		Continued.	Furnace Pressure High	05/11/2022
MSPGCL	Nasik Unit 3	210	08/10/2022	20:05		Continued.	PA FAN 3B motor replacement work Unit # 3 Nashik is under tolling from 08:00 hrs of 10/10/2022 & is available (as PA FAN 3B work is completed)	
MSPGCL	Uran Unit B0	120	09/10/2022	11:53		Continued.	TURBINE PROTECTION OPERATED	06/11/2022
MSPGCL	Uran Unit 8	108	09/10/2022	12:30		Continued.	BOILER PROBLEM	06/11/2022
IPP	JSW (J) U1	300	11/10/2022	02:40		Continued.	No Schedule	
IPP	SWPGPL U-3	135	21/10/2022	01:33		Continued.	Coal Shortage	
MSPGCL	Paras Unit 4	250	22/10/2022	16:51		Continued.	Turbine Vibration	05/11/2022
IPP	SWPGPL U-1	135	23/10/2022	20:29		Continued.	PA Fan Vibration Problem	04/11/2022
MSPGCL	Uran Unit 6	108	29/10/2022	11:59	02/11/2022	18:00	Gas shortage	
IPP	Adani U-4	660	31/10/2022	08:11		Continued.	APH-B hot PA bellow leakage.	03/11/2022
MSPGCL	Parli Unit 6	250	01/11/2022	11:05	01/11/2022	19:38	local AC FAILURE.	
MSPGCL	Chandrapur Unit 6	500	01/11/2022	21:46	02/11/2022	22:38	LOSS OF CONTROL POWER	02/11/2022
MSPGCL	Parli Unit 6	250	02/11/2022	06:20	02/11/2022	20:16	BFP Suction low and Deaerator level not maintained, suspected	04/11/2022

State Load Despatch Center,Airoli (MSETCL) Statement-VI
Details of Generating Unit Outages/Trippings for 01/Nov/2022

Position as on 6.30 Hrs of 02/Nov/2022

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
MSPGCL	Uran Unit 5	108	02/11/2022	17:35		Continued.	Valve malfunction	
							URAN GT5 CHANGEOVER TO GT6	

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Tripping for 01/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 02/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
765 KV MAINBAY Outages/Tripping							
MAIN BAY (706) OF BUS REACTOR @ KORADI 3	IntraState	02/11/2022	09:00	02/11/2022	18:17	PO	Annual Maintenance of Bay Equipment
500 KV LINE Outages/Tripping							
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	01/11/2022	22:11	01/11/2022	23:31	EO	Emergency shutdown of HVDC Pole 1 - Base Filter Z11-Z1 & Z11-Z2 for attending the Red hot observed at connecting jumper of capacitor bushing
400 KV TIEBAY Outages/Tripping							
TIE BAY (406) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	02/11/2022	14:59	02/11/2022	18:40	PO	for routine diagnostic testing work of CT tan delta
400 KV MAINBAY Outages/Tripping							
400KV MAIN BAY 413 OF SPARE BAY @ CHANDRAPUR 2	InterState	23/06/2022	20:33			EO	for requirement of trip coil material from 400 kv spare bay 413 CB and utilise it in 400 kv Warora Ckt 2 CB 425
MAIN BAY (405) OF KHADKA CKT - 1 @ DEEPNAGAR	IntraState	02/11/2022	11:08	02/11/2022	13:14	PO	For Routine Diagnostic Testing work for CT tan Delta
400 KV LINE Outages/Tripping							
KARAD - LONIKAND I	IntraState	10/10/2022	09:28			PO	1. Errection of 315A & 316 in line tower. 2. Loc no. 315 to 315A S/C stringing. 3. Loc no. 315A to 33(D/C LILO tower) stringing. 4. Loc No. 316 to 33(D/C LILO tower) stringing. 5. Dismantling of existing in line tower at loc no 316.
AURANGABAD(MS) - PUNE (GIS) CKT - 1	IntraState	20/10/2022	10:27			HT	For Load management
KHADKA-AURANGABAD (WALUJ)	IntraState	31/10/2022	21:39	01/11/2022	05:48	HT	TO CONTROL OVERVOLTAGE
DEEPNAGAR - THAPTI TANDA	IntraState	01/11/2022	06:33	01/11/2022	18:38	PO	for replacement of faulty insulator strings by long rod insulator
KHADKA-AURANGABAD (WALUJ)	IntraState	01/11/2022	22:13	02/11/2022	05:54	HT	Over voltage
BABHALESHWAR - PADGHE CKT - 2	IntraState	02/11/2022	00:05	02/11/2022	03:20	EO	"Work to be carried on Line :- To attend and fix repair sleeves at broken Conductor strands at Suspension Towers. Loc. No. :- 924(Y-Phase = 2 nos.) under 500kv HVDC TL O&M Sub Division, Padghe."
JAIGAD - KARAD CKT - 1	IntraState	02/11/2022	03:38	02/11/2022	08:16	HT	Over voltage
DEEPNAGAR - THAPTI TANDA	IntraState	02/11/2022	06:11	02/11/2022	18:55	HT	Planned outage
NEW KOYNA - DABHOL CKT - 2	IntraState	02/11/2022	10:00	02/11/2022	17:30	PO	Cold washing work
400 KV ICT Outages/Tripping							
STATION TF-3 @ KORADI 2	IntraState	01/11/2022	10:37	01/11/2022	20:20	PO	Tan delta measurement of Line CT
400/220/33 KV 315 MVA ICT - 2 @ PADGHE	IntraState	02/11/2022	09:18	02/11/2022	17:58	PO	Shifting of 400/220kv 315MVA ICT -2 LV Bay on TBC For replacement heavily rusted Rotary Housing Bearing of A & B Bus RYB Phase Isolators of said ICTs & A&B Bus Jumper will be removed by Hot Line unit Kharghar/Kalwa after shifting on TBC & vice versa .
220 KV TIEBAY Outages/Tripping							

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 02/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
MAIN BUS SECTIONALIZER -2 @ GHODBUNDER (GIS)	IntraState	02/11/2022	08:23	02/11/2022	17:28	PO	Annual Maint of Bus Sectionalizer 2. facilitating outage of 220kV Main Bus 2
220 KV MAINBAY Outages/Trippings							
BUS SECTINLISER @ PEGASUS	IntraState	01/11/2022	10:34	01/11/2022	19:42	EO	CB overhauling work
AIS 220KV BUS COUPLER @ GHODBUNDER	IntraState	02/11/2022	08:25	02/11/2022	17:24	PO	Annual Maint of Bus Coupler. facilitating outage of 220kV Main Bus 2
220 KV LINE Outages/Trippings							
AAREY - MSETCL BORIVALI CKT - 2	IntraState	24/10/2022	22:53			T	R-ph Differential Protection
EKLAHARE (OCR) - PADGHE	IntraState	01/11/2022	09:32	01/11/2022	22:24	HT	H/T TO CONTROL BBLR LINE LOADING
MUMEWADI -HALKARNI 1 LINE	IntraState	01/11/2022	10:15	01/11/2022	11:27	PO	For replacement of flashover insulator at location no 217 B PH
TBC @ KHARGHAR	IntraState	01/11/2022	10:30	01/11/2022	17:52	EO	A Bus Isolator alignment work and replacing broken down pipe and removing A Bus, B-phase Jump removing by Hotline method
VITA - MIRAJ	IntraState	01/11/2022	11:08	01/11/2022	14:13	PO	Relay testing work
PADGHE - NALASOPARA - VASAI (T)	IntraState	01/11/2022	11:36	01/11/2022	14:11	T	TRIPPED ON DISTANCE PROTECTION
TOPWORTH - Vile - bhagad	IntraState	01/11/2022	12:07	01/11/2022	18:14	PO	Replacement of Flashover insulator string at Loc.No.3A-R Phase and Replacement of Jumper at Loc.No.19B and other line maintenance work.
HINJEWADI 2 - PEGASUS	IntraState	01/11/2022	18:53	01/11/2022	19:30	HT	For Outage of Bus sectionalizer at Pegasus S/S
BIDRI - SAWANTWADI	IntraState	02/11/2022	00:20	02/11/2022	08:25	HT	Over voltage
MAIN BUS - 2 @ GHODBUNDER	IntraState	02/11/2022	08:25	02/11/2022	17:24	PO	Annual Maintenance of 220kV Main Bus 2 and Bus side connected isolator
ONI KHAREPATAN LINE	IntraState	02/11/2022	09:21	02/11/2022	20:29	PO	Replacement of R & B-Ph CT, C& Tan delta of CT and bay maintenance at Oni end.
BABLESHWAR -AHAMADNAGAR-I-JEUR TAP	IntraState	02/11/2022	09:32	02/11/2022	18:39	PO	1. ATTENDING THE LOW CLEARANCE PROBLEM AT LOC 37-38 OF THE LINE. THE GROUND TO B PH CLEARANCE IS 5.1 METER WHICH IS LOW AS PER THE IE RULE. There is sugarcane crop below the above location which can rise up to the tower B ph conductor thus leading to burning of crop due to our line . PID faulty STRING REPLACEMENT WORK 1)STN LOC NO 1-Y BBLR Side, 12-B BBLR Side, 15-B BBLR
TROMBAY MSETCL TIE - 1	IntraState	02/11/2022	09:38	02/11/2022	12:12	PO	Breaker replacement at Tata and MSETCL end
WATHAR - MUDSHINGI 3 LINE	IntraState	02/11/2022	10:17	02/11/2022	17:04	PO	Quarterly Maint .work
NAGOTHANE - POSCO	IntraState	02/11/2022	12:06	02/11/2022	17:38	EO	Broken earth wire dismantling and fixing of new earth wire at Loc no.24-25
ACCIL - APTA	IntraState	02/11/2022	15:57			EO	CB DC leakage attending work by testing divison panvel.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Nov/2022

Statement-VII

Position as on 6.30 Hrs of 02/Nov/2022

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
TROMBAY MSETCL TIE - 2	IntraState	02/11/2022	18:23		Continued.	EO	1) Hotspot at 29B GOD for C phase (GOD alignment to be done) at Tata end. 2) Hotspot on Breaker Palm towards 29A for B phase (Flexible jumper to be changed) at Tata End. 3) Hotspot on Vertical dropper on C phase and also bolt replacement on CT (Vertical dropper to be changed) at MSETCL end.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 1 @ SALSETTE	IntraState	12/10/2020	11:35			T	Tripped due to Grid disturbance.
220/132KV 100MVA PTR 1 @ KHAREPATAN	IntraState	22/09/2022	16:35			T	ICT bursted
220/132 KV 200 MVA ICT 2 @ MALEGAON	IntraState	01/11/2022	15:26	01/11/2022	18:01	PO	Replacement work of old & faulty WTI meters at 220/132kV, 200MVA, ICT-II, HV/LV side.
220/132 KV 100MVA ICT 2 @ SOUTH SOLAPUR	IntraState	02/11/2022	11:29	02/11/2022	16:20	PO	Outage is required for Quarterly Maintenance
220 KV BR Outages/Trippings							
BUS REACTOR (48-120 MVAR) @ GORAI	IntraState	01/11/2022	21:00	02/11/2022	07:00	PO	Fine tuning of CSD relay (CB operations-On line & Off line)
110 KV LINE Outages/Trippings							
DHARAVI VIKHROLI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.
DHARAVI POWAI	IntraState	30/08/2021	00:03			PO	Shifting of OPGW and stringing of conductor of 220 kV Trombay-Dharavi- Salsette line and replacement and shifting of conductor of Dharavi Powai and Dharavi Vikhroli line on new tower and dismantling old towers in section 32 to 38. 110 KV Vikhroli Powai line will be formed for dual feed to Vikhroli and Powai.

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage