

State Load Despatch Center, Airoli (MSETCL) Statement I
Daily system Report for 01/Dec/2021 WEDNESDAY

I GENERATION (MUs)			II EXCHANGES (MUs)		
A) MSPGCL	Daily	Monthly	E) InterState Exchanges	Daily	Monthly
1) Thermal	136.913	136.913	1) Gujrat	-7.132	-7.132
2) Hydro	6.158	6.158	2) Madhya Pradesh	3.743	3.743
3) Gas	5.757	5.757	3) Chattisgarh	4.520	4.520
Total MSPGCL	148.828	148.828	4) Maharashtra	126.279	126.279
B) 1) APLM	50.168	50.168	5) Goa (Amona)	-1.851	-1.851
2) JSWEL	14.095	14.095	Total	125.559	125.559
3) VIPL	0.000	0.000	a) Mumbai Schedule	26.334	26.334
4) RPL(AMT)	20.601	20.601	b) Mumbai Drawl	25.354	25.354
5) SWPGPL	7.599	7.599	c) MSEDCL Bilateral *	19.111	19.111
6) Other IPP	36.797	36.797	Include PX	0.000	0.000
7) PGPL	0.000	0.000	d) Mumbai Bilateral *	26.334	26.334
C) 1) TPCL Thermal	11.412	11.412	Include PX	0.000	0.000
2) TPCL Hydro	4.441	4.441	Standby	0.000	0.000
3) TPCL Gas	3.006	3.006	H) ENERGY CATERED (MUs)		
4) AEML Thermal	9.348	9.348	1) MSEDCL	396.113	396.113
D) STATE			2) Mumbai Discoms	53.561	53.561
1) Thermal	286.933	286.933	3) Other Discoms	9.513	9.513
(A1+C1+C4+(B1-B6))			TOTAL STATE	459.187	459.187
2) Hydro	10.599	10.599			
(A2+C2)					
3) Gas	8.763	8.763			
(A3+B7+C3)					
4) Wind	23.429	23.429			
6) SOLAR	3.904	3.904			
TOTAL STATE	333.628	333.628			

* Displayed for information, not added in total.

DETAILS OF MAHARASHTRA STATE PEAK DEMAND(MW) Statement II

PARTICULARS	A. Morning Peak at 11 Hrs	B. Day Peak at 13 Hrs	C. Evening Peak at 19 Hrs	D. Night Minimum at 24 Hrs
MSPGCL Thermal	6578	6036	6214	4627
MSPGCL Hydro	334	190	626	194
MSPGCL Gas	251	259	260	259
MSPGCL Total Generation	7163	6485	7100	5080
Central Sector Receipt	6270	6312	4759	3905
WIND	695	556	997	886
CPP / IPP Thermal	6144	5523	5760	4485
CPP / IPP Gas	0	0	0	0
SOLAR	566	612	0	0
Exchange with Mumbai	-1292	-1320	-888	-910
MSEDCL DEMAND MET	6319	5142	4279	1720
Load Shedding	0	0	0	0
MSEDCL DEMAND	6319	5142	4279	1720
TPCL GENERATION	972	888	1124	533
AEML GENERATION	466	441	423	287
MUMBAI DEMAND	2730	2649	2435	1730
OTHER DISCOM DEMAND	348	343	354	309
STATE DEMAND MET	22276	20817	20163	15176
STATE DEMAND	22276	20817	20163	15176
Frequency (Hz)	49.99	49.87	50.00	49.95

FREQUENCY PARTICULARS

MAXIMUM FREQ.	MINIMUM FREQ.	AVERAGE FREQ.	FREQ. BELOW 49.4 Hz
50.24 Hz at 22.00 Hrs	49.71 Hz at 12.21 Hrs	49.98	0 % of Time(min)

Note : The report is based on Operational Data and is for statistical purpose only.

Daily and Progressive Generation,Maximum,Minimum for 01/Dec/2021

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Koradi				
Unit 6	3.48	3.48	185	115
Unit 7	0.00	0.00	0	0
Unit 8	12.61	12.61	636	372
Unit 9	0.00	0.00	0	0
Unit 10	12.68	12.68	612	373
Total	28.76	28.76		
Bhusawal				
Unit 3	3.22	3.22	165	120
Unit 4	8.78	8.78	450	280
Unit 5	8.54	8.54	450	280
Total	20.54	20.54		
Parli				
Unit 6	3.90	3.90	240	144
Unit 7	0.00	0.00	0	0
Unit 8	3.85	3.85	205	148
Total	7.75	7.75		
Chandrapur				
Unit 3	0.00	0.00	0	0
Unit 4	3.45	3.45	161	122
Unit 5	7.64	7.64	370	280
Unit 6	7.30	7.30	380	245
Unit 7	7.75	7.75	359	286
Unit 8	9.24	9.24	431	285
Unit 9	9.32	9.32	445	281
Total	44.70	44.70		
Paras				
Unit 3	3.98	3.98	216	140
Unit 4	3.92	3.92	207	139
Total	7.90	7.90		
Khaparkheda				
Unit 1	3.12	3.12	155	115
Unit 2	3.14	3.14	170	110
Unit 3	3.46	3.46	178	127
Unit 4	2.37	2.37	168	0
Unit 5	9.18	9.18	450	280
Total	21.27	21.27		
Nasik				
Unit 3	0.00	0.00	0	0
Unit 4	2.94	2.94	140	117
Unit 5	3.04	3.04	187	115
Total	5.98	5.98		
Uran				
All Units	5.76	5.76	260	197
Total	5.76	5.76		
PGPL				
Unit 1	0.00	0.00	0	0
Unit 2	0.00	0.00	0	0
Total	0.00	0.00		
PENCH (MS)				
Pench (MS)	0.10	0.10	22	0
Total	0.10	0.10		
Koyna				

Generating unit	Generation			
	Daily (Mus)	Monthly (Mus)	Max (MW)	Min (MW)
Stage 1-2	1.68	1.68	290	40
Stage 4	0.10	0.10	97	0
Stage 3	0.78	0.78	80	0
Total	2.56	2.56		
Hydro				
KDPH	0.00	0.00	0	0
VTRNA	0.00	0.00	0	0
TILLARI	0.00	0.00	0	0
BHIRA T.R.	0.26	0.26	80	0
SMLHY_PTN	3.34	3.34	157	117
GHATGHAR	0.00	0.00	0	0
Total	3.60	3.60		
Wind				
Total	23.43	23.43	0	0
Total	23.43	23.43		
CPP				
APML(Mus)	50.17	50.17	0	0
JSWEL(Mus)	14.10	14.10	0	0
VIPL(Mus)	0.00	0.00	0	0
RPLAMT-Mus	20.60	20.60	0	0
SWPGPL-Mus	7.60	7.60	0	0
Other(Mus)	36.80	36.80	0	0
Total	129.26	129.26		
SOLAR				
Total	3.90	3.90	0	0
Total	3.90	3.90		
Tata				
Trombay 5	6.80	6.80	368	250
Trombay 6	0.00	0.00	0	0
Trombay 7A	1.74	1.74	95	59
Trombay 7B	1.27	1.27	60	47
Trombay 8	4.62	4.62	217	141
TATA Hydro	4.44	4.44	429	0
Total	18.86	18.86		
AEML				
DTPS U-1&2	9.35	9.35	472	287
Total	9.35	9.35		

* Infirm Power			Summary			Summary		
Particulars	Daily (Mus)	Monthly	Particulars	Daily (Mus)	Monthly (Mus)	Particulars	Daily (Mus)	Monthly (Mus)
			MSPGCL Thermal	136.91	136.91	MSPGCL Total	148.83	148.83
			MSPGCL Thml+Gas	142.67	142.67	Koyna 1,2 & 4 Total	1.78	1.78
			MSPGCL Hydro	6.16	6.16	State Total	333.63	333.63

State Load Despatch Center,Airoli (MSETCL)

Annexure-2

Hourly Load Data As on 01/Dec/2021

TIME SR. NO.	MSPGCL GEN.			TOTAL	WIND	CPP / IPP		SOLAR	CS SHARE	CS RECPT	Mum. NET EXCH.	MSEDC L DEM. MET	LOAD SHED DING	MSEDC L DEM. WITH LS	MUMBAI DEMAND	OTHER DISCOM DEMAND	STATE DEMAND	FREQ. (Hz)
	THM	HY	GAS			THM	GAS											
1	4894	199	235	5328	1239	5018	0	0	5334	4918	-1184	15016	0	15016	2190	303	17509	50.01
2	4704	230	206	5140	1165	4818	0	0	5361	5415	-1089	15168	0	15168	2038	281	17487	49.98
3	4846	194	216	5256	1270	4830	0	0	5253	4995	-1000	15072	0	15072	1932	279	17283	49.97
4	4824	205	197	5226	1237	4971	0	0	5158	5229	-932	15459	0	15459	1840	272	17571	49.96
5	5423	198	206	5827	1212	5015	0	0	5091	4927	-912	15785	0	15785	1827	284	17896	50.01
6	6049	269	217	6535	1232	5332	0	0	5224	5247	-915	17103	0	17103	1889	328	19320	50.02
7	6397	287	237	6921	1166	5837	0	3	5355	5203	-945	17828	0	17828	1978	357	20163	50.02
8	6631	272	248	7151	974	6261	0	78	5427	5461	-887	18662	0	18662	2135	376	21173	49.99
9	6771	276	239	7286	913	6306	0	258	5840	5836	-1120	19109	0	19109	2380	370	21859	49.90
10	6598	361	239	7198	914	6035	0	408	6404	6264	-1251	19202	0	19202	2611	366	22179	49.93
11	6578	334	251	7163	695	6144	0	566	6749	6270	-1292	19198	0	19198	2730	348	22276	49.99
12	6363	209	250	6822	563	5964	0	613	6874	6277	-1256	18630	0	18630	2727	353	21710	50.00
13	6036	190	259	6485	556	5523	0	612	6869	6312	-1320	17825	0	17825	2649	343	20817	49.87
14	6183	175	240	6598	603	5419	0	576	6291	5614	-1271	17179	0	17179	2500	360	20039	50.00
15	5935	157	250	6342	636	5443	0	418	6397	5773	-1148	17121	0	17121	2440	343	19904	49.98
16	5600	174	259	6033	698	5176	0	271	6304	5989	-1104	16717	0	16717	2399	346	19462	49.91
17	6066	173	249	6488	884	5384	0	93	5346	5229	-873	16844	0	16844	2281	361	19486	49.98
18	5970	252	240	6462	890	5548	0	8	5046	5084	-953	16671	0	16671	2411	368	19450	49.99
19	6214	626	260	7100	997	5760	0	0	4806	4759	-888	17374	0	17374	2435	354	20163	50.00
20	5975	345	250	6570	1207	5836	0	0	4650	3722	-969	16009	0	16009	2343	357	18709	50.00
21	4957	263	259	5479	1187	5046	0	0	5045	4480	-1053	14800	0	14800	2189	339	17328	49.95
22	4638	301	251	5190	1188	4581	0	0	4996	4602	-1057	14156	0	14156	2040	348	16544	50.01
23	4634	274	240	5148	1117	4528	0	0	4472	4048	-1025	13492	0	13492	1867	324	15683	50.00
24	4627	194	259	5080	886	4485	0	0	4120	3905	-910	13137	0	13137	1730	309	15176	49.95
MUs	136.91	6.16	5.76	148.83	23.43	129.26	0.00	3.90	132.41	125.56	-25.35	397.56	0.00	397.56	53.56	8.07	459.19	49.98

NOTE : ALL VALUES IN MW

Mumbai Net Exch is shown with reference to MSETCL system and (-) sign indicates MSETCL periphery to Mumbai system.

State Load Despatch Center,Airoli (MSETCL) Statement-VI

Details of Generating Unit Outages/Trippings for 01/Dec/2021

Position as on 6.30 Hrs of 02/Dec/2021

Generating Company	Name of Generating Unit	Capacity	Tripped Date	Tripped Time	Sync.Date	Sync. Time	Reason of Outage	Expected Date
PLANNED OUTAGE								
IPP	Adani U-4	660	10/11/2021	23.58		Continued.	Capital Overhauling	10/12/2021
MSPGCL	Koyna STG-IV Unit-4	250	22/11/2021	09.55		Continued.	Annual Overhaul	
FORCED OUTAGE								
IPP	SWPGL U-1	135	16/02/2016	17.09		Continued.	No PPA.	
PGPL	PGPL U1	262	07/02/2017	17.30		Continued.	No Schedule (NO PPA)	
PGPL	PGPL U2	126	07/02/2017	17.30		Continued.	No Schedule.(NO PPA)	
IPP	IEPL Unit 1	270	28/08/2018	21.26		Continued.	No PPA	
IPP	VIPL U-1	300	29/12/2018	00.30		Continued.	Coal Shortage. (NO PPA From 20.05.2019)	
IPP	VIPL U-2	300	17/01/2019	00.15		Continued.	Coal shortage.(NO PPA From 20.05.2019)	
MSPGCL	Uran Unit 7	108	25/05/2020	12.51		Continued.	Turbine Blade Failure	
MSPGCL	Koradi Unit 7	210	27/04/2021	20.03		Continued.	Retired (04/08/2021 At 00.00)	
MSPGCL	Nasik Unit 3	210	30/08/2021	22.51		Continued.	Against case 4.which was outage on Loss of Fuel(From 19.44Hrs DT.26-08-2021	
IPP	JSW (J) U1	300	02/09/2021	08.41		Continued.	Turbine vibrations high.	
MSPGCL	Uran Unit A0	120	10/09/2021	01.54		Continued.	Turbine bearing Vabration high	
MSPGCL	Uran Unit 5	108	07/11/2021	23.28		Continued.	Turbine problem.	
MSPGCL	Ghatghar Unit-2	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
MSPGCL	Ghatghar Unit-1	125	10/11/2021	23:55		Continued.	Static frequency controller disconnecting switch short circuit problem	10/03/2022
IPP	RPL(AMT) U-4	270	13/11/2021	07:15		Continued.	BOTTOM ASH PROBLEM	
IPP	RPL(AMT) U-4	270	16/11/2021	00.00		Continued.	Coal Shortage	
IPP	JSW (J) U2	300	19/11/2021	01:26		Continued.	No schedule.	
MSPGCL	Chandrapur Unit 3	210	23/11/2021	12:02		Continued.	ID Fan Problem	
MSPGCL	Parli Unit 7	250	28/11/2021	23.57		Continued.	Zero Schedule.	
MSPGCL	Khaparkheda Unit 4	210	01/12/2021	16:34	02/12/2021	20:11	Furnace Pressure High	
MSPGCL	Parli Unit 6	250	02/12/2021	00:00		Continued.	ZERO SCHEDULE	
MSPGCL	Chandrapur Unit 4	210	02/12/2021	00:17		Continued.	Boiler Tube Leakage	
MSPGCL	Parli Unit 8	250	02/12/2021	04:00		Continued.	ZERO SCHEDULE	07/12/2021
MSPGCL	Uran Unit 6	108	02/12/2021	07:45		Continued.	Gas shortage	
MSPGCL	Koyna Unit 7	80	02/12/2021	08:10	02/12/2021	18:20	Preventive Maintenance Work	
TPC-G	Trombay 7B	60	02/12/2021	17:13		Continued.	Gas shortage	
TPC-G	Trombay 7A	120	02/12/2021	17:22		Continued.	Gas shortage	
MSPGCL	Bhusawal Unit 3	210	02/12/2021	23:25		Continued.	Boiler Tube Leakage	

State Load Despatch Center, Airoli (MSETCL)
Details of Line outages/Trippings for 01/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 02/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
500 KV LINE Outages/Trippings							
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	01/12/2021	13:36	01/12/2021	22:34	T	AC Bus and Transformer Overcurrent protection
CHANDRAPUR - PADGHE HVDC POLE 2	IntraState	02/12/2021	10:22		Continued.	T	AC BUS & TRANSFORMER OVERCURRENT PROTECTION
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	02/12/2021	17:33	02/12/2021	18:04	HT	FOR METALIC RETURN MODE
CHANDRAPUR - PADGHE HVDC POLE 1	IntraState	02/12/2021	19:03	02/12/2021	20:55	T	POLE-1 ,BASE FILTER TRIPPED
400 KV MAINBAY Outages/Trippings							
BUS COUPLER @ KORADI	IntraState	02/12/2021	15:51	02/12/2021	19:00	EO	Emergency work for attending Hotspot on Bus-1 R ph PG isolator base clamp (Hotspot above 160°C)
400 KV LINE Outages/Trippings							
DHULE - SSNNL CKT - 1	InterState	01/12/2021	19:37	02/12/2021	16:05	T	Distance Protection, Z-1, B-ph, 2.57KA, 139KM from Dhule
AURANGABAD(MS) - PUNE (GIS) CKT - 2	IntraState	01/12/2021	09:04		Continued.	HT	OVER VOLTAGE
KOLHAPUR (TALANDGE) - ALKUD	IntraState	01/12/2021	10:27	01/12/2021	17:45	PO	Line outage required for replacement of tension insulator at tower nos: 474, 477, 545, 561, 574 & 577.
JAIGAD - KARAD CKT - 1	IntraState	01/12/2021	20:02	02/12/2021	07:31	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	01/12/2021	22:09	02/12/2021	07:33	HT	over voltage.
KARAD - TALANDGE CKT - 1	IntraState	01/12/2021	23:48		Continued.	HT	over voltage
PADGHE - NAGOTHANE CKT - 1	IntraState	01/12/2021	23:55	02/12/2021	08:24	HT	OVER VOLTAGE
NAGOTHANE - DABHOL CKT - 1	IntraState	02/12/2021	02:00	02/12/2021	10:57	T	DIST. PROTECTION
CHANDRAPUR-PARLI CKT-3	IntraState	02/12/2021	09:57	02/12/2021	16:40	PO	(1) C & tan delta measurement of reactor. (2) Bay maintenance work. disc replacement at loc.583 ,631 and earthwire clamping which is rest on cross arm 613 and corona ring fixing at various location (8 location)
LONIKAND I - JEJURI	IntraState	02/12/2021	11:42	02/12/2021	17:25	PO	Half yearly bay maintenance and DT work. DT/Line Maintenance (Insulator String Replacement work, Loc No 1-32)
JAIGAD - KARAD CKT - 1	IntraState	02/12/2021	22:21		Continued.	HT	HT FOR OVERVOLTAGE
LONIKAND I - KOYNA STAGE-IV	IntraState	02/12/2021	23:11		Continued.	HT	HT FOR OVERVOLTAGE
400 KV ICT Outages/Trippings							
400/220/33 KV 315 MVA ICT - 2 @ CHANDRAPUR	IntraState	01/12/2021	10:43		Continued.	PO	1) Replacement of 400KV HV Bushings of R & B-ph ICT units. 2) Servicing & Maintenance of CTR make NIFPS. Of R, Y & B-ph ICT units. 3) Inspection of GE make 400KV CB of ICT-2 HV bay. 4) Replacement of support structure of B-ph 400KV HV CT. 5) MTAMC project work.
400/220/33 KV 500 MVA ICT - 3 @ KOLHAPUR	IntraState	01/12/2021	18:10	01/12/2021	19:36	T	NDR PROTECTION
220 KV LINE Outages/Trippings							
PADGHA - TEMGHAR - 1	IntraState	30/11/2021	10:51		Continued.	HT	line work
GHODBUNDER - GORAI	IntraState	01/12/2021	00:43	01/12/2021	06:03	PO	For lowering of cage for Monopole LS P3 under Relocation/Modification of existing lines infringing Metro 09 route Project.

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 02/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
VERSOVA - GHODBUNDER	IntraState	01/12/2021	00:52	01/12/2021	08:25	PO	For lowering of cage for Monopole LS P3 under Relocation/Modification of existing lines infringing Metro 09 route Project.
KARAD -MUDSHINGI CKT- 4	IntraState	01/12/2021	09:41	01/12/2021	18:54	PO	For replacement disc insulator string by long rod AF insulator string in foggy region at tower Location no-114,121,129,130 to 132,134,157,164,174
TROMBAY - SALSETTE CKT - 1	IntraState	01/12/2021	10:00	01/12/2021	15:58	PO	METRO WORK
MIRAJ - MHAISHAL	IntraState	01/12/2021	10:06	01/12/2021	13:28	PO	Quarterly maintenance work. CT tan delta measurement work
THEUR-PHURSUNGI CKT I	IntraState	01/12/2021	10:15	01/12/2021	18:28	PO	For wiring of new A/R scheme & taking A/R into service.
PADGHE - JINDAL	IntraState	01/12/2021	10:55	01/12/2021	18:07	PO	1.Y-Ph CT to Breaker damage conductor replacement.2.Bay Maintenance.
MAIN BUS SECTION - 1 @ PANDHARPUR	IntraState	01/12/2021	12:10	01/12/2021	17:54	EO	BPH PT BURST OF 132 kV MAIN BUS SECTION 1,HENCE THIS SHOULD BE REPLACED ON URGENT BASIS
KADEGAON-MIRAJ	IntraState	01/12/2021	14:29	01/12/2021	20:26	PO	Quarterly maintenance work. CT tan delta measurement work
DAHANU - GHODBUNDER CKT - 1	IntraState	01/12/2021	15:07	02/12/2021	09:46	T	Dist. Protection, R-ph, 5.96KA, 28.04KM from Ghodbunder
KHAREPATAN -PAWAS LINE	IntraState	02/12/2021	11:07	02/12/2021	17:07	PO	C & Tan delta testing of Line CTs; CRM & timing test of CB at Kharepatan end.
URAN - APTA 2	IntraState	02/12/2021	11:22	02/12/2021	18:37	PO	For providing of missing earthwire at Loc.No.43 to 46
WATHAR - MUDSHINGI 3 LINE	IntraState	02/12/2021	12:14	02/12/2021	17:26	PO	For disc insulator string replacement replaced by long rod AF porcelain insulator in foggy region at tower LN-174,183,220.
HALKARNI-MAHALAXMI LINE	IntraState	02/12/2021	13:36	02/12/2021	15:15	T	Distance Protection
TILLARI - AMONA LINE	IntraState	02/12/2021	13:36	02/12/2021	14:35	T	Distance protection
MAHALAXMI - AMONA	IntraState	02/12/2021	13:36	02/12/2021	15:44	T	Distance Protection
URAN - HOC 1	IntraState	02/12/2021	14:53	02/12/2021	15:33	EO	earthwire at Loc No. 42 to 43 is found rusted and damaged and remained intact on only 2 strands. This earthwire may break and snapped on charged 220KV Apta-Uran 1 line
KAMBA - VASAI	IntraState	02/12/2021	18:15	02/12/2021	18:59	T	BUS BAR OPERATED AT KAMBA END
KAMBA - KOLSHET	IntraState	02/12/2021	18:15	02/12/2021	18:56	T	BUS BAR OPERATED AT KAMBA END
PADGHE - KAMBA 1	IntraState	02/12/2021	18:15	02/12/2021	18:42	T	BUS BAR OPERATED AT KAMBA END
PADGHE - KAMBA 2	IntraState	02/12/2021	18:15	02/12/2021	18:42	T	BUS BAR OPERATED AT KAMBA END
JEJURI - KONDHWA	IntraState	02/12/2021	18:55	02/12/2021	19:12	EO	for SF6 gas refilling work.
220 KV ICT Outages/Trippings							
220 / 110 / 22kV 250 MVA ICT 2 @ SALSETTE	IntraState	10/10/2020	07:39			PO	FOR CRP PANEL REPLACEMENT
220/132KV 100 MVA ICT NO 2 @ MAGARPATTA	IntraState	01/12/2021	14:32			PO	Replacement of existing 100 MVA ICT 02 by new 200 MVA ICT 02
220/132KV 200MVA PTR 2 @ LONAND	IntraState	01/12/2021	22:49	02/12/2021	17:55	T	TRIPPED ON BUCHHLZ INDICATION

State Load Despatch Center,Airoli (MSETCL)
Details of Line outages/Trippings for 01/Dec/2021

Statement-VII

Position as on 6.30 Hrs of 02/Dec/2021

Name of Line	Inter State / Intra State	Tripped Date	Tripped Time	Sync. Date	Sync. Time	Outage Type	Reason of Outage
220/100 KV 200 MVA ICT 4 @ KALWA	IntraState	02/12/2021	14:07	02/12/2021	18:01	EO	200MVA ICT-IV, CB Control Valve Heavy Air leakage on HV Side CB due to which compressor is continuously on.
220 KV BUSBAR Outages/Trippings							
MAIN BUS @ TOPWORTH	IntraState	01/12/2021	10:03	01/12/2021	17:01	PO	Post monsoon maintenance and red hotspot attending work

HT : Hand Tripping, T : Tripping, PO : Planned Outage, EO : Emergency Outage